



City of Ceres

Americans with Disability Act Self Evaluation and Transition Plan

August 2016



Table of Contents

1.0	ADA Self-Evaluation and Transition Plan Development Process	4
1.1	Introduction	4
1.1.1	Overview	4
1.1.2	Legislative Mandate	4
1.1.3	Discrimination and Accessibility	5
1.1.4	Undue Burden	6
1.2	ADA Self-Evaluation and Transition Plan Development Requirements.....	6
1.3	Self-Evaluation Process	7
1.3.1	Introduction.....	7
1.3.2	Program Accessibility Questionnaire	7
1.3.3	Review of Published Rules and Regulations	8
1.3.4	Public Participation Process.....	9
1.4	Facilities Survey.....	9
1.5	Curb Ramp Survey.....	11
2.0	Policies, Procedures and Program Accessibility: Findings and Recommended Actions .	12
2.1	Introduction.....	12
2.2	Overview and Individual Findings of Departmental Programs, Activities, and Services	12
2.3	Description of Programs and Services	12
2.4	Contact Information	14
2.5	Accessible/Adaptive Equipment.....	14
2.6	Customer Service	15
2.7	Notice Requirements.....	16
2.8	Printed Information.....	17
2.9	Website	17
2.10	Public telephones and communication devices.....	18
2.11	Training and Staffing	18
2.12	Program Eligibility and Admission	19
2.13	Public Meetings	19
2.14	Tours and Trips	20
2.15	Use of Consultants for Delivering Program Services	20
2.16	Emergency Evacuation Procedures.....	21
2.17	Facilities.....	21
2.18	Special Events on Public Properties	22
2.19	Municipal Code Review	22
3.0	Transition Plan	23
3.1	Introduction.....	23
3.2	Architectural Barrier for Facilities	23
3.2.1	Facility Reports.....	23
3.2.2	Criteria for Prioritizing the Plan for Facilities	23
3.2.3	Priorities for Facilities.....	24

3.2.4	New Construction and Renovations.....	24
3.2.5	Time Frames for Completion.....	25
3.3	Architectural Barrier for Curb Ramps	31
3.3.1	Curb Ramp Reports.....	31
3.3.2	Criteria for Prioritizing the Plan for Curb Ramps.....	31
3.3.3	Priorities of Curb Ramps	32
3.3.4	General Policies and Practices	34
3.3.5	Time Frames for Completion.....	35
4.0	ADA Coordinator.....	37
4.1	Complaint Procedures for Discrimination Based on Disability.....	48
5.0	Program Accessibility Guidelines, Standards & Resources	38
5.1	Introduction.....	38
5.2	Federal Accessibility Standards & Regulations & Resources	38
5.3	State of California Accessibility Standards & Regulations & Resources.....	39
5.4	General Disability Etiquette.....	40
5.5	State, and National Organizations who Provide Disability Services and Information ..	40
5.6	Accessible Websites.....	41
5.7	Emergency Preparedness	42
5.8	Funding for Projects.....	42

Appendix A - Accessibility Definitions

Appendix B - Programs/Services/Activities Self-Evaluation Questionnaire

Appendix C - Public Notices

Appendix D - ADA Service Accommodation Request Form

Appendix E - ADA Public Notice

Appendix F - ADA Grievance Form

Appendix G - Facility Summary of Architectural Barriers

Appendix H - Curb Ramp Summary List

1.0 ADA Self-Evaluation and Transition Plan Development Process

1.1 Introduction

1.1.1 Overview

The Americans with Disabilities Act (ADA) is a comprehensive civil rights law for persons with disabilities in both employment and the provision of goods and services. The ADA states that its purpose is to provide a “clear and comprehensive national mandate for the elimination of discrimination against individuals with disabilities.” Congress emphasized that the ADA seeks to dispel stereotypes and assumptions about disabilities and to assure equality of opportunity, full participation, independent living, and economic self-sufficiency for people with disabilities.

This ADA Self-Evaluation and Transition Plan is prepared to fulfill the requirements set forth in the ADA 1991 standards Title II Regulation. The ADA states that a public entity must reasonably modify its policies, practices, or procedures to avoid discrimination against people with disabilities. This report will assist the City of Ceres in identifying policy, program, and physical barriers to accessibility and in developing barrier removal solutions that will facilitate the opportunity of access to all individuals.

This report describes the process developed to complete the self-evaluation of City of Ceres’ programs, policies, and facilities; presents the findings of that evaluation; and provides recommendations and a Transition Plan for ensuring accessibility.

This report also provides the planning and implementation of necessary program and facility modification over the next several years. The ADA Self Evaluation and Transition Plan establishes the City of Ceres’ ongoing commitment to the development and monitoring of policies, programs and facilities to include all people.

1.1.2 Legislative Mandate

The development of a transition plan is a requirement of the federal regulations implementing the Rehabilitation Act of 1973, which require that all organizations receiving federal funds make their programs available without discrimination toward people with disabilities. The Act, which has become known as the “civil rights act” of persons with disabilities, states that:

No otherwise qualified handicapped individual in the United States shall, solely by reason of handicap, be excluded from the participation in, be denied the benefits of, or be subjected to discrimination under any program or activity receiving federal financial assistance. (Section 504)

Subsequent to the enactment of the Rehabilitation Act, Congress passed the Americans with Disabilities Act (ADA) on July 26, 1990. The Department of Justice’s Title II regulation adopts the general prohibitions of discrimination established under Section 504 and incorporates specific prohibitions of discrimination for the ADA. Title II provides protections to individuals with disabilities that are at least equal to those provided by the nondiscrimination provisions of

Title V of the Rehabilitation Act. This legislative mandate, therefore, prohibits the City of Ceres from, either directly or through contractual arrangements, from:

- Denying persons with disabilities the opportunity to participate in services, programs, or activities that are not separate or different from those offered others, even if the City offers permissibly separate or different activities.
- Determining the location of facilities, making selections that have the effect of excluding or discriminating against persons with disabilities.

Title II of the ADA stipulates that public entities must identify and evaluate all programs, activities, and services and review all policies, practices, and procedures that govern administration of the programs, activities, and services for all government entities employing more than fifty people. These administrative requirements include:

- Completion of a self-evaluation;
- Development of an ADA complaint procedure;
- Provide noticing of programs, activities and services in accessible formats;
- Designation of a person who is responsible for overseeing Title II compliance; and
- Development of a transition plan if the self-evaluation identifies any structural modifications necessary for compliance. The transition plan must be retained for three years.

In addition, the California Code of Regulations, Title 24, Part 2 mandates that all publicly funded buildings, structures, and related facilities shall be accessible to and usable by persons with disabilities. These regulations, which are often referred to as Title 24, pertain to the City of Ceres buildings and facilities that were constructed using state, City, or municipal funds or that are owned, leased, rented, contracted, or sublet by the City. Title 24 regulations and standards were also incorporated in the evaluation of architectural barriers in the City of Ceres.

1.1.3 Discrimination and Accessibility

There are two types of accessibility: physical accessibility and program accessibility. Absence of discrimination requires that both types of accessibility be provided.

Physical accessibility requires that a facility be barrier free. Barriers include any obstacles that prevent or restrict the entrance to or use of a facility. The ADA establishes requirements to ensure that buildings and facilities are accessible to and usable by people with disabilities. Design guidelines to achieve accessibility have been developed and are maintained by the U.S. Access Board under the jurisdiction of the ADA. The ADA Accessibility Guidelines (ADAAG) cover a wide variety of facilities (including buildings and outdoor recreation areas) and establish minimum accessibility requirements for new construction and alterations to these facilities.

Programmatic accessibility includes physical accessibility, but also entails all policies, practices, and procedures that permit people with disabilities to participate in programs and to access

important information. Program accessibility requires that individuals with disabilities be provided an equally effective opportunity to participate in or benefit from a public entity's programs and services.

The City may achieve program accessibility by a number of methods, both structural and non-structural:

- Structural methods such as altering an existing facility;
- Acquisition or redesign of equipment;
- Assignment of aides; and/or
- Providing services at alternate accessible sites.

When choosing a method of providing program access, the City will give priority to the one that results in the most integrated setting appropriate to encourage interaction among all users, including individuals with disabilities. In compliance with the requirements of the ADA, the City provides equality of opportunity but does not guarantee equality of results.

1.1.4 Undue Burden

The City does not have to take any action that it can demonstrate would result in a fundamental alteration in the nature of a program or activity, would create a hazardous condition for other people, or would represent an undue financial and administrative burden. This determination can only be made by the ADA Coordinator, department head, or designee and must be accompanied by a statement citing the reasons for reaching that conclusion.

The determination that an undue financial burden would result must be based on an evaluation of all resources available for use in a program. For example, if a barrier removal action is judged unduly burdensome, the City must consider other options for providing access that would ensure that individuals with disabilities receive the benefits and services of the program or activity.

1.2 ADA Self-Evaluation and Transition Plan Development Requirements

The Self-Evaluation is the City's assessment of its current policies, practices, and procedures. It identifies and corrects those policies and practices that are inconsistent with the requirements of Title II of the ADA. In keeping with these requirements and as part of the Self-Evaluation, the City of Ceres should:

- Identify all its programs, activities, and services; and
- Review all the policies, practices, and procedures that govern the administration of its programs, activities, and services.

The ADA also sets forth specific requirements for preparation of an acceptable Transition Plan. At a minimum, the elements of the plan should include:

- A list of the physical barriers in City facilities that limit the accessibility of its programs,

activities, or services to individuals with disabilities;

- A detailed outline of the methods to be used to remove these barriers and meet the current standards and accessibility regulations;
- A schedule for taking the steps necessary to achieve compliance with Title II of the ADA; and
- The name of the individual responsible for the Transition Plan implementation.

1.3 Self-Evaluation Process

1.3.1 Introduction

Services and programs offered by the City of Ceres to the public must be accessible. Accessibility applies to all aspects of a program or service, including advertisement, orientation, eligibility, participation, testing or evaluation, physical access, provision of auxiliary aids, and transportation.

The goals of the Self-Evaluation were:

1. To develop policy recommendations for the City and each of its departments, divisions, and programs;
2. To ensure that the views and comments from the public, City staff and the disability community are included in the City's policies; and
3. To foster ties between City staff and representatives of the disability community.

The process of making City facilities and programs accessible to all individuals will be an ongoing one, and the City will continue to review accessibility issues such as resolution of complaints and reasonable modifications to programs. The City will also periodically evaluate the success of improving access to programs by the practices and procedures developed during the Self-Evaluation process.

1.3.2 Program Accessibility Questionnaire

The Self-Evaluation of City of Ceres' services, programs, and activities required and involved the participation of all departments of the City. The City distributed a program accessibility questionnaire (a copy can be found in Appendix B) to each department for its staff to complete. Staff members were asked to complete a written program accessibility questionnaire on services and programs provided to the public and the locations at which these were provided. The survey included a review of the following information:

- A summary of the program and its purpose, the specific activities that comprise the program, and the nature of any advertising or program material produced;
- Any program or admission eligibility requirements;
- An overview of participation in the program, including who participates and how participation is facilitated;

- The methods used by the department to provide accessibility;
- Any access complaints or requests for improving access to the program;
- A list of facilities, or portions of facilities, used for the program and the activity that takes place there;
- Program providers, including outside organizations;
- Transportation services;
- Communication, including television, audiovisual presentations and the City's website;
- Emergency evacuation procedures;
- Public Telephones, Communication Devices, Accessible/Adaptive Equipment;
- Customer Service;
- Notice Requirements;
- Printed Information;
- Training and Staffing;
- Program Eligibility Requirements and Admission;
- Public Meetings;
- Tours and Trips;
- Use of Consultants;
- Facilities; and
- Special Events and Private Events on Public Properties

1.3.3 Review of Policies and Procedures

As part of the self-evaluation, a review of policies was completed that affect accessibility to the City's services. It is the City's intent to ensure that all individuals are knowledgeable of the requirements of the ADA and are informed on the process and resources used by the City to make services, activities and programs accessible.

In addition to the survey questionnaires, discussions with staff members were also conducted regarding services provided to the public. The findings and recommendations are listed in Section 2.

1.3.4 Public Participation Process

A public involvement process included survey input on programs and facilities from the community. The City posted a Notice to Public with input through a survey. Notices were posted on the City's website at <http://www.ci.ceres.ca.us/> on July 31, 2015 to August 21, 2015. Surveys were also left at:

City Hall, Engineering Service Department
2220 Magnolia Street, Ceres, CA

Ceres Public Library
2250 Magnolia Street, Ceres CA

A copy of the above notices can be found in Appendix C.

Results from the survey are summarized as follows:

City of Ceres Survey of Programs and Services

Respondents: 15

Areas of Concern in the City:

Riverbluff Lower Park Pathways
Eastgate Area
Lobby restroom in City Hall
Central from Hatch to Nadine
Park Restroom
Eastgate Area
Suffolk Dr & Waynesboro
Parking lot at City Hall/Police

What Should the Highest Priority be:

Sidewalks
Curb Ramps
Main Doors of City Hall
Recreation Areas
Smryna Park

The Draft ADA Self-Evaluation and Transition Plan (Plan) was posted on the City's website at <http://www.ci.ceres.ca.us/> on August 4, 2016 through September 2, 2016 for public comment. Notifications to the public inviting feedback of the Plan and to attend a public meeting were posted on the website and at the following locations:

City Hall, Engineering Service Department
2220 Magnolia Street, Ceres, CA

Ceres Public Library
2250 Magnolia Street, Ceres CA

Ceres Community Center
2701 4th Street, Ceres, CA

Modesto Senior Center
211 Bodem, Modesto, CA
Shannon Parker (209) 341-2974

Area Agency on Aging
121 Downey Ave. Ste 102, Modesto, CA
Marge Palomino, Director (209) 558-8698

Ceres Senior Citizens
Shirley (209) 838-3419/(209) 402-0272
sagnebg@aol.com

A copy of the notification and Feedback Form can be found in Appendix C.

The City hosted a public meeting on August 18, 2016 from 2:00 pm to 3:00 pm at the Ceres Community Center – Council Chambers to receive input from the public and to discuss any concerns regarding the Plan. Comments received from the public on the Plan included the following:

- *No comments were received regarding the plan.*
- *No members of the public were in attendance, so no comments were received at the August 18, 2016 public meeting.*

1.4 Facilities Survey

The City conducted a survey of architectural barriers in its buildings and facilities used by the public for programs and services provided by the City. Only those areas open to the public were surveyed. The surveys provide the City an overview of the architectural barriers that prevent people with disabilities from using its facilities and participating in its programs. The following facilities were assessed:

Buildings	Parks
• City Hall • Community Center • Library (off site only) • Police Department • American Legion Hall • Whitmore House & Museum • Whitmore Mansion	• Berry Grove Park • Costa Fields Complex • Don Pedro Park • Independence Park • Neel Park • Persephone Park • Redwood Park

	• Riverbluff Park • Riverview Park • Roeding Heights Park • Sam Ryno Park • Smyrna Park • Strawberry Fields Park • Whitmore Park
--	--

Assessments were conducted from April 2015 to June 2015 with aerial facility maps, measuring tape, leveler, ADA checklist as a reference and photos. Assessments were performed based on Americans with Disabilities Act Access Guidelines (ADAAG) and CCR Title 24 standards.

1.5 Curb Ramp Survey

The City conducted a city wide survey of curb ramps within the public right-of-way. The surveys were performed from October to November 2014. The survey included the collection of a GPS location, physical conditions, obstructions that were adjacent or within the path of travel, and photos as needed. Assessments were performed based on Access Guidelines (ADAAG) and CCR Title 24 standards.

The curb ramp assessment list was updated in June 2015 due to recently improved curb ramps under the CDBG Improvement Project at the Morrow Tract-San Ramon Estates-Palm Estates subdivision of the City.

2.0 Policies, Procedures, and Program Accessibility: Findings and Recommended Actions

2.1 Introduction

Services and programs offered by City of Ceres to the public must be accessible. Accessibility applies to all aspects of a program or service, including advertisement, orientation, eligibility, participation, testing or evaluation, physical access, provision of auxiliary aids, transportation, policies, and communication.

2.2 Overview and Individual Findings of Departmental Programs, Activities, and Services

The following sections detail the review of current Citywide and unique policies, services, programs, and activities based on meetings with City staff and responses to the program accessibility questionnaire. The following departments completed or were interviewed on the ADA Programs, Services and Activities survey. The following departments were included in the review:

- City Clerk
- Finance
- Police (Support Services/Traffic/Patrol)
- Fire
- Recreation
- Community Development (Building/Planning/Housing)
- Engineering
- Human Resources
- Library
- Transit
- Public Works (Streets/Parks/Facilities/Wastewater/Water)

Due to the surveys completed by the departments, all departments were grouped together as their findings and recommendations were similar. Action steps apply to all departments unless specifically specified.

All Departments

2.3 Description of Programs and Services

1. Office of the City Clerk – provides record management, information dissemination, City Council and Planning Commission support and agenda meetings and elections.

2. Finance – includes financial management of the City's resources including the daily administration to long range financial planning. These responsibilities include administration, general accounting, accounts payable, payroll, budget preparation, and a variety of customer service activities including business license management and utility billing administration.
3. Community Development Department – includes Planning and Building services. Planning includes both Current Planning (zoning and development review) and Long-Range Planning (long range planning issues and data). Building includes: code information support to the public and staff, field inspection, Plan check submittals and administration, issuance of building permits and assessment of fees.
4. Human Resources – provides for recruitment and selection of City staff, employee and labor relations, classification, performance administration, training coordination, employee assistance and workers' compensation benefits. This department also provides Risk Management of the City's liability and Worker's compensation program including litigation and insurance policies.
5. Police Department – provides full service to the City and includes patrol, investigation, traffic, dispatch, and record management. Services includes 24-hour Patrol operations supporting traffic accident investigation/enforcement and crisis intervention, code enforcement to protect the public's health, safety, welfare, and property value relating to land use, zoning, housing, public nuisances, graffiti abatement, and vegetation/fire hazard abatement.
6. Fire Department - provides fire protection and emergency medical services (EMS). Specialized services include fire suppression, emergency medical responses, hazardous materials mitigation, technical rescue fire investigations, public education and fire prevention
7. Recreation – provides and conducts many popular community wide special events, including: Concerts in the Park, Halloween Festival, Christmas Festival, and Arbor Day. This includes collaboration with local youth sports groups in Ceres, Ceres Street Faire Committee, Ceres Community Foundation, Ceres Community Collaborative, Ceres Athletic Committee, and Ceres Unified School District. Recreation also plans and coordinates event requests and programs held at the Community Center.
8. Engineering Department – provides the orderly development of general engineering services to regulate the construction of municipal structures, city streets, sewage disposal, water supply and storm drainage facilities. The department also manages the planning and construction of capital improvement projects and oversees traffic safety, solid waste and recycling services, and public transportation services.
9. Public Works Department – includes Streets, Parks, Facilities, Wastewater and Water services. The Street division is responsible for all traffic signs, traffic signals, lane striping, legends, street lights, pavement, sidewalks, curb & gutter, alleys, storm drain system, and street sweeping. Parks is responsible for the landscape maintenance of the Parks, Grounds, Right of Ways, undeveloped park sites, and the maintenance of

City street trees. Facilities include the maintenance of the City's facilities buildings and fleet. Wastewater System division is responsible for operating and maintaining the City's Wastewater Treatment Plant and the Wastewater Collection System. The Water division provides and maintains safe and effective drinking water to all of the City's residents.

10. Transit - The City Transit contracts with Storer Transit Systems to help the public move about the City.

11. Library – The Stanislaus County provides library services in the City of Ceres.

2.4 Contact Information

City of Ceres:

Kevin Waugh, City ADA Coordinator
2220 Magnolia Street
Ceres, CA 90201
Email: Kevin.Waugh@ci.ceres.ca.us
Phone: (209)538-5775

2.5 Accessible/Adaptive Equipment

Self-Evaluation Findings:

- a) Most departments do not have adaptive aids for the hearing impaired for programs, services or activities offered. Adaptive aids were noted at the following:
 - Police Dispatch – TTY (teletypewriter) is available in the dispatch center
 - Recreation – Computer stations are ADA compliant
- b) Most departments will try to accommodate any requests for assistance from the public.

Actions Steps:

- 1) All departments - Establish guidelines and train staff on types of adaptive aids that can be available for use by individuals participating in the City's programs
- 2) All departments – When appropriate and when requested, staff will provide or make auxiliary aids that allow a person with disabilities to participate in programs
- 3) All departments - Select items that are easily adjustable or can be modified to accommodate a variety of physical and ergonomic needs when purchasing items such as furniture, site furnishings and office systems.

2.6 Customer Service

Self-Evaluation Findings:

- a) Customer service to the public is an important and primary function for the City. Overall, the City does not have understood established procedures for determining reasonable modifications to achieve program accessibility.
- b) Most departments are unaware if changes can be made to standard operating procedures, there are no formal procedures in place when including a person of disability and requests are currently not tracked.
- c) All departments do not charge an additional fee to persons with disabilities for modifying programs.
- d) Transit services (provided by Storer Transit Systems) and their operators provide services to all persons including those disabled. Policies and formal procedures are in place to make changes as needed.

Action Steps:

- 1) All departments – Provide training to staff to accommodate the needs of individuals with disabilities when providing customer service as the City counter, public meetings and events. For example staff can read documents to those who are visually impaired.
- 2) All departments - Identify and provide training for staff using a relay service that can be used for telephone communications and/or use an alternative method of communication such as email.
- 3) All departments - For departments that use outside contracted employees to provide services to the public, a procedure should be set up to ensure that their work is in compliance with Title II of the ADA.
- 4) All departments – Work with the ADA coordinator to develop a process for receiving requests for a modification or assistance, evaluating and meeting the requests. All requests should be tracked and monitored, a central location is recommended.

2.7 Notice Requirements

Self-Evaluation Findings:

- a) ADA and Title II regulation require the City to inform the public of the rights and protections provided by the ADA. Most staff were unaware of the requirements.
- b) There are non-discrimination notices in the City Council Meeting and Planning Commission Agenda.
- c) Non-discrimination notices are not listed on job posting information or in other public locations. Non-discrimination statements were posted only at the Police Building.

Action Steps:

- 1) City Clerk/City Manager - Approve the City of Ceres ADA Public Notice (Appendix E – ADA Public Notice). This notice should appear on all City of Ceres's information boards including the website.
- 2) City Clerk/City Manager - Include the following notices regarding the City's commitment to providing accessible services in the City's publications that provide general information about or registration information on the City's services, program or activities. The notice should be produced and placed in departments at a location that will maximize public exposure.

“In accordance with the Americans with Disabilities Act and California Law, it is the policy of the City of Ceres to offer its programs, services and meetings in a manner that is readily accessible to everyone, including individuals with disabilities. If you are a person with a disability and require information or materials in an appropriate alternative format; or if you require any other accommodation, please contact the ADA Coordinator at NUMBER, at least two business days in advance of the hearing. Advance notification within this guideline will enable the City to make reasonable arrangements to ensure accessibility. Email: Email Contact”

- 3) City Clerk/City Manager - Non-discrimination language should appear on web and printed public notices and meeting agendas.
- 4) All departments - Publicize information about how and with whom to file a disability discrimination complaint using the City's website.

2.8 Printed Information

Self-Evaluation Findings:

- a) Most departments produce printed information that is available to the public including: brochures on program and services, class information, special events, registration/application for programs and grants, public agendas and notices, job applications, policies and codes, permits, plans and specifications, budget reports, and other miscellaneous items.
- b) Most departments do not have any alternative formats for individuals with visual disabilities and noted that requests were rare.

Action Steps:

- 1) All departments - Provide training or written guidelines to each department on how to produce printed information in alternative formats for persons with various disabilities to ensure that requests are handled in a uniform and consistent manner.
- 2) All departments - Include the following notice on all or selected materials printed by the City that are made available to the public:

“This publication can be made available upon request in alternative formats, such as Braille, large print, audiotope, or computer disk. Requests can be made by contacting the ADA Coordinator, or email. Please allow two business days for your request to be processed.”

- 3) All departments - Identify and have available a list of interpreters, readers, etc to be used to accommodate requests for these services.
- 4) All departments – Provide printed information in a variety of formats upon request (for ex. In large print format for person with visual disabilities or in simple language for persons with cognitive disabilities, TDD service). Provide programmatic changes (for ex. Staff assistance) upon request to assist in filling out forms or when alternative formats are unavailable or not feasible.
- 5) All departments – will make an effort to include pictures or images in its publication of individual with disabilities.

2.9 Website

Self-Evaluation Findings:

- a) Most departments are unaware if the City’s website included information about accessibility for individual with disabilities.

Action Steps:

- 1) All departments - Include the City's policy on non-discrimination on the basis of disability on the website.
- 2) All departments - Create a page/site identifying the ADA Coordinator and grievance procedures along with the forms.
- 3) All departments - Staff and departments who are posting materials on the website are properly trained and are aware of the ADA requirements.

2.10 Public telephones and communication devices

Self-Evaluation Findings:

- a) The Police Department has a TTY (teletypewriter) available in the dispatch center. The City does not have TDD/TTY device for regular calls for service.

Action Steps:

- 1) All departments - Educate and train staff to encourage TTY callers to take advantage of the national "711" Telecommunications Relay Service. The relay service allows people to dial "711" to access all relay services anywhere in the United States, 24 hours a day, free of any surcharges to all callers within the country.

2.11 Training and Staffing

Self-Evaluation Findings:

- a) Overall, staff is not fully aware of the everyday accessibility issues encountered by person with disabilities and what training is required.
- b) Staff members are unaware of the different types of reasonable accommodations available to make services accessible.
- c) Police and Finance staff members would benefit if there was training on American Sign Language (ASL) or other means of communicating with people with hearing impairments.

Action Steps:

- 1) All departments - Provide training to staff members who have contact with the public in regards to providing modifications and using assistive devices to make their programs accessible. The customer training should focus on communicating with and providing modifications for persons with a variety of disabilities.
- 2) All departments - Develop a comprehensive disability access training program. Educate staff in their responsibilities under the ADA. The City's ADA Coordinator is responsible for ensuring that staff members receive training.
- 3) All departments - Develop standard guidelines for written materials. These guidelines should include language that appropriately describes the City's policy on people with disability and staff should receive training.
- 4) All departments - Provide staff with on-going awareness and sensitivity training. Resources on the website are available for training.

2.12 Program Eligibility and Admission

Self-Evaluation Findings:

- a) There were no programs noted in any departments that have eligibility requirements for admissions in to programs.

Action Steps:

- 1) All departments - Provide training to staff regarding non-discrimination language in printed materials as well as on-going awareness and sensitivity training (Similar to Action Steps listed under 2.7, 2.8 and 2.11)

2.13 Public Meetings

Self-Evaluation Findings:

- a) Public meetings are held by the City Clerks office at the Community Center adjacent to City Hall. Public meetings include City Council and Planning Commission.
- b) Under the City Council Agenda, there is a notice for individuals with disability to contact the City Clerk if requesting special accommodations to access, attend or participate at the City meeting.

Action Steps:

- 1) City Clerk – Continue to ensure public meetings are held in accessible locations and provide reasonable accommodations when requested.

2.14 Transportation Services

Self-Evaluation Findings:

- a) The City Transit contracts with Storer Transit Systems to provide transportation services to the public. Transit buses are ADA compliant and operators are trained to assist passengers with disabilities.

Action Steps: None

2.15 Tours and Trips

Self-Evaluation Findings:

- a) Community Services and the Police department provide trips and tours of the City's facilities.
- b) Overall, staff provides assistance on requests for accommodating individuals with disabilities.

Action Steps:

- 1) Community Services, Police – Continue to educate and train staff on providing accessibility for individuals requesting to participate in the service. The department offering the service should meet with the individual with a disability to identify what modifications can be made to allow for participation.

2.15 Use of Consultants for Delivering Program Services

Self-Evaluation Findings:

- a) Transit is contracted out to Storer Transit Systems to provide transit in the City.
- b) Overall, most departments are not using consultants/vendors to conduct programs.

Action Steps:

- 1) All departments - Establish guidelines on administering and requiring contract agreements to include a non-discrimination clause (ex. Compliance to Civil Rights and Compliance with laws)

2.16 Emergency Evacuation Procedures

Self-Evaluation Findings:

- a) In City Hall, warning lights and audible sirens are activated in cases of emergency evacuation.
- b) The Community center has emergency evacuation signs in designated places with room designation in brail.
- c) Overall, all departments and staff were unaware of any special equipment and/or procedures used to notify individuals with visual, hearing, mobility, or cognitive disabilities. There was a general understanding to assist individuals as needed.

Action Steps:

- 1) All departments - Review existing procedures and provide training with staff regarding emergency protocol to ensure that persons with disabilities can be alerted during an emergency. When requested provide all evacuation policies and procedures in alternative formats.

2.17 Facilities

Self-Evaluation Findings:

- a) Programs and services open to the public are held at various City facilities. A complete inventory and findings can be found in Appendix G.
- b) Most staff members were not aware of any requests for improving accessibility to the City's facilities.
- c) Community Center has had requests to provide handicap accessibility from the parking lot to the front entrance.

Action Steps:

- 1) ADA Coordinator - All requests/filing for accessibility and outcomes should be tracked and monitored by the ADA Coordinator.
- 2) All departments - Train staff on the procedure and how to direct or assist individuals with the filing.

2.18 Special Events on Public Properties

Self-Evaluation Findings:

- a) Community Services and the Police department hold special events on public facilities.

Action Steps:

- 1) Community Services, Police - Ensure department staff that facilities should be ADA accessible or reasonable accommodations will be available for individuals with disabilities.

2.19 Municipal Code Review

As part of the City's on-going effort to evaluate policies, procedures, and program accessibility, the City will review its Municipal Code to identify any provisions that may inadvertently reduce the accessibility of the programs, services, and activities available to the public. As a follow-up, the City will amend or modify the ADA Self Evaluation and Transition Plan to incorporate, if any, alternative municipal code language. The City will have its code review, findings and any recommendations included in the annual review at the end of every calendar year.

3.0 Transition Plan

3.1 Introduction

The Transition Plan for City Facilities combines the findings of the policy assessments, program evaluations, facilities and curb ramp surveys conducted by the City.

Policy and program recommendations can be found in Section 2. A complete list of findings and recommendation of facilities and curb ramps are included in Appendix G and H: Facilities Summary List of Architectural Barriers and Curb Ramp Summary List.

It is the intent of the City to have its ADA Coordinator work together with department heads and budget staff to determine funding sources for the City's on-going program of architectural barrier removal projects. Once funding is identified, the ADA Coordinator will coordinate the placement of the projects in the City's Capital Improvement Plan.

3.2 Architectural Barrier for Facilities

The survey process was accomplished by physical assessments using measuring devices, facility diagrams, and survey forms.

3.2.1 Facility Reports

The surveys identified physical barriers in City facilities based on ADAAG and Title 24 standards. GIS map identifying City facilities was generated. Where relevant, photos were taken and included with the surveys.

The facility report for each site includes:

- Findings of barriers found to be in noncompliance with ADAAG and Title 24 standards.
- Planning level recommendations to address the barrier.
- Planning level construction estimate
- Priority Level
- Photo reference

3.2.2 Criteria for Prioritizing the Plan for Facilities

Recognizing that the City has limited funds and may not immediately make all facilities fully accessible, City staff utilized the following criteria as the basis for prioritizing the removal of architectural barriers:

- Level of use by the public.
- Uniqueness of the facility or program - some programs are unique to a building, facility or park and cannot occur at another location.
- Geographic distribution – selecting a facility that is central to the City will ensure

maximum access for the public.

3.2.3 Priorities for Facilities

The criteria listed below were used to assist in the determination of specific program-based barrier removal actions within a facility. Since not all barriers must be removed in order to provide program access, those barriers that limit access to public programs, services, and activities are given first priority. These criteria will also be used for prioritizing the removal of architectural barriers in future findings or projects.

- **Priority One:** The highest priority is placed on those barrier removal items that provide accessibility at the main entrance of a facility or improve a path of travel to the portion of the facility where program activities take place. Examples include:
 - a) Facility entrance walk and ramps
 - b) Facility handrails
 - c) Exterior doors for entrance
 - d) Restrooms
 - e) Designated handicapped areas
 - f) Parking identification and striping
- **Priority Two:** A second level priority is placed on those barrier removal items that improve or enhance access to program use areas. Examples include:
 - a) Transaction counters
 - b) Offices and meeting areas
 - c) Staff Training
- **Priority Three:** A third level priority is placed on those barrier removal items that improve access to amenities serving program areas. Examples include:
 - a) Drinking fountains
 - b) Adjusting site furnishings
 - c) Adjusting door closures

3.2.4 New Construction and Renovations

For all future construction or renovations to the City's buildings and facilities, improvements must comply with Title II of the ADA and State of California standards for City-funded public developments. The City shall also:

1. Prior to construction, schedule a review with the City's ADA Coordinator of all City plans and specifications for the construction of facilities. No project should proceed to construction without a completed and clean document review.

2. Develop a procedure to ensure that the ADA Coordinator is informed of all plans prior to construction to ensure compliance with accessibility requirements. Existing barriers for facilities can often times be incorporated into new projects which reduces overall cost. The ADA Coordinator will track accessibility improvements performed in the City and update the Transition Plan accordingly.

3.2.5 Time Frames for Completion

The following table, Facilities Summary List of Architectural Barriers includes a list of facilities with barriers and recommendations, priority level for construction and estimated construction costs.

The City of Ceres reserves the right to change the barrier removal priorities in order to allow flexibility in accommodating community requests, petitions for reasonable modification from persons with disabilities, and changes in City's programs.

It is the intent of the City to have its ADA Coordinator work together with department heads and budget staff to determine the funding sources for architectural barrier removal projects. Once funding is identified, the ADA Coordinator will coordinate the placement of the projects in the City's Capital Improvement Plan to be addressed on a fiscal year basis. It is the intent of the City to address these barriers within the time frames noted below depending on immediate necessity, degree of complexity, funding and sufficient staff resources.

PHASE ONE – The City's goal is to complete Priority One improvements in two (2) years, provided that a minimum budget of \$100,000 per year, is allocated.

PHASE TWO – The City's goal is to complete Priority Two improvements within four (4) years, provided that a minimum budget of \$100,000 per year is allocated.

PHASE THREE– The City's goal is to complete Priority Three improvements within sixteen (16) years, provided that a minimum budget of \$100,000 per year is allocated.

City of Ceres Facilities Summary List of Architectural Barriers

Summary Total: Priority 1 - \$ 90,000
(Construction only) Priority 2 - \$ 76,000
 Priority 3 - \$ 659,000-729,000

Facility	Barrier	Recommendations	Priority	Estimated Construction Cost
City Hall (entrance on 2 nd Street)	Non-compliant walkway and entrance	Provide accessible entrance and walkway per ADAAG	1	\$10,000
City Hall (Magnolia entrance)	Non-compliant slopes at entrance and patio area	Provide accessible entrance and walkway per ADAAG	1	\$10,000
City Hall (Finance, Engineer & Building)	Non-compliant counter heights and door clearances	Provide accessible counter location and clearance at doors per ADAAG	1	\$7,000
City Hall (Lobby Area at Magnolia entrance)	Non-compliant reach heights for displayed materials, drinking fountains, exit signs	Provide accessibility to displayed materials, drinking fountains and signs	1	\$7,000
City Hall (Lobby Area at Magnolia entrance)	Non-compliant restrooms: signage, doors, fixture clearances/heights, space clearance	Remodel restroom for compliance with ADAAG	3	\$30,000
City Hall (Street Parking)	Non-compliant parking signs, and striping	Provide parking signs and striping per ADAAG	1	\$3,000
Community Center (Walkway, Parking & Entrance)	Non-compliant walkway to entrance, parking signage and stalls, entrance	Provide accessible routes, parking signs and stalls and entrance to building per ADAAG	1	\$15,000
Community Center (General Building)	Non-compliant main door (force), display materials, handrails at stairs, exit signs	Upgrade and provide accessible doors, materials for the public, handrails and signage per ADAAG	1	\$8,000
Community Center (Council Chambers)	Non-compliant ramp, landing, handrails and podium/counter	Upgrade for accessibility per ADAAG	1	\$15,000
Community Center (General Amenities)	Non-accessible listening devices, exit signs missing/wrong location, reach ranges for DVD players/soap dispensers sinks, electrical outlets, door clearances	Upgrade for accessibility per ADAAG	1	\$5,000

City of Ceres ADA Self-Evaluation and Transition Plan
Transition Plan for City Facilities and Curb Ramps

August 2016

Community Center (Restrooms Upstairs & Downstairs)	Non-compliant restrooms: signage, door clearance/weight, fixture clearances/heights, stall widths & clearances, grab bar, exposed pipes	Upgrade for accessibility per ADAAG	2	\$50,000
Community Center (Room Usage)	Non-compliant rooms due to aisle space and access to tables or workstations	Provide accessible clearance space and access	2	\$1,000
Library (Exterior access)	Non-compliant path of travel, parking signs and space, handrails	Upgrade for accessibility per ADAAG	1	\$10,000
Police Department (Exterior access)	Non-compliant path of travel, steps and handrails	Upgrade for accessibility per ADAAG	2	\$12,000
Police Department	Non-compliant counter and door clearances	Provide accessible counter location and clearance at doors per ADAAG	2	\$5,000
Police Department (Interior Amenities)	Non-accessible call button, power assist door control, telephone, fire alarm pull station	Provide clearance space and reach ranges for amenities per ADAAG	2	\$8,000
American Legion Hall (Parking)	Non-accessible parking stalls, and walkway	Provide accessible parking stalls and walkway to building per ADAAG	3	\$10,000
American Legion Hall (Exterior Doors and Gate)	Non-compliant door clearances and closures, iron gate missing kick plate	Provide accessible doors per ADAAG	3	\$4,000
American Legion Hall (Restrooms)	Non-compliant restrooms: fixture height, clearances, signage, door clearance, exposed pipes	Upgrade for accessibility per ADAAG	3	\$25,000
American Legion Hall (Various)	Non-accessible sink/bar area, drinking fountains, exit signage, switches, hardware, listening devices	Upgrade for accessibility per ADAAG	3	\$15,000
Whitmore House & Museum* (Exterior Walkway)	Non-accessible walkway, stairs, slope, landing, door fixtures to building, museum, restrooms	Provide accessible route to building per ADAAG	3	\$30,000
Whitmore House & Museum* (Restrooms)	Non-compliant restroom: signage missing, clearance at door, fixture heights	Upgrade for accessibility per ADAAG	3	\$20,000
Whitmore House & Museum* (Museum Counter)	Non-compliant counter heights	Provide accessible counter per ADAAG	3	\$5,000

City of Ceres ADA Self-Evaluation and Transition Plan
Transition Plan for City Facilities and Curb Ramps

August 2016

Whitmore Mansion (Exterior Walkway)	Non-accessible walkway, stairs and handrails, lift at porch area	Provide accessible route to building per ADAAG	3	\$25,000
Whitmore Mansion (Various)	Non-accessible porch area due to changes in level, door hardware, restrooms, sink, general route inside	Provide an accessible route and amenities per ADAAG	3	\$80,000 - \$150,000 (cost depends on retaining historic nature)
Berry Grove Park	Non-accessible path of travel to amenities, picnic area not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Costa Fields Complex	Non-accessible path of travel, picnic area not accessible, no designated ADA area	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Costa Fields Complex (Restrooms)	Non-compliant restrooms: fixture height, no ADA accessible stall, seat height	Upgrade for accessibility per ADAAG	3	\$25,000
Costa Fields Complex (Parking)	Non-compliant parking stalls, signage and striping	Provide compliant parking stalls to walkway per ADAAG	3	\$5,000
Costa Fields Complex (Condiment & Spectator Area)	Non-compliant tray holder in walkway, no accessible seating space or path in spectator area	Provide accessible path and designated space per ADAAG	3	\$10,000
Don Pedro Park (Restroom and site were under construction at time of assessment)	Non-accessible path of travel to amenities, picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$25,000
Independence Park	Non-accessible path of travel to amenities, picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Neel Park	Non-accessible path/sidewalk to park due to slope	Provide accessible route to park per ADAAG	3	\$10,000
Persephone Park	Non-accessible path of travel to amenities (high cross slopes), picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000

City of Ceres ADA Self-Evaluation and Transition Plan
Transition Plan for City Facilities and Curb Ramps

August 2016

Redwood Park	Non-accessible path of travel to amenities, picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Riverbluff Park (Parking) <i>(Park facility and site were under construction at time of assessment)</i>	Non-compliant parking stalls, signage and striping and curb ramp	Provide compliant parking stalls per ADAAG	3	\$10,000
Riverbluff Park (Restrooms)	Non-compliant restrooms: fixture height, signage, hardware, clearance space	Upgrade for accessibility per ADAAG	3	\$25,000
Riverbluff Park	Non-accessible play equipment and components including benches	Provide accessible play equipment and access to benches per ADAAG	3	\$15,000
Riverview Park	Non-accessible path of travel to amenities, picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Persephone Park	Non-accessible path of travel to amenities (high cross slopes), picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Roeding Heights Park	Non-accessible path of travel to amenities, picnic area and benches not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Roeding Heights Park (Restrooms)	Non-compliant restrooms: fixture height, no ADA accessible stall, clearances, signage	Upgrade for accessibility per ADAAG	3	\$25,000
Sam Ryno Park	Non-compliant drinking fountain in path of travel, play equipment and benches not accessible	Provide accessible route to play areas and provide compliant drinking fountains per ADAAG	3	\$10,000

*City of Ceres ADA Self-Evaluation and Transition Plan
Transition Plan for City Facilities and Curb Ramps*

August 2016

Smyrna Park	Non-accessible path of travel to amenities, picnic area, benches and drinking fountain not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Smyrna Park (Parking)	Non-compliant parking stalls, signage, striping and access to walkway	Provide compliant parking stalls per ADAAG	3	\$10,000
Strawberry Fields Park (Restrooms)	Non-compliant restrooms: door handles, clearances, fixture heights, signage	Upgrade for accessibility per ADAAG	3	\$25,000
Strawberry Fields Park	Non-accessible path of travel to amenities, picnic area, benches and drinking fountain not accessible, no designated ADA area, play equipment not accessible from path	Provide accessible route to areas and amenities per ADAAG	3	\$20,000
Whitmore Park (Park restroom and site were under construction at time of assessment)	Non-accessible path of travel to amenities and picnic area	Provide accessible route to areas and amenities per ADAAG	3	\$20,000

*This facility is listed as a qualified historical landmark. ADA improvements will require further review as there are some exceptions allowed.

Interim Measures - In accordance with the requirements of the ADA, when barriers are scheduled to be removed over a period of time, interim measures to provide program access will be implemented. Interim measures may include the redesign of equipment, assignment of aides to beneficiaries, delivery of services at alternate accessible sites, or the use of accessible conveyances. In addition, other methods may be employed that result in accessible, programs and activities being readily accessible to and usable by individuals with disabilities.

3.3 Barriers at Curb Ramps

Title II of the ADA requires that public entities having responsibilities for or authority over streets, roads, and/or areas meant for pedestrian use, to develop a Transition Plan. The Plan provides inaccessible facilities onto environments that are accessible to and functional for individuals with disabilities and provides an outline for implementation and scheduling of improvements to provide ADA complying curb ramps within the City.

3.3.1 Curb Ramp Reports

The survey process was accomplished by physical assessments using measuring devices, GIS software and maps. The surveys identify physical barriers and condition of curb ramps and adjacent areas using ADAAG and Title 24 standards. Each location was identified and tracked using GPS. Aerial maps were generated using the GPS location of curb ramp surveyed. Where relevant, photos were taken and included with the surveys.

A total of 2,548 locations were surveyed – see Appendix H. The curb ramp report for each site includes:

- Location of street and quadrant
- If a curb ramp exists and if not, is one needed
- Non-compliance features noted included: detectable warning surfaces, excessive slopes, displacements of ½” and more, tactile grooves and obstructions within the path of travel
- Photo reference (not included in Appendix)
- Ranking Priority for: Location, Physical and Overall

The City has set up ArcGIS Online in which all the data collected above has been uploaded under the curb ramp database. The program will allow users to view ramp attributes, pull up the photos associated (if applicable) as well as edit or update the data as needed.

3.3.2 Criteria for Prioritizing the Plan for Curb Ramps

The City’s goal is to promote efficiency and improve pedestrian accessibility. It must be emphasized that the City’s intent is for all individuals with disabilities be reasonably accommodated. High priorities were allocated to those locations that:

- Provide access to state, local offices and facilities that provide public services and programs
- Provide access to places of accommodation including public, commercial, medical, recreation use.
- Provide access to public transit.
- Provide access to improve pedestrian crossings at heavily used corridors.

3.3.3 Priorities of Curb Ramps

Recognizing that the City has limited funds and cannot immediately install/retrofit ADA compliant curb ramps at all of its location, City staff established a ranking system for prioritizing the curb ramp improvements. The Overall Priority established is based upon the location and physical ranking of each location.

The following methodology was used to determine the ranking:

Physical Ranking - evaluates the curb ramp with respect to its physical condition and function to City's programs.

- P1** Ramps serving City functions used by the public
Reconstruct or install ramps to allow for accessible path of travel to a City program/function
- P2** Install NEW ramps where one does not exist
Ramp will provide access to sidewalk/continuous path of travel (including path of travel from opposite road) to allow for path of travel to a City program/function.
- P3** Utility conflict, physical barriers or other constraints exist at a location
When feasible, ramp/location will be reconstructed to provide continuous path of travel
- P4** Ramp will be reconstructed when it does not meet current federal or state standards
P4a - Missing detectable warning system
P4b - Deficiencies include: grooved tactiles, displacement (1/2+ inches height), slopes excessive
- P5** No observed deficiencies

Location Ranking - evaluates the curb ramp with respect to its physical location within the City and surrounding land use adjacent to the curb ramp.

- L1** Requested by the public/residents and validated by City staff.
- L2** Government locations
L2-City of Ceres facilities serving the public
L2-b Other governmental facilities serving the public
- L3** Public locations with high occupancy (privately owned)
- Arterial Streets
- Hospitals, medical facilities, senior facilities
- Shopping strips
- Apartments, Church, others
- L4** Residential Areas
- L5** All other areas

Overall Ranking- determined by the ranking of Location and Physical ranking.

O1 Highest ranking will be given when a ramp is rated

P1 Ramps serving City functions used by the public

AND

L1 Requested by the public/residents

OR

L2-City of Ceres facilities serving the public

O2 This ranking will be given when a ramp is rated:

L2-b Other governmental facilities serving the public

AND

P2 Install NEW ramps where one does not exist

O3 This ranking will be given when a ramp is rated:

L3 Public locations with high occupancy (privately owned)

AND

P2 Install NEW ramps where one does not exist

O4 This ranking will be given when a ramp is rated:

L2-b Other governmental facilities serving the public

AND

P3 Utility conflict, physical barriers or other constraints exist at a location, a ramp will be reconstructed

OR

P4-a Missing DWS

O5 This ranking will be given when a ramp is rated:

L3 Public locations with high occupancy (privately owned)

AND

P3 Utility conflict, physical barriers or other constraints exist at a location, a ramp will be reconstructed

OR

L4/L5 Residential Areas AND All other Areas

AND

P2 Install NEW ramps where one does not exist

O6 This ranking will be given when a ramp is rated:

L2-b Other governmental facilities serving the public

AND

P4-b Deficiencies include: grooved tactiles, displacement (1/2+ in in height), slopes excessive

OR

- L3** Public locations with high occupancy (privately owned)
AND
P4-a Missing DWS

O7 This ranking will be given when a ramp is rated:

- L3** Public locations with high occupancy (privately owned)
AND
P4-b Deficiencies include: grooved tactiles, displacement (1/2+ in in height), slopes excessive

OR

- L4/L5** Residential Areas **AND** All other Areas
AND
P3 Utility conflict, physical barriers or other constraints exist at a location, a ramp will be reconstructed

O8 This ranking will be given when a ramp is rated:

- L4/L5** Residential Areas **AND** All other Areas
AND
P4-a Missing DWS

OR

- P4-b** Deficiencies include: grooved tactiles, displacement (1/2+ in in height), slopes excessive

O9 All other ramps not meeting the above criteria

3.3.4 General Policies and Practices

Self-Evaluation Findings:

- a) The City does not have any set programs or funding to increase pedestrian accessibility.
- b) Accessibility improvements are done when feasible and within the project limits of an existing transportation improvement project and as new development occurs.

Recommended Actions:

- 1) Street-Related Capital Improvement Projects – Curb ramps are installed, repaired and/or brought into compliance in all street-related capital improvement projects.
- 2) The ADA Coordinator will establish a Service Request Accommodation Program which will be posted on the website and other public locations that will allow residents to request for a curb ramp modification/installation. Requests shall be tracked and maintained on the Curb Ramp database. Public work staff shall be trained on the guidelines.

- 3) Once a year, the Curb Ramp priority list shall be updated, supplemented and reviewed as part of the City's on-going responsibilities to improve accessibility for pedestrians. Outreach of the review and process should include pertinent departments (Transit, Public Works, Development, Community Services) and local groups in the community.

3.3.5 Time Frames for Completion

The following table, Curb Ramp Summary List of Rankings, includes a summary of the rankings based on the ranking priority based on Section 3.3.3 Priorities of Curb Ramps. The table also includes number of ramps in each ranking and associated estimated cost for construction.

The City of Ceres reserves the right to change the curb ramp priorities in order to allow flexibility in accommodating community requests, petitions for reasonable modification from persons with disabilities, and changes in City's programs. The City will continue to implement its *Service Accommodation Request Program*.

It is the intent of the City to have its ADA Coordinator work together with department heads and budget staff to determine the funding sources for the ADA Transition Plan. Once funding is identified, the ADA Coordinator will coordinate the placement of the projects in the City's Capital Improvement Plan to be addressed on a fiscal year basis.

It is the intent of the City to address non-compliant curb ramps within a time frame of thirty (30) years of this report depending on immediate necessity, degree of complexity, and overall cost.

PHASE ONE – The City's goal is to complete curb ramp improvements with rankings of Priority 1 within 4 years (by Year 2020) provided that a minimum budget of \$75,000 per year is allocated.

PHASE TWO - The City's goal is to complete curb ramp improvements with rankings of Priority 2 within 5 years (by Year 2021) provided that a minimum budget of \$50,000 is allocated.

PHASE THREE - The City's goal is to complete curb ramp improvements with rankings of Priority 4 to 9 within 30 years (by Year 2046) provided that a minimum budget of \$100,000 per year is allocated.

City of Ceres
Curb Ramp Summary List of Rankings

Overall Rank	Total Locations	Preliminary Estimated Construction Cost
O1	184	\$243,200
O2	8	\$25,600
O3	20	\$64,000
O4	87	\$96,600
O5	82	\$269,600
O6	55	\$60,400
O7	15	\$41,100
O8	1,701	\$1,925,400
O9	396	\$8,800
TOTALS:	2,548	\$2,734,700

See Appendix H – Curb Ramp Summary List for a complete listing of each location.

4.0 ADA Coordinator

ADA and Title II regulations require the City identify an ADA Coordinator. The City of Ceres' ADA Coordinator is:

Kevin Waugh, City ADA Coordinator
2220 Magnolia Street
Ceres, CA 90201
Email: Kevin.Waugh@ci.ceres.ca.us
Phone: (209)538-5775

4.1 Complaint Procedures for Discrimination Based on Disability

Self-Evaluation Findings:

- a) ADA and Title II regulations require the City have in place a complaint procedure. One is currently in place and is posted on the website.

Action Steps:

- 1) The ADA Coordinator will be responsible for: maintaining the complaint procedures process which is posted on the website and other public locations as needed, follow up with all requests, track and update database as necessary, Train public work staff and other departmental staff about the procedures.

5.0 Program Accessibility Guidelines, Standards & Resources

5.1 Introduction

In order to facilitate access to all City Programs and Departments, the City will maintain these program accessibility guidelines, standards and resources. This information is available to all employees and volunteers. The City will add to these guidelines when necessary to address its needs and include information and technological devices that help staff and volunteers members communicate with individuals with a variety of disabilities. The City will periodically review the components of this section, as new technologies are developed in order to ensure that the best types of modifications are included. This section also contains the accessibility standards of care that govern new construction and alterations to facilities.

5.2 Federal Accessibility Standards & Regulations & Resources

There are both State and Federal regulations for accessible facilities. Below are resources for both the State of California and Federal facility regulations.

U.S. Department of Justice

- **The U.S. Department of Justice**, <http://www.ada.gov>. The US DOJ provides many free ADA materials including the Americans with Disability Act (ADA) text. Printed materials may be ordered by calling the ADA Information Line [1.800.514.0301 (Voice) or 1.800.514.0383 (TDD)]. Publications are available in standard print as well as large print, audiotape, Braille, and computer disk for people with disabilities. Documents, including the following publications, can also be downloaded from the Department of Justice website.
- **ADA Regulation for Title II**, http://www.ada.gov/regs2010/titleII_2010/titleII_2010_regulations.htm. This publication describes Title II of the Americans with Disabilities Act, Pub. L. 101-336, which prohibits discrimination on the basis of disability by public entities. Title II of the ADA protects qualified individuals with disabilities from discrimination on the basis of disability in the services, programs, or activities of all state and local governments. This rule adopts the general prohibitions of discrimination established under section 504, as well as the requirements for making programs accessible to individuals with disabilities and for providing equally effective communications. It also sets forth standards for what constitutes discrimination on the basis of mental or physical disability, provides a definition of disability and qualified individual with a disability, and establishes a complaint mechanism for resolving allegations of discrimination.
- **Title II Technical Assistance Manual and Yearly Supplements**, <http://www.ada.gov/taman2.html> and supplement <http://www.ada.gov/taman2up.html>. This manual explains in lay terms what state and local governments must do to ensure that their services, programs, and activities are provided to the public in a nondiscriminatory manner.
- **Current Text of the Americans with Disabilities Act of 1990**, including changes made by the ADA Amendments Act of 2008 (P.L. 110-325),

<http://www.ada.gov/pubs/adastatute08.pdf>. The ADA prohibits discrimination and ensures equal opportunity for persons with disabilities in employment, state and local government services, public accommodations, commercial facilities, and transportation. It also mandates the establishment of TDD/telephone relay services.

- **ADA Information for Law Enforcement**, <http://www.ada.gov/policeinfo.htm>. This page contains compliance assistance materials to help state and local law enforcement officers understand how to interact with victims, witnesses, suspects, and others who have disabilities.

US Access Board

- **The US Access Board**, <http://www.access-board.gov/>. The US Access Board writes Federal regulations for Facilities, Public Rights-of-Way, Transportation, and Communications. This page also contains research papers, newsletters, annual reports and more. In addition to regular print, publications are available in: large print, disk, audiocassette, and Braille. Multiple copies of publications can be ordered by sending a request to pubs@access-board.gov. In addition to the guidelines, guidance material is also available to assist staff in understanding and implementing federal accessibility guidelines. Copies of Advisory Committee Reports that have been written but not yet adopted as law are also provided.
- **ADA and ABA Accessibility Guidelines Homepage**, <http://www.access-board.gov/guidelines-and-standards>. Includes a Side-by-Side Comparison of the ADA-ABA guidelines, the original ADA standards, and the International Building Code (2003 edition) issued by the Access Board.

5.3 State of California Accessibility Standards & Regulations & Resources

Title 24, California Building Code

- **The State of California** has also adopted a set of design guidelines for accessible facilities, which can be found in the California Code of Regulations, Title 24, Part II, California Building Code (CBC), www.iccsafe.org. CBC contains general building design and construction requirements relating to fire and life safety, structural safety, and access compliance. CBC provisions provide minimum standards to safeguard life or limb, health, property and public welfare by regulating and controlling the design, construction, quality of materials, use and occupancy, location and maintenance of all buildings and structures and certain equipment. Although California has adopted most of the ADAAG requirements, there are some differences. In general, the more restrictive requirement (whether federal or state) should be applied when designing accessible facilities. The complete Title 24 or any of its parts is available for purchase from the International Code Council (ICC), 5360 South Workman Mill Road, Whittier, CA 90601, 1.800.423.6587, www.iccsafe.org or at various bookstores that carry technical books.

Since the CBC is updated every three years, the City should have an ongoing program of

regularly reviewing these changes and updating policies and procedures related to accessibility to keep them current.

Division of the State Architect

- **The Division of State Architect (DSA)**, <http://www.dsa.dgs.ca.gov/Pubs/default.htm>, also provides information and resources for accessible or universal design. The DSA's website is <http://www.dsa.dgs.ca.gov>. For technical assistance contact DSA's Access Compliance Program at 1130 K Street, Suite 101, Sacramento, California 95814 (916.322.4700).
- **DSA's 2003 California Access Compliance Reference Manual**. The purpose of this book of regulations and statutes together is to clarify the obligations for architectural accessibility in California.

5.4 General Disability Etiquette

A guide to disabilities and disability etiquette should be assembled and distributed to staff and volunteers in addition to staff training. The guide will ensure that staff and volunteers are familiar with a variety of types of disabilities and that they are sensitive to the abilities and needs of people with disabilities in order not to offend or demean them. The guide should be periodically updated to ensure that it includes current acceptable language for talking about disabilities. Some examples of disability etiquette guides:

- **The County of Long Beach**, disability etiquette publication http://www.longbeach.gov/hr/ada/disability_etiquette.asp.
- **Easter Seals Disability Etiquette website** http://www.easterseals.com/site/PageServer?pagename=ntl_etiquette.
- **City of Sacramento's Disability Etiquette Website** <http://portal.cityofsacramento.org/HR/Divisions/Office-of-Civil-Rights/ADA>.

5.5 State, and National Organizations who Provide Disability Services and Information

State & National Organizations Who Provide Services to People with Disabilities

- **ADA Coordinator's Toolkit**, <http://nwadacenter.org/toolkit/ada-best-practices-tool-kit-state-and-local-governments-doj>
- **United Cerebral Palsy of Central California**, <http://www.ccucp.org>. United Cerebral Palsy of Central California is a non-profit social service organization dedicated to serving men, women, and children with disabilities. Programs include adaptive services, assistive technology services, summer programs, life skills training, and a center for arts and technology.
- **Disability Resources, Inc.**, <http://www.disabilityresources.org>. Disability Resources, Inc. is a national nonprofit organization that provides information about resources for independent living. DRI maintains an on-line directory of assistive technology resources.

- **CATS**, <http://www.atnet.org>. CATS is a statewide project of the California Department of Rehabilitation that promotes access to assistive technologies, related services, and information to enable people with disabilities to be successful, independent, and productive. CATS maintain several directories on their website including assistive technology vendors and service providers for Hard of Hearing/Deaf, Learning Disabled, Mobility/Physical/Orthopedic, Speech/Language, visually impaired/Blind.
- **World Institute on Disabilities (WID) Accessibility and Assistive Technology Resource List**, <http://www.wid.org/resources/accessibility-assistive-technology/>. WID maintains a comprehensive list of accessible technology resources.
- **The Center for Accessible Technology**, <http://www.cforat.org>. CFORAT provides access to computers for people with disabilities. Their goal is for children with disabilities to succeed in school, adults with disabilities can find (and keep) jobs and all people with disabilities can use the internet, email and benefit from the digital revolution.
- **American Association of People with Disabilities Telecommunications and Technology Policy Initiative**, <http://www.aapd.com/what-we-do/technology/>. The American Association of People with Disabilities (AAPD), the country's largest cross-disability membership organization, organizes the disability community to be a powerful voice for change – politically, economically, and socially. The mission of the Telecommunications and Technology Policy Initiative (TTPI) is to ensure that all technology products and services are designed with disability users in mind.

5.6 Accessible Websites

State & National Organizations who Provide Information about Creating & Maintaining Accessible Websites

How to tell if your web site is accessible

- **HiSoftware Services**, www.hissoftware.com. This company provides accessible software consulting.
- **Free website accessibility checker** provided by HiSoftware
<http://www.cynthiasays.com>
- **Web Accessibility Initiative for Evaluating Website Accessibility**, <http://www.w3.org/WAI/eval/Overview.html>. This is a list of resources which provide general procedures and tips for evaluation in different situations, from evaluation during Web site development to ongoing monitoring of existing sites. This list is intended to supplement other content management and quality assurance procedures.

Resources for Web developers

- **Accessibility of State and Local Government Websites to People with Disabilities**, <http://www.ada.gov/websites2.htm>. Publications providing guidance on making state and

local government websites accessible.

- **Rich Media Home**, <http://ncam.wgbh.org/access-ncam> . A growing collection of resources for developers and users interested in ways to make rich media accessible to people with disabilities.
- **Section 508 on-line accessible software development training**, <http://training.section508.gov/>

5.7 Emergency Preparedness

National Resources for Emergency Preparedness Plans

- **The Access Board Emergency Evacuation Plan Checklist**, https://www.osha.gov/SLTC/etools/evacuation/docs/eap_checklist.pdf An overview of these the Access Board's design requirements. Also included are links to information developed by other organizations on evacuation planning and disaster preparedness.
- National Organization Disability resources on **Emergency Preparedness for Employers and Businesses**, http://nod.org/disability_resources/emergency_preparedness_for_persons_with_disabilities
- **United States Department of Labor** Emergency Preparedness for People with Disabilities, <http://www.dol.gov/odep/programs/emergency.htm>. The Office of Disability Employment Policy (ODEP) assumed a leadership role on the Interagency Coordinating Council as chair of the Subcommittee on Emergency Preparedness in the Workplace. The subcommittee has developed **Preparing the Workplace for Everyone**, a framework of guidelines for federal agencies related to including employees and visitors with disabilities in emergency plans: http://www.dol.gov/odep/pubs/ep/preparing/Workplace_Final.pdf
- **Federal Agency for Emergency Management**, <http://www.fema.gov/plan/prepare/specialplans.shtm>. This site has a helpful checklist for including individuals with special needs in evacuation plans.
- **National Center for Accessible Media** Accessible Emergency Alerts for People with Disabilities, <http://ncam.wgbh.org/alerts/>. The Access to Emergency Alerts project unites emergency alert providers, local information resources, telecommunications industry and public broadcasting representatives, and consumers in a collaborative effort to research and disseminate replicable approaches to make emergency warnings accessible.

5.8 Funding for Projects

CalTrans has published a transportation funding guidebook in August 2008 titled "State and Federal Funds Available for Local Agency Projects", http://www.dot.ca.gov/hq/LocalPrograms/lam/Transportation_Funding_Guidebook.pdf

This document provides concise, high-level overviews of several Federal and State transportation funding programs available to local agencies. Each program description contains key facts about eligibility, project selection, significant dates, references, sources for assistance and other essential information.

Appendix A
Accessibility Definitions

The following is a summary of many definitions found in the ADA and ADAAG. Please refer to the Americans with Disabilities Act of 1990, the Title II Technical Assistance Manual, and the ADA Accessibility Guidelines for Buildings and Facilities (ADAAG) as amended through September 2002 for the full text of definitions and explanations.

Accessible Route

An *accessible route* is a continuous unobstructed path that connects all accessible elements and spaces of a building or facility and that complies with Chapter 4 of ADAAG. Interior accessible routes may include corridors, floors, ramps, elevators, lifts, and clear floor space at fixtures. Exterior accessible routes may include parking access aisles, curb ramps, crosswalks at vehicular ways, walks, ramps, and lifts.

ADA

Acronym for the Americans with Disabilities Act.

Adaptive/Auxiliary Aids and Services

The term *auxiliary aids and services* includes:

- Qualified interpreters or other effective methods of making orally delivered materials available to individuals with hearing impairments;
- Qualified readers, taped texts, or other effective methods of making visually delivered materials available to individuals with visual impairments;
- Acquisition or modification of equipment or devices; and
- Other similar services and actions.

ASL

American Sign Language. Manual (hand) language with its own syntax and grammar used primarily by people who are deaf.

Complaint

A *complaint* is a claimed violation of the ADA.

Curb Ramp

A *curb ramp* is a short ramp cutting through a curb or built up to it.

Detectable Warning

Detectable warnings are standardized surface features built in or applied to walking surfaces or other elements to warn individuals with visual impairments of hazards on a circulation path.

Disability

The term *disability* means, with respect to an individual:

- A physical or mental impairment that substantially limits one or more of the major life activities of such individual;
- A record of such impairment; or
- Being regarded as having such impairment.

A. Qualified Individual with a Disability

A qualified individual with a disability means an individual with a disability who, with or without reasonable modification to rules, policies, or practices; the removal of architectural, communication, or transportation barriers; or the provision of auxiliary aids and services, meets the essential eligibility requirements for the receipt of services or the participation in programs or activities provided by the City.

B. Regarded as Having a Disability

An individual is disabled if she or he is treated or perceived as having an impairment that substantially limits major life activities, although no such impairment exists.

Discrimination on the Basis of Disability

Discrimination on the basis of disability means to:

- Limit, segregate, or classify a citizen in a way that may adversely affect opportunities or status because of the person's disability;
- Limit, segregate, or classify a participant in a program or activity offered to the public in a way that may adversely affect opportunities or status because of the participant's disability;
- Participate in a contract that could subject a citizen with a disability to discrimination;
- Use any standards, criteria, or methods of administration that have the effect of discriminating on the basis of disability;
- Fail to make reasonable modifications to accommodate known physical or mental limitations of an otherwise qualified individual with a disability unless it can be shown that the modification would impose an undue burden on the City's operations;
- Use selection criteria that exclude otherwise qualified people with disabilities from participating in the programs or activities offered to the public; and
- Fail to use tests in a manner that ensures that the test results accurately reflect the qualified applicant's skills or aptitude to participate in a program or activity.

Having a Record of Impairment

An individual is disabled if he or she has a history of having an impairment that substantially limits the performance of a major life activity; or has been diagnosed, correctly or incorrectly, as having such impairment.

Hearing Impairment

Partial or total deafness.

Learning disabilities

Any form of physical or mental disability that delays development or acquisition of knowledge.

Marked Crossing

A *marked crossing* is a crosswalk or other identified path intended for pedestrian use in crossing a vehicular way.

Mobility disabilities/mobility impairment

A condition limiting physical ability; generally considered to include lack of a limb or loss of limb use due to disease, amputation, paralysis, injury, or developmental condition; or limitation of movement due to cardiovascular or other disease.

Physical or Mental Impairments

Physical or mental impairments may include, but are not limited to: vision, speech, and hearing impairments; emotional disturbance and mental illness; seizure disorders; mental retardation; orthopedic and neuromotor disabilities; learning disabilities; diabetes; heart disease; nervous conditions; cancer; asthma; hepatitis B; HIV infection (HIV condition); and drug abuse if the drug user has successfully completed or is participating in a rehabilitation program and no longer uses illegal drugs.

The following conditions are not physical or mental impairments: transvestitism; transexualism; current illegal drug use; homosexuality or bisexuality; compulsive gambling; kleptomania; pyromania; pedophilia; exhibitionism; voyeurism; pregnancy; height; weight; eye color; hair color; left-handedness; poverty; lack of education; a prison record; and poor judgment or quick temper that are not symptoms of a mental or physiological disorder.

Program Accessibility

A public entity's services, programs, or activities, when viewed in their entirety, must be readily accessible to and usable by individuals with disabilities. This standard, known as *program accessibility*, applies to all existing City facilities.

Reasonable Modification

If individuals' disabilities prevent them from performing the essential functions of the program or activity, it is necessary to determine whether *reasonable modification* would enable these individuals to perform the essential functions of the program or activity.

Reasonable modification is any change in program or activity or in the way things are customarily done that enables an individual with a disability to enjoy equal program

opportunities. Modifications may mean adjustments:

- To a registration or application process to enable an individual with a disability to be considered for the program or activity; and
- That enables individuals with disabilities to enjoy equally the benefits of the program or activity as other similarly situated individuals without disabilities enjoy.

Modification includes making existing facilities and equipment used by individuals readily accessible and usable by individuals with disabilities.

Modification applies to:

- All decisions and to the application or registration process;
- All services provided in connection with the program or activity; and
- Known disabilities only.

Modification is not required if:

- It changes the essential nature of a program or activity;
- It creates a hazardous situation; or
- It poses an undue burden.

Service Animal

The ADA defines a service animal as any guide dog, signal dog, or other animal individually trained to provide assistance to an individual with a disability. If they meet this definition, animals are considered service animals under the ADA regardless of whether they have been licensed or certified by a state or local government. Service animals perform some of the functions and tasks that the individual with a disability cannot perform for him or herself. Some of the typical uses of service animals are:

- Guiding persons with visual impairments;
- Alerting persons with hearing impairments to sounds;
- Pulling wheelchairs or carrying and picking up things for persons with mobility impairments; or
- Assisting persons with mobility impairments to maintain their balance.

Although a number of states have programs to certify service animals, agencies or businesses may not insist on proof of state certification before permitting the service animal to accompany the person with a disability.

SETP

Acronym for Self-Evaluation and Transition Plan.

Substantial Limitation of Major Life Activities

An individual is disabled if she or he has a physical or mental impairment that:

- Renders her or him unable to perform a major life activity, or
- Substantially limits the condition, manner, or duration under which she or he can perform a particular major life activity in comparison to other people.

Major life activities are functions such as caring for oneself, performing manual tasks, walking, seeing, hearing, speaking, breathing, learning, and working.

In determining whether a physical or mental impairment *substantially limits* the condition, manner, or duration under which an individual can perform a particular major life activity in comparison to other people, the following factors shall be considered:

- The nature and severity of the impairment;
- The duration or expected duration of the impairment; and
- The permanent or long-term impact (or expected impact) of or resulting from the impairment.

TDD

A Telecommunication Device for the Deaf allows a person to transmit typed messages over the phone lines to another person with a TDD. Most TDD's include a keyboard for typing messages to send and a display and/or printer to receive messages.

TTY

TTY stands for Text Telephone and is a registered trademark for a specific kind of TDD.

Appendix B

Programs/Services/Activities Self-Evaluation Questionnaire

AMERICANS with DISABILITIES ACT

PROGRAMS/SERVICES/ACTIVITIES SELF-EVALUATION QUESTIONNAIRE

BACKGROUND:

The purpose of this questionnaire is to gather data on how your department's programs¹ are, or are not, accessible to people with disabilities. Questions are in the areas of:

Description of Program Activities

Accessible/Adaptive Equipment

Customer Service

Notice Requirements

Printed Information

Television and Audiovisual Public Information

Website

Public Telephones and Communication Devices

Training and Staffing

Program Eligibility Requirements and Admission

Public Meetings

Transportation Services

Tours and Trips

Use of Consultants

Emergency Evacuation Procedures

Facilities

Special Events and Private Events on Public Properties

Your participation in completing this questionnaire will assist your department in improving its ability to serve the needs of people with disabilities.

INSTRUCTIONS:

Please fill out a separate questionnaire for each program or service offered by your Department. For example, The Police Department operates programs/services in several Divisions. A separate questionnaire needs to be filled out for each program.

After completing the questionnaire, please submit to Michael Brinton in Engineering via email or drop off. Supporting materials such as forms, brochures, etc. can be included as well.

Deadline is October 17, 2014.

General description of the programs¹

Department/Division: _____

Date program questionnaire filled out: _____

Name/title of person completing this questionnaire: _____

Telephone #: _____ Email: _____

Program name: _____

Brief description of program: _____

A. Accessible/ Adaptive Equipment

- A1** Do you allow the public to use electronic equipment (i.e. copying machines, personal computers, microfilm readers, etc.) in your programs?

Yes___ No___ N/A___

Please describe:

- A2** Do you ensure that electronic equipment is accessible to and usable by individuals with disabilities by providing equipment such as workstations, easily reachable equipment, or staff

¹ "Programs", when used in this questionnaire, refers to programs, activities and services offered to the public by the City.

assistance?

Yes___ No___ Don't know___

If yes, please describe:

- A3** Are auxiliary aids (such as tools, access to equipment, moveable light sources, adjustable worktable levels, paper and pen, etc.) provided to assist persons with disabilities?

Yes___ No___

If yes, please describe:

B. Customer Service

- B1** If any of the department's programs (activities or services) have eligibility requirements for participation, do they contain any of the following?

Physical or mental fitness or performance requirements? Yes___ No___

If yes, please describe:

Safety Standards? Yes___ No___

If yes, please describe:

- B2** How do you ensure that these policies do not discriminate against people with disabilities?
Please write your answer here:

- B3** Does your department make changes to standard operating procedures to include a person with disabilities?

Yes___ No___ Don't Know___

If yes, please briefly describe this process:

- B4** Is there a formal procedure for making changes to standard operating procedure?

Yes___ No___ Don't Know___

If yes, please briefly describe the process you have established:

- B5** Do you track accessibility requests? Yes___ No___ Don't Know___

If yes, how many requests have you received and what type:

B6 Does your program charge an additional fee for people with disabilities for modifying programs?

Yes___ No___ Don't Know___

If yes, please briefly describe the fees or charges:

B7 Does your department consult or work with any outside organizations that assist people with disabilities?

Yes___ No___ Don't Know___

If yes, please provide a list of organizations:

C. Notice Requirements

C1 Do you have a non-discrimination statement that includes persons with disabilities?

Yes___ No___ Don't Know___

Please describe:

C2 Is a non-discrimination statement that includes information about how to reach the ADA coordinator posted in all departments in a location that maximizes public exposure?

Yes___ No___ Don't Know___

Please describe:

C3 Do you notify all persons that your meetings, hearings, interviews, and conferences will be held in accessible locations and that adaptive/auxiliary aids (such as assistive listening devices, readers for the blind, pen and paper) will be provided, upon request, to participants with disabilities?

Yes___ No___ Don't Know___

C4 How do you notify all persons about how and with whom to file a disability discrimination complaint and what procedures are they told to follow? Please describe the process here:

D. Printed Information

D1 Do you provide printed information to the public?

Yes___ No___ Don't Know___

D2 What type of printed documents do you publish and distribute to the public? (Only answer if

you answered "yes" to D1) Please describe:

D3 Are all the program documents controlled centrally? (Only answer if you answered "yes" to D1)

Yes___ No___ Don't Know___

D4 How do you make documents and publications available to individuals with visual disabilities? (check all that apply):

___ Audiotape

___ Large print

___ Braille

___ Electronic Copy

___ Do not provide any alternative formats upon request

___ Other: If so, please list them:

D5 Do you make the content of documents and publications available in simple, easy-to-understand language for individuals with learning disabilities?

Yes___ No___ Don't Know___

If yes, provide a sample copy of the document or publication.

D6 Do you show images of people in your publications? Yes___ No___ Don't Know___

D7 Do you also include images of people with disabilities? Yes___ No___ Don't Know___

If yes, provide a sample copy of the document or publication.

E. Television and Audiovisual Public Information

E1 Does your department prepare audiovisual or televised presentations or website demonstrations/webinars for the public or make audiovisual presentations to the public?

Yes___ No___ Don't Know___

E2 How do you make audiovisual or televised or on-line presentations prepared or presented by your department to the public accessible to individuals with disabilities?

___ Captioning

___ Transcription

___ Do not provide alternative formats upon request

___ Other: If so, please list them:

E3 What type of audiovisual presentations (film, videotape, television) does your department provide? (Only answer this question if you answered “yes” to E1). Please describe:

E4 Do you show images of people in your audiovisual presentations? (Only answer this question if you answered “yes” to E1).

Yes___ No___ Don't Know___

If yes, provide a sample copy of the presentation.

E5 Do you also portray individuals with disabilities in your audiovisual presentations? (Only answer this question if you answered “yes” to E4).

Yes___ No___ Don't Know___

If yes, provide a sample copy of the presentation.

F. Website

F1 Does your department have a website? Yes___ No___ Don't Know___

F2 What is your department's website? What information is provided on this site?
Please describe briefly what information is provided:

F3 Does your department's website include information about accessibility of facilities (parking, bathrooms, assistive listening devices, etc.) where programs or services are offered? (Only answer if you answered “yes” to F1).

Yes___ No___ Don't Know___

Please describe briefly what information is provided about accessible features:

F4 Does your department ensure that its website is usable by individuals with disabilities, including those who use speaking browsers?

Yes___ No___ Don't Know___

F5 Are the documents provided on your website for downloading accessible to persons with visual disabilities?

Yes___ No___ Don't Know___

Please describe:

G. Public Telephones and Communication Devices

G1 How do you communicate by telephone with individuals with hearing or speech difficulties?
Please describe:

G2 If you use Text Telephones (TTY's) or Telecommunication Devices for the Deaf (TDD's), list the location, telephone number, and organization of TTY/TDD directories in which the TTY/TDD number is listed:

G3 Do you use the California relay service (711)? Yes___ No___ Don't Know___
Please describe:

G4 Do you publish your TTY/TDD number or California Relay Service numbers in all materials where a phone number is listed?
Yes___ No___ Don't Know___
Please describe:

G5 Do you train your staff in operating TTY/TDD's and in other means of communicating over the telephone with a person with a hearing or speech disability?
Yes___ No___ Don't Know___
Please describe:

H. Training and Staffing

H1 Do any staff members have contact with the public?
Yes___ No___ Don't Know___

H2 How do you inform staff members who have contact with the public of your department's obligations and policies that enable persons with disabilities to participate in programs or activities? Please describe:

H3 How have you trained these staff members? (Only answer if you answered “yes” to H2).
Please describe:

H4 Are there staff members in your department who provide emergency services to the public?

Yes___ No___ Don't Know___

If yes, describe:

H5 If yes, have they had training in American Sign Language (ASL) or other means of communicating in emergency situations with people who have hearing or speech impairments? Please describe:

H6 Are there other staff members who would be able to provide better customer service if they had training in American Sign Language (ASL) or other means of communicating with people who have hearing impairments?

Yes___ No___ Don't Know___

Please describe:

I. Program Eligibility Requirements and Admission

I1 Are there any limitations or ratios for the number of people with disabilities who may participate in or be admitted to any department program?

Yes___ No___ Don't Know___

If yes, please briefly describe the programs:

I2 Does your program use any criteria (for example good health, residency, letters of recommendation) or written and/or oral tests (including level of skill or achievement, or other factor being tested) in the admissions process?

Yes___ No___ Don't Know___

I3 If yes, please list and describe participation requirements. (Only answer if you answered “yes” to I3).

- I4** Are there any forms required for admission to the program (for example, tests and/or the submission of other admissions criteria such as certificates?).

Yes___ No___ Don't Know___

If yes, please list the forms or email them to Terry Rodrigue

- I5** Do the forms contain a notice that your organization does not discriminate against people with disabilities?

Yes___ No___ Don't Know___

Please describe:

- I6** Is an interview required prior to an applicant's entrance into the program?

Yes___ No___ Don't Know___

Please describe:

J. Public Meetings

- J1** Does your department hold public meetings? Yes___ No___ Don't Know___

- J2** Do you require that public meetings, hearings, and conferences be held in accessible locations?

Yes___ No___ Don't Know___

- J3** Are interpreters, readers, or adaptive equipment provided when requested for meetings, interviews, and conferences?

Yes___ No___ Don't Know___

- J4** How much advance notice do you request? (Only answer if you answered "yes" to J3).

- J5** Do you ensure that all individuals with hearing disabilities who do not read sign language can participate effectively in meetings, conferences, and hearings via assistive listening devices or other means?

Yes___ No___ Don't Know___

Please describe:

K. Transportation Services

- K1** Do you provide transportation to volunteers, program participants, visitors, and others who participate in your programs?

Yes___ No___ Don't Know___

- K2** What procedures does your department follow to make transportation accessible to persons who have visual disabilities? Please describe:
- K3** What procedures does your department follow to make transportation accessible to persons who have hearing disabilities? Please describe:
- K4** What procedures does your department follow to make transportation accessible to persons who have mobility disabilities? Please describe:
- K5** What procedures does your department follow to make transportation accessible to persons who have learning disabilities? Please describe:

L. Tours and Trips

- L1** Does your department provide tours of your facilities or organize trips for members of the public?
Yes___ No___ Don't Know___
- L2** Please list and describe the tours and trips. (Only answer if you answered "yes" to L1).
- L3** How do you provide accessible tours to people with visual impairments? Please describe:
- L4** How do you provide accessible tours to people with hearing impairments? Please describe:
- L5** How do you provide accessible tours to people with mobility impairments? Please describe:
- L6** How do you provide accessible tours to people with learning impairments? Please describe:

M. Use of Consultants

M1 Do you use consultants to conduct programs on behalf of your department?

Yes___ No___ Don't Know___

M2 How do you ensure that consultants are aware of their obligations to facilitate participation of individuals with disabilities in programs or activities operated on behalf of your department?
Please describe:

M3 How do you monitor this obligation? Please describe:

N. Emergency Evacuation Procedures

N1 What equipment and/or procedures do you use to notify individuals with visual disabilities of emergencies and evacuation procedures?

Please list equipment and/or procedures specific to individuals with visual disabilities.

N2 What equipment and/or procedures do you use to notify individuals with hearing disabilities of emergencies and evacuation procedures?

Please list equipment and/or procedures specific to individuals with visual disabilities.

N3 What equipment and/or procedures do you use to notify individuals with mobility disabilities of emergencies and evacuation procedures?

Please list equipment and/or procedures specific to individuals with visual disabilities.

N4 What equipment and/or procedures do you use to notify individuals with cognitive disabilities of emergencies and evacuation procedures?

Please list equipment and/or procedures specific to individuals with visual disabilities.

O. Facilities

- O1** List all facilities, or portions of facilities, used for department programs. For each facility, designate the activity for which it is used. (Note: Facilities leased or otherwise used from another person/organization should also be included).

- O2** Have you had requests for improving accessibility to your department's programs or facilities?

Yes___ No___ Don't Know___

Please describe:

- O3** Would the implementation of any measure to improve accessibility for people with disabilities to your programs pose an unfair financial or administrative burden?

Yes___ No___ Don't Know___

If yes, list an alternative means that would not pose a financial or administrative burden.

P. Special Events and Private Events on Public Properties

- P1** Does your department organize special events or do you help facilitate private events on public property?

Yes___ No___ Don't Know___

If yes, please describe briefly the type of event and what types of outside organizations are involved.

- P2** How do you ensure that both private entities and your staff are aware of their obligations to facilitate participation of individuals with disabilities in these special events or private events held on public property? Please describe:

Thank you for completing this survey!

Appendix C

Public Notices

- ✓ **Self-Evaluation Process of the ADA Self-Evaluation and Transition Plan**
 - ✓ **Notice Inviting Feedback at Public Meeting for the DRAFT Plan**
 - ✓ **Feedback Form**



CITY OF CERES
2220 MAGNOLIA STREET CERES, CA 95307
PH: (209) 538-5792 FX: (209) 538-5675

July 21, 2015

**Public Notice of the Self-evaluation process for the:
City of Ceres Americans with Disabilities Act (ADA) Self-evaluation and Transition Plan**

The City of Ceres is in the process of updating the Americans with Disabilities Act (ADA) Self-evaluation and Transition Plan (Plan). Areas to be evaluated include facility accessibility, accommodations for individuals with disabilities and administrative policies and procedures.

Individuals who would like to provide input are invited to complete a survey. Surveys are available for organizations that represent individuals with disabilities, community members, employees and other interested individuals who wish to participate in the evaluation. Surveys are due to the City by August 28, 2015. A Public Meeting will be held in September/October 2015 to inform the public about the Plan and to gather comments/opinions from the community. The Plan will be taken to the City Council meeting for adoption once the City has review comments and input from the community. The Public Meeting and the Council Meeting will be held at the Community Center, 2701 4th Street, Ceres, CA 95307.

Your comments and opinions are important to us and will provide valuable information regarding how the City of Ceres can better accommodate individuals with disabilities. Surveys are available at the following locations:

- ✓ City of Ceres, Engineering Department, 2220 Magnolia Street, Ceres, CA 95307
- ✓ Community Center, 2701 4th Street, Ceres, CA 95307.
- ✓ Online at Website: <http://www.ci.ceres.ca.us>
- ✓ mailed to you by calling the Engineering Department at (209) 538-5792

Please contact Daryl Jordan, ADA coordinator at 209-538-5792 or Daryl.Jordan@ci.ceres.ca.us if you have questions or comments or would like a survey in an alternate format. Information regarding the Americans with Disabilities Act can be obtained from the ADA Coordinator.



CITY OF CERES

2220 MAGNOLIA STREET CERES, CA 95307 PH: (209) 538-5792 FX: (209) 538-5675

**SURVEY INPUT FOR PROGRAMS AND FACILITIES
FOR THE ADA SELF-EVALUATION AND TRANSITION PLAN**

What is your relationship to the City of Ceres? (Circle all that apply)			
Visitor	Community member	Contractor	Participant of a program
	Employee	Resident	Other
QUESTIONS			
1. Please list any accommodation requests made to the City and state whether the accommodation was met: (if this does not apply, please put N/A)			
2. Please list any specific buildings or facilities which you have accessibility concerns and describe the nature of the concern:			
3. Please list any specific parks which you have accessibility concerns and describe the nature of the concern:			
4. Please list any specific programs, services or activities where you have accessibility concerns and describe the nature of the concern:			

5. Please list any specific curb, sidewalk or crossing location(s) where you have accessibility concerns and describe the nature of the concern:	
6. What do you feel is the highest priority for the City of Ceres to improve accessibility?	
7. Do you know who to contact to request accommodations?	
8. Do you have any additional comments or concerns?	
May we contact you if we have further questions? ☐ Yes ☐ No	
Name:	Company (if applicable):
Email:	Phone:

We value your input. Please return this Survey by August 28th, 2015 to:

Attention: Kevin Waugh

By mail or in person: CITY OF CERES, 2220 MAGNOLIA STREET, CERES CA 95307

By fax: (209) 538-5675

By email: Kevin.Waugh@ci.ceres.ca.us

OR directly online at the City's website: <http://www.ci.ceres.ca.us>

Please contact Kevin Waugh, at (209) 538-5792 or Kevin.Waugh@ci.ceres.ca.us, if you have questions or comments.



The City of Ceres

invites you to take part in the

ADA Title II Self-Evaluation and Transition Plan Process

AUGUST 18, 2016
2:00 PM - 3:00 PM
2701 4th Street
Council Chambers at
Ceres Community Center



The City of Ceres is requesting feedback on the City's draft ADA Self-Evaluation and Transition Plan. Over the last year the City conducted an exhaustive self-evaluation of the City's programs, policies, and facilities on accessibility and has created a plan which identifies barriers and establishes the commitment to ensuring accessibility to all individuals. Your opinion is important and will provide valuable information regarding how the City of Ceres can better accommodate individuals with disabilities. Please join us to:

- ⇒ Ask questions
- ⇒ Discuss the Plan and meet with City staff
- ⇒ Provide input

The Draft ADA Self-Evaluation and Transition Plan and Feedback Form can be found on the City's website or contacting the ADA coordinator below. The Plan will be available for review until September 2, 2016.

For any questions, or if you need special assistance to participate in this meeting or require documents in an alternative format, please contact the ADA coordinator at:



Kevin Waugh
Phone: 209-538-5775
Email: Kevin.Waugh@ci.ceres.ca.us
Website: <http://www.ci.ceres.ca.us>



The City of Ceres
invites you to take part in the
ADA Title II Self-Evaluation & Transition Plan Process

The City of Ceres is requesting your feedback on the City's draft ADA Self-Evaluation and Transition Plan by submitting this **Feedback Form**. Your opinion is important and will provide valuable information regarding how the City of Ceres can better accommodate individuals with disabilities. The Draft ADA Self-Evaluation and Transition Plan can be found on the City's website noted below. Questions, Comments or Form submittal can be sent to the ADA Coordinator, mailed/faxed or dropped at:

ADA Coordinator: Kevin Waugh
Email: Kevin.Waugh@ci.ceres.ca.us
Engineering Department
2220 Magnolia Street, Ceres, CA 95307

Website: <http://www.ci.ceres.ca.us> Phone:
(209) 538-5775 FAX: 209-538-5675

Name:	
Email Address (optional):	Phone Number (optional):
Are you a resident of the City of Ceres?	
Have you reviewed the City's draft ADA Self-Evaluation and Transition Plan?	
Do you feel the Plan meets the City's needs or your needs? Please explain	
Is there a specific section of the Plan you have comments or suggestions on? Please reference page #.	
Overall, please rate your opinion of the Plan from 1 to 10 (1=Great, 10=Needs Work):	
Please use this space for any other comments:	

*** The Plan & Feedback Form is available until September 2, 2016 – Thank you for your Feedback ***

Appendix D
ADA Service Accomodation Request Form




CITY OF CERES ADA Service Accommodation Request Form

Date:	Phone of Requestor:
Name of Requestor:	Email of Requestor:
Address of Requestor (Optional):	
This is a request for accommodation which is needed because of my disability	
1. I am applying for services provided by the City of Ceres, Department of _____	
2. The accommodation I am requesting will allow me to participate in the following activity and/or service: _____ _____	
3. My specific functional limitation is: _____ _____	
4. Describe the reasonable accommodations that are necessary: _____ _____ _____	
5. Additional Comments: _____ _____	
Requestor Signature:	Date:

Return this form to: Kevin Waugh, City ADA Coordinator
2220 Magnolia Street, Ceres, CA 95307
Email: Kevin.Waugh@ci.ceres.ca.us
Phone: (209)538-5775



Appendix E
ADA Public Notice



CITY OF CERES

ADA PUBLIC NOTICE



In accordance with the requirements of Title II of the Americans with Disabilities Act of 1990 ("ADA"), the City of Ceres will not discriminate against qualified individuals with disabilities on the basis of disability in its services, programs, or activities.

Employment: City of Ceres does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under Title I of the ADA.

Effective Communication: City of Ceres will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in the City of Ceres programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, or vision impairments.

Modifications to Policies and Procedures: City of Ceres will make all reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all of its programs, services, and activities. For example, individuals with service animals are welcomed in City of Ceres offices, even where pets are generally prohibited.

Anyone who requires an auxiliary aid or service for effective communication, or a modification of policies or procedures to participate in a program, service, or activity of City of Ceres, should contact, Michael Brinton, City ADA Coordinator at 209-538-5758 or michael.brinton@ci.ceres.ca.us as soon as possible but no later than 48 hours before the scheduled event.

The ADA does not require the City of Ceres to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.

Complaints that a program, service, or activity of City of Ceres is not accessible to persons with disabilities should be directed to:

**Kevin Waugh, City ADA
Coordinator**

**2220 Magnolia St
Ceres, CA 95307
209-538-5775
209-538-5675 fax**

E-mail:

Kevin.Waugh@ci.ceres.ca.us

The City of Ceres will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids/services or reasonable modifications of policy, such as retrieving items from locations that are open to the public but are not accessible to persons who use wheelchairs.

Appendix F
ADA Grievance Form



CITY OF CERES ADA Grievance Procedure



The grievance procedure is established to meet the requirements of the Americans with Disabilities Act of 1990 (ADA). It may be used by anyone wishing to file a complaint alleging discrimination on the basis of disability in the provisions of services, activities, programs or benefits by the City of Ceres.

Written Complaint: The complaint should contain as much information as possible about the alleged discrimination. Information should include name, address, phone number of the complainant and location, date and a description of the problem(s). Alternative means of filing a complaint, such as personal interview or a tape recording of the complaint, assistance with filing on the City of Ceres Grievance Form, is available upon request.

The complaint should be submitted by the grievant and/or his/her designee as soon as possible but no later than 60 calendar days after the alleged discrimination to:

Kevin Waugh, City ADA Coordinator
2220 Magnolia Street
Ceres, CA 95307
Email: Kevin.Waugh@ci.ceres.ca.us
Phone: (209)538-5775

Meeting: Within fifteen (15) calendar days after receipt of the complaint, the ADA Coordinator will schedule a meeting with the complainant to discuss the complaint and possible resolutions. After an investigation and review of the complaint, the ADA Coordinator will respond in writing, and where appropriate, in a format accessible to the complainant. The response will explain his/her position on the issue and offer options for substantive resolution of the complaint.

Appeal: If the response by the ADA Coordinator does not satisfactorily resolve the issue, the complainant may appeal the decision within fifteen (15) calendar days after receipt of the response to the City Manager.

After receiving the appeal, the City Manager or his designee will review the appeal and the ADA Coordinator finding. Within a reasonable period, after a review, the City Manager or his designee will respond in writing, or in a format that is accessible to the complainant, with a final resolution to the complaint.



CITY OF Ceres ADA Grievance Procedure



Date:	Phone of Grievant:
Name of Grievant:	Email of Grievant:
Address of Grievant:	
Name, Address and Phone of Alternate Contact Person:	
Department alleged to have denied access:	Date of denied access:
Location:	
Disability Statement - My disability is:	
This problem is: (Circle one) temporary permanent	
Please describe the particular way in which you believe you have been denied the benefits of any services, program or activity or have otherwise been subjected to discrimination. Attach any additional pages if necessary. Include a description of the way in which accommodation could be provided to allow access.	

Return this form to: Kevin Waugh, ADA Coordinator
2220 Magnolia Street Ceres, CA 95307
Email: kevin.waugh@ci.ceres.ca.us Phone: (209) 538-5775

Appendix G

Facilities Summary List of Architectural Barriers

City of Ceres
ADA Self Evaluation and Transition Plan

LIST OF FACILITIES

Description		Address	Park Cross Streets	Use	Public Programs
Buildings (& Associated Parking Lots)					
1	City Hall - General Administration	2220 Magnolia St., Ceres, CA 95307		City Hall offices, Building Permits, Utility Billing	YES
2	Library	2250 Magnolia St., Ceres, CA 95307		Library use	YES
3	Police - Public Safety	2727 3rd St., Ceres, CA 95307		Police Dept.	NO
4	Fire Station #1	2755 3rd St., Ceres, CA 95307		Fire Station	NO
5	Fire Station #2	830 Pecos Ave., Modesto, CA 95351		Fire Station	NO
6	Fire Station #3	420 E. Service Rd., Modesto, CA 95358		Fire Station	NO
7	Fire Station #4	3101 Fowler Rd., Ceres, CA 95307		Fire Station	NO
8	American Legion Hall	2609 Lawrence St. Ceres, CA 95307		Special Event Rental	YES
9	Ceres Community Center	2701 4th St., Ceres, CA 95307		Special Event Rental	YES
10	Whitmore House & Museum	2928 5th St., Ceres, CA 95307		Historical Society/Community Events	YES
11	Whitmore Mansion	2732 5th St., Ceres, CA 95307		Special Event Rental	YES
12	Public Works Corporation Yard	2220 Hackett Rd., Ceres, CA 95307		Including: Adm Building, Facilities Shop	NO
				Water, & Streets and Fleet Shop	
13	Parks Office & Shop	2650 Fowler Rd., Ceres, CA 95307		Adm Offices, Breakroom, Equipment Area	NO
14	Wastewater Treatment Plant	4200 Morgan Rd., Ceres, CA 95307		Sewer Treatment Plant and Aeration Ponds	NO
Parks and Concessions					
15	Berry Grove Park	2409 Calcagno St., Ceres, CA 95307	Linden Dr.	Picnic, Play Equipment	YES
16	Costa Fields Complex	Rose Ave. , Ceres, CA 95307	Between Fowler & Garrison	Concessions, Baseball Fields, Restroom, Storage	YES
17	Don Pedro Park	3630 Blaker Rd., Ceres, CA 95307	Walnut Ave.	Picnic, Play Equipment, Adult Fitness Area	YES
18	Independence Park	1639 Paramount	Belmon Ave.	Picnic, Play Equipment	YES
19	Neel Park	Boothe & Helen Perry		No Amenities	YES
20	Persephone Park	2117 Lunar Dr.	Lindsay Way	Picnic, Play Equipment	YES
21	Redwood Park	2700 Veda Dr.	10th St.	Picnic, Play Equipment	YES
22	Riverbluff Park	3643 E. Hatch Road		Concessions, Picnic, Playground, Various activity areas	YES
23	Riverview Park	2700 Canyon Dr.	Riverpark Dr.	Picnic, Play Equipment	YES
24	Roeding Heights Park & Restroom	2824 Stanford Ave.	Rose Ave.	Picnic, Playground, Various activity areas	YES
25	Sam Ryno Park	Brown Ave. & Stone Springs Dr.		No Amenities	YES
26	Smyrna Park	2650 Fowler Road	Fowler & Moffett Rds	Picnic, Playground, Skate Park, Various Activity areas	YES
27	Strawberry Fields Parks & Restroom	3200 Malik Dr.	Hackett & Morgan Rds.	Picnic, Play Equipment	YES
28	Whitmore Park & Restroom	2921 3rd Street	North St.	Picnic Area, Gazebo	YES

CITY HALL

2220 Magnolia Street, Ceres CA

Location: City Hall - Street Parking

Date of Assessment: April 2015

Findings: Non-compliant parking signs, and striping
Recommendation: Install striping and parking signs per ADAAG

Estimated Construction Cost: \$3,000

Priority: 1



Location: City Hall - Entrance at 2nd St (Finance)

Date of Assessment: April 2015

Findings: Non-compliant main door landing/
sidewalk and walkway to entrance

Recommendation: Provide accessible landing,
sidewalk and walkway per ADAAG

Estimated Construction Cost: \$10,000

Priority: 1



Location: City Hall - Finance Counter and Engineering & Planning Counter

Date of Assessment: April 2015

Findings: Non-compliant counter heights, and
clearance of counter to doors (Finance), provide
door clearances at Engineering & Planning
(relocate play table)

Recommendation: Provide area with accessible
counter height per ADAAG, relocate play table and
other obstructions from door areas.

Estimated Construction Cost: \$7,000

Priority: 1



CITY HALL (continue)

2220 Magnolia Street, Ceres CA

Location: City Hall - Magnolia Entrance

Date of Assessment: April 2015

Findings: Non-compliant slopes at entrance and patio area

Recommendation: Provide accessible landing, sidewalk and walkway per ADAAG

Estimated Construction Cost: \$10,000

Priority: 1



Location: City Hall - Lobby Area at Magnolia entrance,
Lobby Area at 2nd St. entrance

Date of Assessment: April 2015

Findings: Display of materials are at non-compliant reach height, drinking fountains do not meet ADA dimensions, fire extinguisher height, exit signage missing tactile

Recommendation: Relocate displays, and install drinking fountains and other adjustments to meet ADAAG

Estimated Construction Cost: \$7,000

Priority: 1



CITY HALL (continue)
2220 Magnolia Street, Ceres CA

Location: City Hall - Restrooms from Lobby area


Date of Assessment: April 2015

Findings: Non-compliant signage, doors,
Fixtures clearances, overall space clearances, strobe
light mounting height, etc

Recommendation: Remodel restroom for compli-
ance with ADAAG

Estimated Construction Cost: \$30,000

Priority: 3



COMMUNITY CENTER

2701 4th Street, Ceres CA

Location: Community Center – Exterior Access, Parking, Main entrance


Date of Assessment: April 2015

Findings: Non-compliant slope and path of travel along public path at 5th street, non-accessible parking due to signage mount height, fine signage missing, striping color, striping font size, detectable warning, excessive running slopes to main entry

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$15,000

Priority: 1



COMMUNITY CENTER (continue)

2701 4th Street, Ceres CA

Location: Community Center – General building


Date of Assessment: April 2015

Findings: Non-compliant opening force of main door, display materials out of reach ranges, handrails at top and bottom of main stair and stairs at rear are non-compliant, no tactile provided at exit signs (locations are not compliant),

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$8,000

Priority: 1



COMMUNITY CENTER (continue)

2701 4th Street, Ceres CA

Location: Community Center – Council Chambers

Date of Assessment: April 2015

Findings: Non-accessible facilities including ramp, landing, handrails, podium/counter

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$15,000

Priority: 1



COMMUNITY CENTER (continue)

2701 4th Street, Ceres CA

Location: Community Center – General amenities


Date of Assessment: April 2015

Findings: Throughout building, no assistive listening devices, exit signs are missing or located incorrectly, light switch height, electrical outlet height, reach ranges for DVD players, door clearance at Patio and Health and Fitness Room, non-accessible soap dispensers, non-accessible sinks due to clearance

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$5,000

Priority: 1



Location: Community Center – Restrooms Upstairs & Downstairs

Date of Assessment: April 2015

Findings: Non-compliant facilities: door signage height, door clearance, doors are too heavy, stall width/clearance, dispensers heights, grab bar, toilet tissue access and pipes are not wrapped

Recommendation: relocate dispensers and clear areas for immediate ADA compliance, other deficiencies to be upgraded per ADAAG

Estimated Construction Cost: \$50,000

Priority: 2



COMMUNITY CENTER (continue)
2701 4th Street, Ceres CA

Location: Community Center – Room Usage

Date of Assessment: April 2015

Findings: Rooms throughout are non-accessible due to aisle clearance and access to tables or stations.

Includes Upstairs Meeting Room, Computer Room, Teen Lounge and Arts and Crafts Room.

Recommendation: Provide accessible clearance and access

Estimated Construction Cost: \$1,000

Priority: 2



LIBRARY

2250 Magnolia Street, Ceres CA

NOTE: At the time of the ADA survey assessment, the Library was closed and not open to the public due to interior renovations.

Location: Library – Exterior Access, On and Off -street Parking, Pedestrian Ramps



Date of Assessment: April 2015

Findings: Non-compliant slope, and path of travel, non-accessible parking due to slope, signage mount height, fine signage missing, striping color, striping font size, missing detectable warning system from sidewalk to parking area, excessive running slopes and non-compliant handrails to main entry

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$10,000

Priority: 1



POLICE DEPARTMENT

2727 3rd Street, Ceres CA

Location: Police Department – Exterior Walkway


Date of Assessment: April 2015

Findings: Non-compliant slope (excessive slope at the south and north side of the main entry), and path of travel, excessive running slope near steps, non compliant handrails near steps

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$12,000

Priority: 2



POLICE DEPARTMENT (continue)
2727 3rd Street, Ceres CA

Location: Police Department – Public Counter

Date of Assessment: April 2015

Findings: Accessible counter depth protrudes into door clearance for employee door.

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$5,000

Priority: 2



Location: Police Department – Interior Amenities

Date of Assessment: April 2015

Findings: Non-accessible call button, power assist door control, telephone, fire alarm pull station (reach height)

Recommendation: Relocate for accessibility to comply with ADAAG

Estimated Construction Cost: \$8,000

Priority: 2



AMERICAN LEGION HALL

2609 Lawrence Street, Ceres CA

Location: American Legion - Off Street Parking

Date of Assessment: April 2015

Findings: Non-accessible parking, (size, access aisle, striping, curb ramp and signage), parking protrudes into public pathway

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$10,000

Priority: 3



Location: American Legion - Exterior Doors
(Gondoring Room, Patio Room)


Date of Assessment: April 2015

Findings: Non-compliant door clearances, doors close too fast/forceful.

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$3,000

Priority: 3



Location: American Legion - Various

Date of Assessment: April 2015

Findings: Interior is missing tactile exit signage throughout; assistive listening devices are required; switches, thermostats not accessible, hardware at operable partition is non-compliant

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$15,000

Priority: 3

AMERICAN LEGION HALL (continue)

2609 Lawrence Street, Ceres CA

Location: American Legion - Restrooms


Date of Assessment: April 2015

Findings: Non-accessible amenities and fixtures (soap, mirror, and paper towels), Facilities are not accessible due to clearance (urinals, toilet paper, flush handle, grab bar), restroom sign height not-compliant, pipes not wrapped, clearance at restroom doors

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



Location: American Legion – Exterior Gate

Date of Assessment: April 2015

Findings: Non-Compliant, no kick plate

Recommendation: Install per ADAAG

Estimated Construction Cost: \$1,000

Priority: 3



AMERICAN LEGION HALL (continue)
2609 Lawrence Street, Ceres CA

Location: American Legion - Sink/Bar Areas

Date of Assessment: April 2015

Findings: Non-accessible reach height

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$8,000

Priority: 3



Location: American Legion - Drinking Fountains


Date of Assessment: April 2015

Findings: Non-Accessible due to reach height

Recommendation: Install per ADAAG

Estimated Construction Cost: \$7,000

Priority: 3



WHITMORE HOUSE & MUSEUM

2928 5th Street, Ceres CA

NOTE: At the time of the ADA survey assessment, the Whitmore House was listed as a qualified historical landmark.

Location: Whitmore House & Museum - Exterior Walkway

Date of Assessment: April 2015

Findings: Non-compliant path from public way. Non-accessible walkway due to slope, stairs, ramp, door, hardware and path

Recommendation: Level pathways, upgrade stairs and ramp, and door hardware to provide accessible route to building per ADAAG

Estimated Construction Cost: \$15,000

Priority: 3



Location: Whitmore House & Museum – Access Points


Date of Assessment: April 2015

Findings: Non-compliant access to museum (threshold, change in level, unstable surface) , main house (width, hardware and threshold) and non compliant access to restrooms (landing width/depths, floor clearance and interior access to door).

Recommendation: Provide accessible route to building and access point per ADAAG

Estimated Construction Cost: \$15,000

Priority: 3



WHITMORE HOUSE & MUSEUM (continue)
2928 5th Street, Ceres CA

Location: Whitmore House & Museum – Restroom


Date of Assessment: April 2015

Findings: Non-compliant access to restroom including missing signs, clearance for maneuvering at door and inside, dispenser mount heights

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Whitmore House & Museum – Museum Counter


Date of Assessment: April 2015

Findings: Non-compliant counter due to height

Recommendation: Provide accessible counter per ADAAG

Estimated Construction Cost: \$5,000

Priority: 3



WHITMORE MANSION

2732 5th Street, Ceres CA

NOTE: At the time of the ADA survey assessment, the Whitmore Mansion was not listed as a qualified historical landmark.

Location: Whitmore Mansion - Exterior Walkways

Date of Assessment: April 2015

Findings: Non-compliant stairs (handrails, risers, striping, width and landings). Non-compliant lift at rear porch area. Non-compliant paths of travel (curb ramp, running and cross slopes, changes in level).

Recommendation: Provide an accessible route to building per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



Location: Whitmore Mansion - Porch


Date of Assessment: April 2015

Findings: Non-accessible due to changes in level / door thresholds at wraparound throughout.

Recommendation: Provide an accessible route to building entry per ADAAG

Estimated Construction Cost: \$80,000-\$150,000

Priority: 3



WHITMORE MANSION (continue)
2732 5th Street, Ceres CA

Location: Whitmore Mansion - Various

Date of Assessment: April 2015

Findings: Non-compliant door hardware throughout, door width/clearance at many doors (parlor, storage at basement, changes in level of floor, general kitchen and dining area, upstairs), non-compliant restrooms at second floor, non-compliant wall sink at upstairs bedroom and non-compliant play area in attic, unaccessible routes to basement and other areas of the mansion and property site

Recommendation: Provide an accessible route to building and restrooms per ADAAG

Estimated Construction Cost: \$included in above
Priority: 3



BERRY GROVE PARK

2409 Calcagno Street, Ceres CA

Location: Berry Grove Park - Picnic Area

Date of Assessment: April 2015

Findings: Non-accessible picnic tables and designated ADA area, not located along an accessible path.

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Berry Grove Park - Play Equipment

Date of Assessment: April 2015

Findings: Non-accessible path to play equipment (slopes and pedestrian ramp)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



Location: Berry Grove Park - Paths of Travel

Date of Assessment: April 2015

Findings: Non-accessible paths, varying levels and slopes.

Recommendation: Provide accessible routes per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



COSTA FIELDS COMPLEX

Rose Avenue, Ceres CA

Location: Costa Fields Complex – Restrooms

Date of Assessment: April 2015

Findings: Non-compliant fixture locations including hand dryer, no ambulatory compartment, seat height and toilet tissue dispenser

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



Location: Costa Fields Complex – Picnic Area

Date of Assessment: April 2015

Findings: Non-accessible picnic area (Rose Avenue side).

Recommendation: Provide accessible path and designate picnic location per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Costa Fields Complex – Paths of Travel


Date of Assessment: April 2015

Findings: Non-accessible travel paths at Rose Avenue and path to Smyrna Park (running and cross slopes)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



COSTA FIELDS COMPLEX (continue)

Rose Avenue, Ceres CA

Location: Costa Fields Complex – Off Street Parking

Date of Assessment: April 2015

Findings: Non-compliant parking due to transition from access aisle to sidewalk, striping and signage

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$5,000

Priority: 3



Location: Costa Fields Complex– Condiment Area

Date of Assessment: April 2015

Findings: Non-compliant tray holder, protruding in walkway area

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$0

Priority: 3



Location: Costa Fields Complex– Spectator Areas

Date of Assessment: April 2015

Findings: Non-accessible seating space and path

Recommendation: Provide path and designate accessible area for wheelchair location per ADAAG

Estimated Construction Cost: \$10,000

Priority: 3



DON PEDRO PARK

3630 Blaker Road, Ceres CA

NOTE: At the time of the ADA survey assessment, the restroom building and immediate site area were to be under separate construction contract and are not included in this assessment.

Location: Don Pedro Park - Picnic area and benches

Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas and benches, lack of designated ADA amenities

Recommendation: Provide an accessible route and designate an ADA picnic and bench area per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



Location: Don Pedro Park - Play Equipment

Date of Assessment: April 2015

Findings: Non-accessible play structure due to access path and ground level play equipment.

Recommendation: Level pathway and add accessible play equipment per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



INDEPENDENCE PARK

1639 Paramount Avenue, Ceres CA

Location: Independence Park - Picnic area and benches

Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas and benches, lack of designated ADA amenities

Recommendation: Provide an accessible route and designate an ADA picnic and bench area per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Independence Park - Play Equipment

Date of Assessment: April 2015

Findings: Non-accessible play equipment (Access path and play equipment have no ground level access).

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



NEEL PARK

Boothe Road & Helen Perry Road, Ceres CA

Location: Neel Park – Path and Sidewalk

Date of Assessment: April 2015

Findings: Path and sidewalks to park areas exceed slope requirements (attached photo shows 8.7% running slope)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$10,000

Priority: 3



PERSEPHONE PARK

2117 Lunar Drive, Ceres CA

Location: Persephone Park - Picnic area and benches

Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas and benches, lack of designated ADA amenities

Recommendation: Provide an accessible route and designate an ADA picnic and bench area per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Persephone Park - Play Equipment

Date of Assessment: April 2015

Findings: Non-accessible route to play equipment. Access path and play equipment have no ground level access).

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



Location: Persephone Park - Path and Sidewalk

Date of Assessment: April 2015

Findings: Path and sidewalks to park areas exceed slope requirements (attached photo shows 16.8% cross slope)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



REDWOOD PARK

2700 Veda Drive, Ceres CA

Location: Redwood Park - Picnic area and benches

Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas and benches, lack of designated ADA amenities

Recommendation: Provide an accessible route and designate an ADA picnic and bench area per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Redwood Park - Play Equipment


Date of Assessment: April 2015

Findings: Non-accessible route to play equipment. Access path and play equipment have no ground level access (attached photo shows 11.6% cross slope)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



RIVERBLUFF PARK

23643 East Hatch Road, Ceres CA

NOTE: At the time of the ADA survey assessment, the park facility was under construction. A pedestrian path was not available to the park, only a vehicular path was open.

Location: Riverbluff Park - Off Street Parking


Date of Assessment: April 2015

Findings: Non-compliant curb ramps and accessible parking (slopes, paint, stall widths, signage)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$10,000

Priority: 3



RIVERBLUFF PARK (continue)
23643 East Hatch Road, Ceres CA

Location: Riverbluff Park - Restroom

Date of Assessment: April 2015

Findings: Non-compliant signage, door, hardware, amenities, and facilities.

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



RIVERVIEW PARK

2700 Canyon Drive, Ceres CA

Location: Riverview Park - Picnic Area

Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas, lack of designated ADA amenities.

Recommendation: Provide an accessible route and designate an ADA picnic and bench area per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Riverview Park - Play Equipment

Date of Assessment: April 2015

Findings: Non-accessible route to play equipment. Access path and play equipment have no ground level access (attached photo shows 11.6% slope on path and 11% slope on ramp to play equipment)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



ROEDING HEIGHTS PARK

2824 Stanford Avenue, Ceres CA

Location: Roeding Heights Park - Picnic Area
Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas, lack of designated ADA amenities.

Recommendation: Provide an accessible route and designate an ADA picnic area per ADAAG

Estimated Construction Cost: \$20,000
Priority: 3



Location: Roeding Heights Park - Play Equipment
Date of Assessment: April 2015

Findings: Non-accessible route to play equipment. Access path and play equipment have no ground level access

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above
Priority: 3



ROEDING HEIGHTS PARK (continue)
2824 Stanford Avenue, Ceres CA

Location: Roeding Heights Park - Restrooms


Date of Assessment: April 2015

Findings: Non-accessible restrooms including signage, fixtures, accessible compartments, and clearances

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



SAM RYNO PARK

Brown Avenue at Stone Springs Drive, Ceres CA

Location: Sam Ryno Park - Drinking Fountain

Date of Assessment: April 2015

Findings: Fountain encroaches on pedestrian route

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$10,000

Priority: 3



Location: Sam Ryno Park - Play Equipment and pathway

Date of Assessment: April 2015

Findings: Non-accessible pathway to play equipment and bench areas.

Recommendation: Provide an accessible route and designate an ADA bench area per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



SMYRNA PARK

2650 Fowler Road, Ceres CA

NOTE: At the time of the ADA survey assessment, the restroom building and immediate site are were under a construction contract and are not included in this assessment.

Location: Smyrna Park - Paths of Travel

Date of Assessment: April 2015

Findings: Non-accessible paths throughout the park including to picnic area, restroom and parking.to various areas within the park (excessive slopes and changes in level).

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$10,000

Priority: 3



Location: Smyrna Park - Off Street Parking

Date of Assessment: April 2015

Findings: Non-compliant ADA parking area: transition to access aisles, missing signage, van access aisle not wide enough, striping

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



SMYRNA PARK (continue)
2650 Fowler Road, Ceres CA

Location: Smyrna Park - Drinking Fountains

Date of Assessment: April 2015

Findings: Non-accessible drinking fountains.

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



Location: Smyrna Park - Play Equipment and Bench

Date of Assessment: April 2015

Findings: Non-accessible path to play equipment and bench, path should lead to ground level equipment.

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



STRAWBERRY FIELDS PARK

3200 Malik Drive, Ceres CA

Location: Strawberry Fields Park - Restroom

Date of Assessment: April 2015

Findings: Non-compliant signage, door hardware, clearance space to amenities

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$25,000

Priority: 3



STRAWBERRY FIELDS PARK (continue)

3200 Malik Drive, Ceres CA

Location: Strawberry Fields Park - Picnic Area

Date of Assessment: April 2015

Findings: Non-accessible paths to picnic areas, lack of designated ADA amenities.

Recommendation: Provide an accessible route and designate an ADA picnic area per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Strawberry Fields Park - Drinking Fountains

Date of Assessment: April 2015

Findings: Non-accessible drinking fountain (clear space, range height, pedestrian protection)

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



Location: Strawberry Fields Park - Play Equipment

Date of Assessment: April 2015

Findings: Non-accessible pathway to play equipment

Recommendation: Provide an accessible route per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



WHITMORE PARK

2921 3rd Street, Ceres CA

NOTE: At the time of the ADA survey assessment, the restroom building and immediate site were to be under a construction contract and are not included in this assessment.

Location: Whitmore Park - Picnic Area

Date of Assessment: April 2015

Findings: Non-accessible picnic tables (not along accessible route) and designated ADA picnic area

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$20,000

Priority: 3



Location: Whitmore Park - Gazebo

Date of Assessment: April 2015

Findings: Non-accessible path to gazebo (slopes, pedestrian ramp, stairway and handrails). Running slope measure 12.6%

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above

Priority: 3



WHITMORE PARK (continue)
2921 3rd Street, Ceres CA

Location: Whitmore Park - Drinking Fountains

Date of Assessment: April 2015

Findings: Non-compliant including clear floor space, height, pedestrian protection

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above
Priority: 3



Location: Whitmore Park - Path

Date of Assessment: April 2015

Findings: Non-accessible path surrounding the park (slopes, change in level, pedestrian ramp), slope in photo shows 12% to 14% cross slopes

Recommendation: Upgrade per ADAAG

Estimated Construction Cost: \$ included in above


Priority: 3



Appendix H
Curb Ramp Summary List

The City of Ceres

Curb Ramp Ranking



City of Ceres
Curb Ramp Summary List

SORTED BY INTERSECTION NAME

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1868	INT1071SE1	2ND ST & CASWELL AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1869	INT1071SW1	2ND ST & CASWELL AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
104	INT1066SW1	2ND ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
106	INT1066SE1	2ND ST & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
454	INT1065NE1	2ND ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
455	INT1065NW1	2ND ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
456	INT1065SW1	2ND ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
457	INT1065SE1	2ND ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
469	INT1064NW1	2ND ST & NORTH ST	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
470	INT1064NE1	2ND ST & NORTH ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
471	INT1064SE1	2ND ST & NORTH ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1872	INT1084SE1	3RD ST & CASWELL AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1873	INT1084SW1	3RD ST & CASWELL AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
108	INT1083SW1	3RD ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
109	INT1083SE1	3RD ST & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2375	INT1083NW1	3RD ST & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2376	INT1083NE1	3RD ST & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
510	INT1079NE1	3RD ST & EL CAMINO	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
512	INT1079NW1	3RD ST & EL CAMINO	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
450	INT1082NE1	3RD ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
451	INT1082NW1	3RD ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
452	INT1082SW1	3RD ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
453	INT1082SE1	3RD ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
474	INT1081NW1	3RD ST & NORTH ST	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
475	INT1081SE1	3RD ST & NORTH ST	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
472	INT1081SW1	3RD ST & NORTH ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
473	INT1081NE1	3RD ST & NORTH ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1870	INT1102SE1	4TH ST & CASWELL AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1871	INT1102SW1	4TH ST & CASWELL AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
111	INT1114SW1	4TH ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
112	INT1114SE1	4TH ST & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2373	INT1114NW1	4TH ST & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2374	INT1114NE1	4TH ST & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
515	INT1106NW1	4TH ST & EL CAMINO & HWY 99 (OFF RAMP) N & HWY 99 (ON RAMP) N	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
516	INT1106NE1	4TH ST & EL CAMINO & HWY 99 (OFF RAMP) N & HWY 99 (ON RAMP) N	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
501	INT1109NW1	4TH ST & LAWRENCE ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
502	INT1109SW1	4TH ST & LAWRENCE ST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
503	INT1109SE1	4TH ST & LAWRENCE ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
505	INT1109NE1	4TH ST & LAWRENCE ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
446	INT1113NE1	4TH ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	Yes	No	Telephone pole in ramp	P1	L2-a	01	\$ 5,600
447	INT1113NW1	4TH ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
448	INT1113SW1	4TH ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
449	INT1113SE1	4TH ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
477	INT1112SW2	4TH ST & NORTH ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
478	INT1112SW1	4TH ST & NORTH ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
479	INT1112NW1	4TH ST & NORTH ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
480	INT1112NW2	4TH ST & NORTH ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
482	INT1112NE1	4TH ST & NORTH ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
484	INT1112NE2	4TH ST & NORTH ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
486	INT1112SE1	4TH ST & NORTH ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
487	INT1112SE2	4TH ST & NORTH ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1857	INT1132SE1	5TH ST & ACORN LN	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1858	INT1132SW1	5TH ST & ACORN LN	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2364	INT1139NE1	5TH ST & CASWELL AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2365	INT1139NW1	5TH ST & CASWELL AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2367	INT1139SE1	5TH ST & CASWELL AVE	SE	Yes	Yes	No	Yes	No	No	No	Modification made around utility pole, 4ft	P4-a	L4	08	\$ 1,100
2366	INT1139SW1	5TH ST & CASWELL AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
113	INT1138SW1	5TH ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
114	INT1138SE1	5TH ST & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2371	INT1138NW1	5TH ST & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2372	INT1138NE1	5TH ST & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
526	INT1140NW1	5TH ST & EL CAMINO	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
528	INT1140NE1	5TH ST & EL CAMINO	NE	Yes	Yes	No	Yes	Yes	No	No		P4-a	L4	08	\$ 1,100
549	INT1142NW1	5TH ST & LAWRENCE ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
551	INT1142NW2	5TH ST & LAWRENCE ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
553	INT1142SW2	5TH ST & LAWRENCE ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
554	INT1142SW1	5TH ST & LAWRENCE ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
556	INT1142SE2	5TH ST & LAWRENCE ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
557	INT1142SE1	5TH ST & LAWRENCE ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
561	INT1142NE2	5TH ST & LAWRENCE ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
562	INT1142NE1	5TH ST & LAWRENCE ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
442	INT1137SE1	5TH ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
443	INT1137NW1	5TH ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
444	INT1137NE1	5TH ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
445	INT1137SW1	5TH ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	Yes	No	Telephone pole in ramp	P1	L2-a	01	\$ 5,600
488	INT1143NW1	5TH ST & NORTH ST	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
489	INT1143SW1	5TH ST & NORTH ST	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
492	INT1143SE1	5TH ST & NORTH ST	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
493	INT1143NE1	5TH ST & NORTH ST	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
2368	INT1141NE1	5TH ST & THOMAS AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2369	INT1141SE1	5TH ST & THOMAS AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2356	INT1174SE1	6TH ST & CASWELL AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2357	INT1174SW1	6TH ST & CASWELL AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
117	INT1170SW1	6TH ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
119	INT1171SW1	6TH ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2344	INT1170NE1	6TH ST & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2345	INT1171NE1	6TH ST & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
542	INT1160NW1	6TH ST & LAWRENCE ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
543	INT1160SW1	6TH ST & LAWRENCE ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
544	INT1160SE1	6TH ST & LAWRENCE ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
546	INT1160NE1	6TH ST & LAWRENCE ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
438	INT1164NE1	6TH ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
439	INT1164NW1	6TH ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
440	INT1164SW1	6TH ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	Yes	No		P1	L2-a	01	\$ 5,600
441	INT1164SE1	6TH ST & MAGNOLIA ST	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
2346	INT1179SE1	6TH ST & MARY AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2347	INT1179NE1	6TH ST & MARY AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
494	INT1163SW1	6TH ST & NORTH ST	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
496	INT1163NW1	6TH ST & NORTH ST	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
538	INT1161SW1	6TH ST & PARK ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
539	INT1161NE1	6TH ST & PARK ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
540	INT1161NW1	6TH ST & PARK ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
541	INT1161SE1	6TH ST & PARK ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
532	INT1162SE1	6TH ST & ROEDING RD	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
534	INT1162NE1	6TH ST & ROEDING RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2352	INT1175NE1	6TH ST & THOMAS AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2353	INT1175NW1	6TH ST & THOMAS AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2354	INT1175SW1	6TH ST & THOMAS AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2355	INT1175SE1	6TH ST & THOMAS AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
120	INT1200SW1	7TH ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
121	INT1200SE1	7TH ST & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
621	INT1195SE1	7TH ST & LAWRENCE ST	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
622	INT1195SW1	7TH ST & LAWRENCE ST	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
436	INT1199NW1	7TH ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
437	INT1199NE1	7TH ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2348	INT1202NW1	7TH ST & MARY AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2349	INT1202NE1	7TH ST & MARY AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
623	INT1192NW1	7TH ST & PARK ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
624	INT1192SW1	7TH ST & PARK ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
625	INT1192SE1	7TH ST & PARK ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
626	INT1192NE1	7TH ST & PARK ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
655	INT1193NE1	7TH ST & ROEDING RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
656	INT1193NW1	7TH ST & ROEDING RD	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2350	INT1201SE1	7TH ST & THOMAS AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2351	INT1201SW1	7TH ST & THOMAS AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
617	INT1220SE1	8TH ST & LAWRENCE ST	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
619	INT1220SW1	8TH ST & LAWRENCE ST	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
630	INT1217NE1	8TH ST & PARK ST	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
631	INT1217SW1	8TH ST & PARK ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
632	INT1217NW1	8TH ST & PARK ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
633	INT1217SE1	8TH ST & PARK ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
652	INT1213NW1	8TH ST & ROEDING RD	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
122	INT1237SW1	9TH ST & E WHITMORE AVE & MOFFETT	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
123	INT1237SE1	9TH ST & E WHITMORE AVE & MOFFETT	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2340	INT1237NW1	9TH ST & E WHITMORE AVE & MOFFETT	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2342	INT1237NE1	9TH ST & E WHITMORE AVE & MOFFETT	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
661	INT1222NW1	9TH ST & EL CAMINO	NW	Yes	Yes	No	Yes	No	No	Yes	No sidewalk north/south	P5	L4	09	
662	INT1222NE1	9TH ST & EL CAMINO	NE	Yes	Yes	No	Yes	No	No	Yes	No sidewalk north/south	P5	L4	09	
608	INT1229NW1	9TH ST & LAWRENCE ST	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
609	INT1229SW1	9TH ST & LAWRENCE ST	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
613	INT1229NE1	9TH ST & LAWRENCE ST	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
615	INT1229SE1	9TH ST & LAWRENCE ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
435	INT1231NE1	9TH ST & MAGNOLIA ST	NE	No	Yes	No	No	No	Yes	No	PO landscape comes up to back of curb	P2	L4	05	\$ 3,200
432	INT1231SE1	9TH ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
433	INT1231NW1	9TH ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
434	INT1231SW1	9TH ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
637	INT1228NW1	9TH ST & PARK ST	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
635	INT1228SW1	9TH ST & PARK ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
642	INT1226NE1	9TH ST & ROEDING RD	NE	Yes	Yes	No	No	No	Yes	No	Fire Hydrant in	P3	L4	07	\$ 5,600
640	INT1226SW1	9TH ST & ROEDING RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
639	INT1226NW1	9TH ST & ROEDING RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
641	INT1226SE1	9TH ST & ROEDING RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
600	INT1230SE1	9TH ST & STANDFORD AVE	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
601	INT1230SW1	9TH ST & STANDFORD AVE	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
604	INT1230NE1	9TH ST & STANDFORD AVE	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L2-a	09	
353	INT1277NW1	10TH ST & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
354	INT1277NE1	10TH ST & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
128	INT1287SE1	10TH ST & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
127	INT1287SW1	10TH ST & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L3	09	
351	INT1276NW1	10TH ST & HOLLY CI	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
352	INT1276SW1	10TH ST & HOLLY CI	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
347	INT1275NW1	10TH ST & HOLLY CI & VEDA DR	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
348	INT1275SW1	10TH ST & HOLLY CI & VEDA DR	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
349	INT1275SE1	10TH ST & HOLLY CI & VEDA DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
350	INT1275NE1	10TH ST & HOLLY CI & VEDA DR	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
394	INT1284SW1	10TH ST & LAWRENCE ST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
395	INT1284NW1	10TH ST & LAWRENCE ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
422	INT1286SE1	10TH ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
423	INT1286NE1	10TH ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
424	INT1286SW1	10TH ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
425	INT1286NW1	10TH ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
341	INT1279NE1	10TH ST & MELANIE CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
342	INT1279SE1	10TH ST & MELANIE CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
392	INT1283SE1	10TH ST & OASIS AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
393	INT1283NE1	10TH ST & OASIS AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
396	INT1282NE1	10TH ST & PALM AVE	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
397	INT1282SE1	10TH ST & PALM AVE	SE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
390	INT1281SE1	10TH ST & PYRAMID AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
391	INT1281NE1	10TH ST & PYRAMID AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
335	INT1280NW1	10TH ST & ROEDING RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
338	INT1280SE1	10TH ST & ROEDING RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
333	INT1280NE1	10TH ST & ROEDING RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
336	INT1280SW1	10TH ST & ROEDING RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
398	INT1285SW1	10TH ST & STANDFORD AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
400	INT1285NE1	10TH ST & STANDFORD AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
399	INT1285NW1	10TH ST & STANDFORD AVE	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
401	INT1285SE1	10TH ST & STANDFORD AVE	SE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
343	INT1278NE1	10TH ST & TRICIA CT	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
345	INT1278SE1	10TH ST & TRICIA CT	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1834	INT923SE1	AARVIG CT & AARVIG LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1836	INT923SW1	AARVIG CT & AARVIG LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1837	INT923NW1	AARVIG CT & AARVIG LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1839	INT924NW1	AARVIG CT & LAURELWOOD CT	NW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 1,100
1831	INT942SE1	AARVIG LN & CROWN VIEW DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1832	INT942SW1	AARVIG LN & CROWN VIEW DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2406	INT1030SW1	ACADEMY PL & CENTRAL AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2407	INT1030NW1	ACADEMY PL & CENTRAL AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2408	INT1030NE1	ACADEMY PL & CENTRAL AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1550	INT1238NE1	ACORN LN & FOWLER RD & MOFFETT RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1551	INT1238NW1	ACORN LN & FOWLER RD & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1552	INT1238SE1	ACORN LN & FOWLER RD & MOFFETT RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1553	INT1238SW1	ACORN LN & FOWLER RD & MOFFETT RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1859	INT1099SE1	ACORN LN & MYRTLEWOOD DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1860	INT1099NE1	ACORN LN & MYRTLEWOOD DR	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1856	INT1197NW1	ACORN LN & WALLACE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1853	INT1197NE1	ACORN LN & WALLACE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1854	INT1197SE1	ACORN LN & WALLACE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1855	INT1197SW1	ACORN LN & WALLACE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2275	INT1428SE1	ADRIEN WY & ANGIE AVE	SE	No	Yes	No	No	No	No	No		P2	L5	05	\$ 3,200
2276	INT1428NE1	ADRIEN WY & ANGIE AVE	NE	No	Yes	No	No	No	No	No		P2	L5	05	\$ 3,200
2279	INT1461NW1	ADRIEN WY & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2280	INT1461SW1	ADRIEN WY & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1019	INT569NE1	AGRESTI DR & DANIEL WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1005	INT567SE1	AGRESTI DR & KINSER RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1007	INT567SW1	AGRESTI DR & KINSER RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1014	INT568NW1	AGRESTI DR & TOMBA DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1016	INT568SE1	AGRESTI DR & TOMBA DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1017	INT568NE1	AGRESTI DR & TOMBA DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1149	INT344SE1	ALCOY DR & PARIS WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1150	INT344SW1	ALCOY DR & PARIS WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1151	INT344NE1	ALCOY DR & PARIS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1159	INT412NW1	ALCOY DR & POMPEII LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1160	INT412SW1	ALCOY DR & POMPEII LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1161	INT412SE1	ALCOY DR & POMPEII LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1156	INT385SE1	ALCOY DR & PORTUGAL DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1157	INT385NE1	ALCOY DR & PORTUGAL DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1158	INT385NW1	ALCOY DR & PORTUGAL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1310	INT442NE1	ALEXIS AVE & ALONDRA DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1312	INT442SE1	ALEXIS AVE & ALONDRA DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1313	INT442NW1	ALEXIS AVE & ALONDRA DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1305	INT444SE1	ALEXIS AVE & BRIA DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1306	INT444NE1	ALEXIS AVE & BRIA DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1307	INT443NE1	ALEXIS AVE & EDITH CT	NE	Yes	Yes	No	Yes	No	No	No	DWS size out of	P4-a	L4	08	\$ 1,100
1308	INT443SE1	ALEXIS AVE & EDITH CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1309	INT443NW1	ALEXIS AVE & EDITH CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1144	INT376NW1	ALLACANTE DR & MARSHFIELD LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1145	INT376SW1	ALLACANTE DR & MARSHFIELD LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1146	INT376SE1	ALLACANTE DR & MARSHFIELD LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1147	INT342NE1	ALLACANTE DR & PARIS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1148	INT342NW1	ALLACANTE DR & PARIS WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1162	INT411NE1	ALLACANTE DR & POMPEII LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1163	INT411NW1	ALLACANTE DR & POMPEII LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1164	INT411SE1	ALLACANTE DR & POMPEII LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1124	INT428SW1	ALLACANTE DR & VALLEY BROOK DR	SW	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1516	INT731SW1	ALMOND GROVE LN & DAISY TREE LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1517	INT731NW1	ALMOND GROVE LN & DAISY TREE LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1518	INT731SE1	ALMOND GROVE LN & DAISY TREE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1520	INT730NW1	ALMOND GROVE LN & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1521	INT730SW1	ALMOND GROVE LN & DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1522	INT730NE1	ALMOND GROVE LN & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1315	INT481SW1	ALONDRA DR & DESIREE CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1316	INT481SE1	ALONDRA DR & DESIREE CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1317	INT481NE1	ALONDRA DR & DESIREE CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1707	INT1426SE1	ALPHONSE DR & JOSEPH LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1708	INT1426SW1	ALPHONSE DR & JOSEPH LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1715	INT1377SE1	ALPHONSE DR & LORETTA LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1716	INT1377SW1	ALPHONSE DR & LORETTA LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1701	INT1459SW1	ALPHONSE DR & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1704	INT1459NW1	ALPHONSE DR & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1717	INT1355SE1	ALPHONSE DR & MOLLY LN	SE	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1712	INT1405SE1	ALPHONSE DR & RITA LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1714	INT1405SW1	ALPHONSE DR & RITA LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1705	INT1438SW1	ALPHONSE DR & VINELAND LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1706	INT1438SE1	ALPHONSE DR & VINELAND LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1127	INT416NW1	ALPINE SPRING CT & VALLEY BROOK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1128	INT416SW1	ALPINE SPRING CT & VALLEY BROOK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1284	INT1536NW1	ALPS CT & TIRANO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1286	INT1536SW1	ALPS CT & TIRANO WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
223	INT1671SW1	ALTESSA LN & BELLA FLORA DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
226	INT1671NW1	ALTESSA LN & BELLA FLORA DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
228	INT1671NE1	ALTESSA LN & BELLA FLORA DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
252	INT1673NE1	ALTESSA LN & EAU CLAIRE AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
253	INT1673SE1	ALTESSA LN & EAU CLAIRE AVE	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
254	INT1673SW1	ALTESSA LN & EAU CLAIRE AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
248	INT1672NW1	ALTESSA LN & HELEN PERRY RD	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
249	INT1672NE1	ALTESSA LN & HELEN PERRY RD	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
250	INT1672SW1	ALTESSA LN & HELEN PERRY RD	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
251	INT1672SE1	ALTESSA LN & HELEN PERRY RD	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2076	INT699NE1	ALWAY DR & CULLEN AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2077	INT699NW1	ALWAY DR & CULLEN AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2083	INT701SE1	ALWAY DR & LUCCHESI LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2084	INT701SW1	ALWAY DR & LUCCHESI LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
874	INT564SE1	AMANDA DR & CASSIE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
864	INT647SW1	AMANDA DR & GEORGEANN PL	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
865	INT647NW1	AMANDA DR & GEORGEANN PL	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
866	INT647SE1	AMANDA DR & GEORGEANN PL	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
869	INT606SE1	AMANDA DR & JORDANOLO DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
870	INT606SW1	AMANDA DR & JORDANOLO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
871	INT606NE1	AMANDA DR & JORDANOLO DR	NE	Yes	Yes	Yes	Yes	No	No	No		P4-a	L4	08	\$ 3,200
1214	INT396NW1	AMANECER DR & MALIK AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1215	INT396SW1	AMANECER DR & MALIK AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
136	INT1682NE1	AMBER LEAF LN & NORTHERN OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
137	INT1682SE1	AMBER LEAF LN & NORTHERN OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
138	INT1682SW1	AMBER LEAF LN & NORTHERN OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
69	INT1681NW1	AMBER LEAF LN & WILD OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
71	INT1681NE1	AMBER LEAF LN & WILD OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1076	INT679NE1	AMBLESIDE CT & AMBLESIDE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1077	INT679SE1	AMBLESIDE CT & AMBLESIDE WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1079	INT679SW1	AMBLESIDE CT & AMBLESIDE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1080	INT678NE1	AMBLESIDE WY & CAULFIELD DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1082	INT678NW1	AMBLESIDE WY & CAULFIELD DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
991	INT676NW1	AMBLESIDE WY & KINSER RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
992	INT676SE1	AMBLESIDE WY & KINSER RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
993	INT676SW1	AMBLESIDE WY & KINSER RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1469	INT591SW1	ANGEL LN & SERENE LN	SW	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1470	INT596NW1	ANGEL LN & TRANQUIL LN	NW	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2281	INT1427NW1	ANGIE AVE & E HATCH RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2282	INT1427NE1	ANGIE AVE & E HATCH RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
236	INT1686SE1	ANNIGONI CT & TARAMEA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
238	INT1686SW1	ANNIGONI CT & TARAMEA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
239	INT1686NE1	ANNIGONI CT & TARAMEA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2301	INT601SE1	ANTELOPE LN & NADINE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2302	INT601SW1	ANTELOPE LN & NADINE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2292	INT600NW1	ANTELOPE LN & TYRUS ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2293	INT600NE1	ANTELOPE LN & TYRUS ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2294	INT600SE1	ANTELOPE LN & TYRUS ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2299	INT581NE1	APPLETON WY & BLUEJAY WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2300	INT581SW1	APPLETON WY & BLUEJAY WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2287	INT582SW1	APPLETON WY & EUGENE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2288	INT582NW1	APPLETON WY & EUGENE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2289	INT582NE1	APPLETON WY & EUGENE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2290	INT583SE1	APPLETON WY & TYRUS ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2291	INT583NE1	APPLETON WY & TYRUS ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
255	INT1417NE1	ARCHCLIFFE DR & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
259	INT1417NW1	ARCHCLIFFE DR & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
256	INT1418SW1	ARCHCLIFFE DR & KING HENRY CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
257	INT1418NW1	ARCHCLIFFE DR & KING HENRY CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
258	INT1418NE1	ARCHCLIFFE DR & KING HENRY CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
197	INT1657SE1	ARIANO LN & BELLA FLORA DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
198	INT1657SW1	ARIANO LN & BELLA FLORA DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
199	INT1657NW1	ARIANO LN & BELLA FLORA DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
193	INT1656NE1	ARIANO LN & BELLEZA CT & BELLEZA DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
194	INT1656NW1	ARIANO LN & BELLEZA CT & BELLEZA DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
195	INT1656SW1	ARIANO LN & BELLEZA CT & BELLEZA DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
196	INT1656SE1	ARIANO LN & BELLEZA CT & BELLEZA DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
173	INT1655NE1	ARIANO LN & MIRA SOL DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
174	INT1655NW1	ARIANO LN & MIRA SOL DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
175	INT1655SE1	ARIANO LN & MIRA SOL DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
176	INT1655SW1	ARIANO LN & MIRA SOL DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
148	INT1654NE1	ARIANO LN & NORTHERN OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
149	INT1654SE1	ARIANO LN & NORTHERN OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
150	INT1654SW1	ARIANO LN & NORTHERN OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
153	INT1654NW1	ARIANO LN & NORTHERN OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
94	INT1651NE1	ARIANO LN & OLD OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
97	INT1651NW1	ARIANO LN & OLD OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
98	INT1651SE1	ARIANO LN & OLD OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
115	INT1653NW1	ARIANO LN & STANDING OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
116	INT1653SW1	ARIANO LN & STANDING OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
124	INT1653SE1	ARIANO LN & STANDING OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
47	INT1652SW1	ARIANO LN & WILD OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
50	INT1652SE1	ARIANO LN & WILD OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
53	INT1652NE1	ARIANO LN & WILD OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
55	INT1652NW1	ARIANO LN & WILD OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1117	INT453SE1	ARISTOCRAT DR & MALIK AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1118	INT453NE1	ARISTOCRAT DR & MALIK AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1119	INT453NW1	ARISTOCRAT DR & MALIK AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1120	INT453SW1	ARISTOCRAT DR & MALIK AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1090	INT542NE1	ARISTOCRAT DR & MORGAN RD	NE	No	Yes	No	No	No	No	No	crosswalk area	P2	L4	05	\$ 3,200
1086	INT542NW1	ARISTOCRAT DR & MORGAN RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1087	INT542SW1	ARISTOCRAT DR & MORGAN RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1095	INT515NE1	ARISTOCRAT DR & POINT GREY RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1096	INT515SE1	ARISTOCRAT DR & POINT GREY RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1097	INT515SW1	ARISTOCRAT DR & POINT GREY RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1092	INT526SE1	ARISTOCRAT DR & SARIYA WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1094	INT526SW1	ARISTOCRAT DR & SARIYA WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1103	INT500NW1	ARISTOCRAT DR & STARBOARD WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1104	INT500SW1	ARISTOCRAT DR & STARBOARD WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1105	INT500SE1	ARISTOCRAT DR & STARBOARD WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1106	INT500NE1	ARISTOCRAT DR & STARBOARD WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1121	INT427SE1	ARISTOCRAT DR & VALLEY BROOK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1122	INT427NE1	ARISTOCRAT DR & VALLEY BROOK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1123	INT427SW1	ARISTOCRAT DR & VALLEY BROOK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
646	INT1622NW1	ARMANDO CT & YOLANDA ST	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
649	INT1622NE1	ARMANDO CT & YOLANDA ST	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
650	INT1622SE1	ARMANDO CT & YOLANDA ST	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
2526	INT915SE1	ARTHUR WY & HOLLISTER ST	SE	No	No	No	No	No	No	No	Private Road	P4-a	L4	08	
2488	INT841NW1	ASHBURY CT & EVANS RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2489	INT841NE1	ASHBURY CT & EVANS RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
782	INT726NW1	ASHUR AVE & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
784	INT726NE1	ASHUR AVE & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No	Large amount of veg in	P4-a	L4	08	\$ 1,100
785	INT727SE1	ASHUR AVE & ISAIAH CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
786	INT727NE1	ASHUR AVE & ISAIAH CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
787	INT727NW1	ASHUR AVE & ISAIAH CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
765	INT728SE1	ASHUR AVE & POSHO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
766	INT728SW1	ASHUR AVE & POSHO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
767	INT728NW1	ASHUR AVE & POSHO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1411	INT1412SE1	ASTER CT & LOUISE AVE	SE	No	No	No	No	No	No	No	No sidewalks, ramps not	P4-a	L4	08	
1412	INT1412NE1	ASTER CT & LOUISE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1111	INT473NE1	ASTORIA CT & HIGHLANDS PARK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1112	INT473NW1	ASTORIA CT & HIGHLANDS PARK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
384	INT1297SE1	ASTRO DR & EVALEE LN	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
385	INT1297NE1	ASTRO DR & EVALEE LN	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
779	INT1594NW1	ATTIKA ST & MONTEREY PINE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
780	INT1594SW1	ATTIKA ST & MONTEREY PINE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
781	INT1594NE1	ATTIKA ST & MONTEREY PINE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
783	INT1594SE1	ATTIKA ST & MONTEREY PINE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
795	INT1635NE1	ATTIKA ST & MORELLO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
797	INT1635NW1	ATTIKA ST & MORELLO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
882	INT1568NW1	ATTIKA ST & VANDALAY DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
883	INT1568NE1	ATTIKA ST & VANDALAY DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2108	INT1125NW1	AUTUMN GROVE LN & MILLCREEK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2109	INT1125NE1	AUTUMN GROVE LN & MILLCREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2110	INT1125SE1	AUTUMN GROVE LN & MILLCREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2124	INT1126SE1	AUTUMN GROVE LN & SHADOWBROOK	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2125	INT1126SW1	AUTUMN GROVE LN & SHADOWBROOK	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2126	INT1126NW1	AUTUMN GROVE LN & SHADOWBROOK	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1134	INT373NE1	AVENIDA REAL & CAMINO DEL REY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1135	INT373SE1	AVENIDA REAL & CAMINO DEL REY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1136	INT373SW1	AVENIDA REAL & CAMINO DEL REY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1137	INT339NE1	AVENIDA REAL & KIMBALL HILL DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1138	INT339NW1	AVENIDA REAL & KIMBALL HILL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1133	INT407NW1	AVENIDA REAL & VALLEY BROOK DR	NW	Yes	Yes	No	Yes	No	No	No	ramp is part of	P4-a	L4	08	\$ 1,100
327	INT1334NW1	AVERY CT & EAST LN	NW	Yes	No	No	Yes	No	No	No		P4-a	L2-b	04	\$ 3,200
1413	INT1413SE1	AZALEA CT & LOUISE AVE	SE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1414	INT1413NE1	AZALEA CT & LOUISE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1152	INT347SE1	AZORES LN & PARIS WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1153	INT347NE1	AZORES LN & PARIS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1154	INT386SW1	AZORES LN & PORTUGAL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1155	INT386NW1	AZORES LN & PORTUGAL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1814	INT1075SE1	BANYAN CT & HALE ALOHA WY	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1815	INT1075SW1	BANYAN CT & HALE ALOHA WY	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
274	INT1384NW1	BARRY CT & ROEDING RD	NW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
275	INT1384NE1	BARRY CT & ROEDING RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
643	INT1621SE1	BASSETTI CT & YOLANDA ST	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
644	INT1621NE1	BASSETTI CT & YOLANDA ST	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
645	INT1621NW1	BASSETTI CT & YOLANDA ST	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
1615	INT946NE1	BAVIL DR & GAZA LN	NE	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 3,200
1613	INT1001NW1	BAVIL DR & URM I AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2425	INT836NE1	BAXTER WY & RICHARD WY	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
2424	INT836NW1	BAXTER WY & RICHARD WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2426	INT837SW1	BAXTER WY & ZONA BELLA LN	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1862	INT1061SE1	BEACHWOOD DR & GLENWOOD DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1863	INT1061NE1	BEACHWOOD DR & GLENWOOD DR	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
699	INT1572NE1	BEECH WY & FIR LN	NE	Yes	Yes	No	Yes	No	No	No	Ramp crosses to	P4-a	L4	08	\$ 1,100
697	INT1588NW1	BEECH WY & MONTEREY PINE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
698	INT1588SW1	BEECH WY & MONTEREY PINE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
230	INT1688NE1	BELLA FLORA CT & BELLA FLORA DR & TARAMEA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
231	INT1688NW1	BELLA FLORA CT & BELLA FLORA DR & TARAMEA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
233	INT1688SE1	BELLA FLORA CT & BELLA FLORA DR & TARAMEA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
234	INT1688SW1	BELLA FLORA CT & BELLA FLORA DR & TARAMEA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
212	INT1636NW1	BELLA FLORA DR & EASTGATE BLV	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
213	INT1636NE1	BELLA FLORA DR & EASTGATE BLV	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
216	INT1636SE1	BELLA FLORA DR & EASTGATE BLV	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
219	INT1660NW1	BELLA FLORA DR & TOSCANA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
220	INT1660NE1	BELLA FLORA DR & TOSCANA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
222	INT1660SE1	BELLA FLORA DR & TOSCANA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
189	INT1689NE1	BELLEZA DR & TARAMEA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
190	INT1689NW1	BELLEZA DR & TARAMEA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
191	INT1689SW1	BELLEZA DR & TARAMEA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
192	INT1697SE1	BELLEZA DR & TRAVESIA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2610	INT1697SW1	BELLEZA DR & TRAVESIA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2471	MID1715NE1	BELMONT AVE	NE	No	No	No	No	No	No	No		P4-a	L4	08	
2470	INT631SW1	BELMONT AVE & GRAND VIEW AVE	SW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2469	INT631SE1	BELMONT AVE & GRAND VIEW AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2467	INT688SW1	BELMONT AVE & PARAMOUNT AVE	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2468	INT688NW1	BELMONT AVE & PARAMOUNT AVE	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
720	INT851SW1	BELVA CT & BURTON DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
721	INT851NW1	BELVA CT & BURTON DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1264	INT1509NW1	BERN CT & RHONE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1269	INT1509NE1	BERN CT & RHONE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2429	INT840NW1	BERNICE DR & DARBY LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2430	INT840SE1	BERNICE DR & DARBY LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2431	INT840NE1	BERNICE DR & DARBY LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2448	INT839NE1	BERNICE DR & JOEL WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2449	INT839SE1	BERNICE DR & JOEL WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1168	INT353NE1	BIG CREEK LN & CASTLEROCK CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1169	INT353NW1	BIG CREEK LN & CASTLEROCK CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1165	INT370NE1	BIG CREEK LN & CEDAR SPRINGS CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1166	INT370NW1	BIG CREEK LN & CEDAR SPRINGS CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1167	INT370SE1	BIG CREEK LN & CEDAR SPRINGS CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1139	INT340SE1	BIG CREEK LN & KIMBALL HILL DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1140	INT340NE1	BIG CREEK LN & KIMBALL HILL DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1170	INT430NW1	BIG CREEK LN & MALIK AVE	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1171	INT430SW1	BIG CREEK LN & MALIK AVE	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1172	INT430NE1	BIG CREEK LN & MALIK AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1129	INT409NW1	BIG CREEK LN & VALLEY BROOK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1130	INT409SW1	BIG CREEK LN & VALLEY BROOK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1131	INT409SE1	BIG CREEK LN & VALLEY BROOK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1132	INT409NE1	BIG CREEK LN & VALLEY BROOK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
873	INT1576SW1	BIGAROON CT & SKEENA AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
875	INT1576NW1	BIGAROON CT & SKEENA AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
876	INT1576NE1	BIGAROON CT & SKEENA AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
867	INT1577NE1	BIGAROON CT & VALERA DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
868	INT1577SE1	BIGAROON CT & VALERA DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
872	INT1577NW1	BIGAROON CT & VALERA DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1432	INT379SW1	BILLY CT & DEL SOL DR & HOLLOWELL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1433	INT379NW1	BILLY CT & DEL SOL DR & HOLLOWELL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1435	INT379SE1	BILLY CT & DEL SOL DR & HOLLOWELL DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1428	INT378SE1	BILLY CT & SEBASTIAN WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1429	INT378NE1	BILLY CT & SEBASTIAN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1430	INT378NW1	BILLY CT & SEBASTIAN WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1536	INT825SW1	BING LN & DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1537	INT825SE1	BING LN & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1538	INT825NE1	BING LN & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1599	INT826NE1	BING LN & TARTARIAN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1600	INT826SW1	BING LN & TARTARIAN WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
794	INT790SW1	BLAKER RD & CANCEMILLA CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
796	INT790NW1	BLAKER RD & CANCEMILLA CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1533	INT796SE1	BLAKER RD & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1535	INT796NE1	BLAKER RD & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1529	INT795NW1	BLAKER RD & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1530	INT795SW1	BLAKER RD & DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1531	INT795SE1	BLAKER RD & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
735	INT785SE1	BLAKER RD & DOYLE AVE & FLOWER GARDEN CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
736	INT785SW1	BLAKER RD & DOYLE AVE & FLOWER GARDEN CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
737	INT785NW1	BLAKER RD & DOYLE AVE & FLOWER GARDEN CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
738	INT785NE1	BLAKER RD & DOYLE AVE & FLOWER GARDEN CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1682	INT782NW1	BLAKER RD & E SERVICE RD	NW	Yes	Yes	No	Yes	No	No	Yes	Only able to cross to NEC	P5	L4	09	
1684	INT782NE1	BLAKER RD & E SERVICE RD	NE	Yes	Yes	No	Yes	No	No	Yes	Ramp leads to infill at	P5	L4	09	
81	INT804SW1	BLAKER RD & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
82	INT804SE1	BLAKER RD & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
790	INT803SW1	BLAKER RD & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
791	INT803SE1	BLAKER RD & HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
792	INT803NE1	BLAKER RD & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
793	INT803NW1	BLAKER RD & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
950	INT802SE1	BLAKER RD & HEAVENLY WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
951	INT802NE1	BLAKER RD & HEAVENLY WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
758	INT792SW1	BLAKER RD & HUGO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
759	INT792NW1	BLAKER RD & HUGO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
972	INT797SE1	BLAKER RD & KINSER RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
973	INT797SW1	BLAKER RD & KINSER RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
974	INT797NW1	BLAKER RD & KINSER RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
975	INT797NE1	BLAKER RD & KINSER RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
809	INT799SE1	BLAKER RD & MARAZZI LN	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
810	INT799SW1	BLAKER RD & MARAZZI LN	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
811	INT799NW1	BLAKER RD & MARAZZI LN	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
741	INT788SW1	BLAKER RD & PINK AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
743	INT788NW1	BLAKER RD & PINK AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1659	INT789NE1	BLAKER RD & SOUTHWOOD DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1660	INT789SE1	BLAKER RD & SOUTHWOOD DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1662	INT789NW1	BLAKER RD & SOUTHWOOD DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1663	INT789SW1	BLAKER RD & SOUTHWOOD DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
812	INT798SW1	BLAKER RD & SUNGATE DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
813	INT798SE1	BLAKER RD & SUNGATE DR	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
814	INT798NW1	BLAKER RD & SUNGATE DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
807	INT800SE1	BLAKER RD & WALNUT AVE	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
808	INT800NE1	BLAKER RD & WALNUT AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1356	INT398SE1	BLUE FALLS CT & ROCKY BROOK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1357	INT398SW1	BLUE FALLS CT & ROCKY BROOK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1358	INT398NW1	BLUE FALLS CT & ROCKY BROOK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
319	INT1683NW1	BLUE LN & HYACINTH DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
322	INT1683SW1	BLUE LN & HYACINTH DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
323	INT1683NE1	BLUE LN & HYACINTH DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
326	INT1683SE1	BLUE LN & HYACINTH DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
328	INT1684SW1	BLUE LN & KIWI DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
329	INT1684SE1	BLUE LN & KIWI DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
300	INT1685SW1	BLUE LN & PODOCARPUS DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
304	INT1685NW1	BLUE LN & PODOCARPUS DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
307	INT1685NE1	BLUE LN & PODOCARPUS DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1262	INT467NW1	BLUE MOON CT & TWILIGHT DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1263	INT467NE1	BLUE MOON CT & TWILIGHT DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1265	INT467SE1	BLUE MOON CT & TWILIGHT DR	SE	Yes	Yes	Yes	Yes	No	No	No		P4-a	L4	08	\$ 3,200
1519	INT1397SW1	BLUEBIRD DR & CARDINAL DR	SW	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 3,200
1509	INT1345NW1	BLUEBIRD DR & ROSE AVE	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1510	INT1345NE1	BLUEBIRD DR & ROSE AVE	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1512	INT1345SE1	BLUEBIRD DR & ROSE AVE	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
2297	INT627NW1	BLUEJAY WY & ROLLS ROYCE LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2298	INT627NE1	BLUEJAY WY & ROLLS ROYCE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1899	INT926NW1	BLUERIDGE CT & STONUM RD & WANN CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1900	INT926NE1	BLUERIDGE CT & STONUM RD & WANN CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1901	INT926SW1	BLUERIDGE CT & STONUM RD & WANN CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1902	INT926SE1	BLUERIDGE CT & STONUM RD & WANN CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2565	INT1559SW1	BOOTHE RD & E HATCH RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
2566	INT1559SE1	BOOTHE RD & E HATCH RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
2547	INT1548NW1	BOOTHE RD & E WHITMORE AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2548	INT1548NE1	BOOTHE RD & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
669	INT1553NE1	BOOTHE RD & FOWLER RD & HELEN	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
670	INT1553SE1	BOOTHE RD & FOWLER RD & HELEN	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
671	INT1553NW1	BOOTHE RD & FOWLER RD & HELEN	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
673	INT1553SW1	BOOTHE RD & FOWLER RD & HELEN	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
582	INT1551SW1	BOOTHE RD & MOONVIEW DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
583	INT1551NW1	BOOTHE RD & MOONVIEW DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1200	INT1554NW1	BOOTHE RD & PRIMROSE LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1204	INT1554SW1	BOOTHE RD & PRIMROSE LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
916	INT1557NW1	BOOTHE RD & RHONE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
917	INT1557SW1	BOOTHE RD & RHONE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
903	INT1558NW1	BOOTHE RD & SKEENA AVE & ZURICH LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
905	INT1558NE1	BOOTHE RD & SKEENA AVE & ZURICH LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
906	INT1558SW1	BOOTHE RD & SKEENA AVE & ZURICH LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
910	INT1558SE1	BOOTHE RD & SKEENA AVE & ZURICH LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
920	INT1556NW1	BOOTHE RD & SUFFOLK DR	NW	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
933	INT1556SW1	BOOTHE RD & SUFFOLK DR	SW	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
580	INT1550NE1	BOOTHE RD & VALLEY OAK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
581	INT1550SE1	BOOTHE RD & VALLEY OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
945	INT1549NW1	BOOTHE RD & VERA WY	NW	Yes	Yes	No	Yes	Yes	No	No		P4-a	L4	08	\$ 1,100
946	INT1549SW1	BOOTHE RD & VERA WY	SW	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
677	INT1555NW1	BOOTHE RD & WAYNESBORO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
679	INT1555SW1	BOOTHE RD & WAYNESBORO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
681	INT1555NE1	BOOTHE RD & WAYNESBORO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
682	INT1555SE1	BOOTHE RD & WAYNESBORO DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
584	INT1552NE1	BOOTHE RD & WHITEHAVEN AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
585	INT1552SE1	BOOTHE RD & WHITEHAVEN AVE	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1926	INT873SE1	BORDEAUX DR & COLUMBARD WY	SE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1924	INT872SE1	BORDEAUX DR & MERLOT DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1925	INT872NE1	BORDEAUX DR & MERLOT DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1920	INT870SE1	BORDEAUX DR & MOET WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1921	INT870NE1	BORDEAUX DR & MOET WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1919	INT869SW1	BORDEAUX DR & NADINE AVE	SW	No	Yes	No	No	No	No	No	School Crosswalk	P2	L2-b	02	\$ 3,200
1917	INT869NE1	BORDEAUX DR & NADINE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1918	INT869NW1	BORDEAUX DR & NADINE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1922	INT871SE1	BORDEAUX DR & SAUVIGNON DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1923	INT871NE1	BORDEAUX DR & SAUVIGNON DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
481	INT1696NW1	BOUGAINVILLEA DR & DUSTY MILLER LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
483	INT1696SW1	BOUGAINVILLEA DR & DUSTY MILLER LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
485	INT1696SE1	BOUGAINVILLEA DR & DUSTY MILLER LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
365	INT1665NW1	BOUGAINVILLEA DR & FIDDLELEAF LN	NW	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
367	INT1665NE1	BOUGAINVILLEA DR & FIDDLELEAF LN	NE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
370	INT1665SE1	BOUGAINVILLEA DR & FIDDLELEAF LN	SE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
373	INT1678SW1	BOUGAINVILLEA DR & MANDEVILLA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
375	INT1678SE1	BOUGAINVILLEA DR & MANDEVILLA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
377	INT1691SW1	BOUGAINVILLEA DR & WATER LILY LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
381	INT1691SE1	BOUGAINVILLEA DR & WATER LILY LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
476	INT1691NW1	BOUGAINVILLEA DR & WATER LILY LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1380	INT489SW1	BOULDER FALLS CT & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1381	INT489NW1	BOULDER FALLS CT & SAN PEDRO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1383	INT489NE1	BOULDER FALLS CT & SAN PEDRO AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1448	INT266SE1	BOYLE DR & E SERVICE RD	SE	Yes	No	No	Yes	No	No	No	No other ramps in this	P1	L2-a	01	\$ 3,200
1718	INT382SE1	BREW MASTER DR & FARM SUPPLY DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1719	INT382NE1	BREW MASTER DR & FARM SUPPLY DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1711	INT438NW1	BREW MASTER DR & PARTEE LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1713	INT438NE1	BREW MASTER DR & PARTEE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1301	INT474NE1	BRIA DR & ESTEBAN AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1302	INT474NW1	BRIA DR & ESTEBAN AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1304	INT474SW1	BRIA DR & ESTEBAN AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
389	INT1311NE1	BRICKIT CT & EL CAMINO	NE	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
388	INT1311SE1	BRICKIT CT & EL CAMINO	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2016	INT1005SW1	BRIDGET MARIE DR & EHLERS DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2017	INT1005NW1	BRIDGET MARIE DR & EHLERS DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2014	INT997SW1	BRIDGET MARIE DR & GRAND CENTRAL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2015	INT997SE1	BRIDGET MARIE DR & GRAND CENTRAL DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2432	INT864NE1	BRIDGEWATER DR & DARBY LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2433	INT864NW1	BRIDGEWATER DR & DARBY LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2434	INT864SE1	BRIDGEWATER DR & DARBY LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2436	INT864SW1	BRIDGEWATER DR & DARBY LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2447	INT863SW1	BRIDGEWATER DR & JOEL WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2435	INT865NW1	BRIDGEWATER DR & RON CT	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2490	INT867NW1	BROOKINGS CT & EVANS RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2491	INT867NE1	BROOKINGS CT & EVANS RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1321	INT405NE1	BROWN AVE & CAMBRIDGE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1322	INT405SE1	BROWN AVE & CAMBRIDGE WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1323	INT405SW1	BROWN AVE & CAMBRIDGE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1351	INT421NW1	BROWN AVE & E SERVICE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1352	INT421NE1	BROWN AVE & E SERVICE RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1354	INT421SE1	BROWN AVE & E SERVICE RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1179	INT406SE1	BROWN AVE & HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1180	INT406SW1	BROWN AVE & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1331	INT400NW1	BROWN AVE & MOON RIVER WY	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1333	INT400NE1	BROWN AVE & MOON RIVER WY	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1334	INT400SE1	BROWN AVE & MOON RIVER WY	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1346	INT422NW1	BROWN AVE & ROCKY BROOK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1347	INT422SW1	BROWN AVE & ROCKY BROOK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1349	INT422SE1	BROWN AVE & ROCKY BROOK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1328	INT403NE1	BROWN AVE & SAN PEDRO AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1329	INT403SE1	BROWN AVE & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1330	INT403SW1	BROWN AVE & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1324	INT404NW1	BROWN AVE & SEBASTIAN WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1325	INT404SW1	BROWN AVE & SEBASTIAN WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1326	INT404SE1	BROWN AVE & SEBASTIAN WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1327	INT404NE1	BROWN AVE & SEBASTIAN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1336	INT402NW1	BROWN AVE & STONE SPRINGS CT & STONE SPRINGS DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1337	INT402SW1	BROWN AVE & STONE SPRINGS CT & STONE SPRINGS DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1338	INT402SE1	BROWN AVE & STONE SPRINGS CT & STONE SPRINGS DR	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1339	INT402NE1	BROWN AVE & STONE SPRINGS CT & STONE SPRINGS DR	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1340	INT413NW1	BROWN AVE & TRANQUIL LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1342	INT413SW1	BROWN AVE & TRANQUIL LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1343	INT413SE1	BROWN AVE & TRANQUIL LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1345	INT413NE1	BROWN AVE & TRANQUIL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1513	INT704SW1	BUCKTHORN LN & DAISY TREE LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1514	INT704SE1	BUCKTHORN LN & DAISY TREE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1515	INT704NE1	BUCKTHORN LN & DAISY TREE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1498	INT703NE1	BUCKTHORN LN & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1499	INT703NW1	BUCKTHORN LN & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1501	INT703SW1	BUCKTHORN LN & DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1195	INT358NE1	BUENAVENTURA DR & DEL SOL CT & DEL SOL DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1196	INT358SE1	BUENAVENTURA DR & DEL SOL CT & DEL SOL DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1197	INT358SW1	BUENAVENTURA DR & DEL SOL CT & DEL SOL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1198	INT358NW1	BUENAVENTURA DR & DEL SOL CT & DEL SOL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1185	INT360SE1	BUENAVENTURA DR & HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1186	INT360SW1	BUENAVENTURA DR & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1205	INT356NW1	BUENAVENTURA DR & MADRID CT	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1206	INT356SW1	BUENAVENTURA DR & MADRID CT	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1207	INT356NE1	BUENAVENTURA DR & MADRID CT	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1201	INT357NW1	BUENAVENTURA DR & SALAMANCA CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1202	INT357SW1	BUENAVENTURA DR & SALAMANCA CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1203	INT357NE1	BUENAVENTURA DR & SALAMANCA CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1211	INT354NE1	BUENAVENTURA DR & STONE SPRINGS DR	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1212	INT354NW1	BUENAVENTURA DR & STONE SPRINGS DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1213	INT354SW1	BUENAVENTURA DR & STONE SPRINGS DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1190	INT359NW1	BUENAVENTURA DR & TULAROSA CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1192	INT359SW1	BUENAVENTURA DR & TULAROSA CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1193	INT359NE1	BUENAVENTURA DR & TULAROSA CT	NE	Yes	Yes	Yes	Yes	No	No	No		P4-a	L4	08	\$ 3,200
1208	INT355NW1	BUENAVENTURA DR & WINDING BROOK	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1209	INT355SW1	BUENAVENTURA DR & WINDING BROOK	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1210	INT355NE1	BUENAVENTURA DR & WINDING BROOK	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2048	INT987SE1	BURGUNDY LN & CENTRAL PARK WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2049	INT987SW1	BURGUNDY LN & CENTRAL PARK WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1931	INT982NW1	BURGUNDY LN & COLUMBARD WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1932	INT982SE1	BURGUNDY LN & COLUMBARD WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
734	INT857SW1	BURTON DR & DOYLE AVE	SW	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 3,200
728	INT853SE1	BURTON DR & HACKETT RD	SE	No	Yes	No	No	No	No	No	No sidewalk	P2	L4	05	\$ 3,200
722	INT853SW1	BURTON DR & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
723	INT853NW1	BURTON DR & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
725	INT853NE1	BURTON DR & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
731	INT856SW1	BURTON DR & MELBA CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
732	INT856NW1	BURTON DR & MELBA CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
733	INT856SE1	BURTON DR & MELBA CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
708	INT845SE1	BURTON DR & WALNUT AVE	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
710	INT845NE1	BURTON DR & WALNUT AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
712	INT846SW1	BURTON DR & WALNUT AVE	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
713	INT846NE1	BURTON DR & WALNUT AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
714	INT846NW1	BURTON DR & WALNUT AVE	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
716	INT849SW1	BURTON DR & WHITECLOUD CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
719	INT849NW1	BURTON DR & WHITECLOUD CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2005	INT980SW1	BUTCHER AVE & CATHEDRAL LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2006	INT980NE1	BUTCHER AVE & CATHEDRAL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2007	INT980SE1	BUTCHER AVE & CATHEDRAL LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2011	INT996NW1	BUTCHER AVE & GRAND CENTRAL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2012	INT996NE1	BUTCHER AVE & GRAND CENTRAL DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2013	INT996SW1	BUTCHER AVE & GRAND CENTRAL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2008	INT961SE1	BUTCHER AVE & MORALES CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2009	INT961NW1	BUTCHER AVE & MORALES CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2010	INT961NE1	BUTCHER AVE & MORALES CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2538	INT931SW1	CABRERA CT & PANERO WY	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2539	INT931NW1	CABRERA CT & PANERO WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2062	INT759SW1	CADILLAC DR & COGNAC WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2063	INT759NW1	CADILLAC DR & COGNAC WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2072	INT753SW1	CADILLAC DR & CULLEN AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2073	INT753NW1	CADILLAC DR & CULLEN AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2080	INT755SW1	CADILLAC DR & LUCCHESI LN	SW	Yes	No	No	No	No	No	No		P4-a	L4	08	\$ 3,200
2060	INT757SE1	CADILLAC DR & VERDEA CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2061	INT757NE1	CADILLAC DR & VERDEA CT	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2058	INT747NE1	CADILLAC DR & WOODWORTH AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2059	INT747NW1	CADILLAC DR & WOODWORTH AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1800	INT1055NE1	CALCAGNO ST & CAPITAL DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1802	INT1055NW1	CALCAGNO ST & CAPITAL DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2404	INT1031SE1	CALCAGNO ST & CENTRAL AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2405	INT1031NE1	CALCAGNO ST & CENTRAL AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1771	INT1135NW1	CALCAGNO ST & LINDEN DR	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1772	INT1135NE1	CALCAGNO ST & LINDEN DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1774	INT1168SW1	CALCAGNO ST & LYNLEY DR	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1775	INT1168SE1	CALCAGNO ST & LYNLEY DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1776	INT1169NW1	CALCAGNO ST & LYNLEY DR	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1778	INT1169NE1	CALCAGNO ST & LYNLEY DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1616	INT1242NW1	CALCAGNO ST & MOFFETT RD	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1617	INT1242SW1	CALCAGNO ST & MOFFETT RD	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1766	INT1096NE1	CALCAGNO ST & MYRTLEWOOD DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1767	INT1096SE1	CALCAGNO ST & MYRTLEWOOD DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1768	INT1096SW1	CALCAGNO ST & MYRTLEWOOD DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1770	INT1096NW1	CALCAGNO ST & MYRTLEWOOD DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1780	INT1212NE1	CALCAGNO ST & RUNNING LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1781	INT1212NW1	CALCAGNO ST & RUNNING LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1782	INT1212SE1	CALCAGNO ST & RUNNING LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1783	INT1212SW1	CALCAGNO ST & RUNNING LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1419	INT425SW1	CAMBRIDGE WY & KATIE LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1421	INT425SE1	CAMBRIDGE WY & KATIE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2320	INT1371NE1	CAMELIA CT & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2322	INT1371NW1	CAMELIA CT & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1036	INT622SE1	CAMERON PARK CT & CAMERON PARK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1000	INT617NE1	CAMERON PARK DR & KINSER RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1001	INT617NW1	CAMERON PARK DR & KINSER RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1028	INT618SE1	CAMERON PARK DR & LAKE TAHOE CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1030	INT618NE1	CAMERON PARK DR & LAKE TAHOE CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1031	INT618SW1	CAMERON PARK DR & LAKE TAHOE CT	SW	Yes	Yes	Yes	Yes	No	No	No		P4-a	L4	08	\$ 3,200
1033	INT619SE1	CAMERON PARK DR & STRAWBERRY DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1034	INT619SW1	CAMERON PARK DR & STRAWBERRY DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1035	INT619NE1	CAMERON PARK DR & STRAWBERRY DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1182	INT372NE1	CAMINO DEL REY & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1183	INT372NW1	CAMINO DEL REY & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1187	INT372SW1	CAMINO DEL REY & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2235	INT1260NE1	CANYON CT & CANYON DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2236	INT1260NW1	CANYON CT & CANYON DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2237	INT1260SW1	CANYON CT & CANYON DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2173	INT1191NW1	CANYON DR & FLATRIDGE CT	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2174	INT1191NE1	CANYON DR & FLATRIDGE CT	NE	Yes	Yes	Yes	No	No	No	No		P4-a	L4	08	\$ 3,200
2177	INT1219SW1	CANYON DR & FRUITRIDGE CT & FRUITRIDGE DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2178	INT1219NW1	CANYON DR & FRUITRIDGE CT & FRUITRIDGE DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2179	INT1219NE1	CANYON DR & FRUITRIDGE CT & FRUITRIDGE DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2180	INT1219SE1	CANYON DR & FRUITRIDGE CT & FRUITRIDGE DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2175	INT1208SW1	CANYON DR & GROVER DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2176	INT1208SE1	CANYON DR & GROVER DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2171	INT1172NW1	CANYON DR & LANDRETH CT	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2172	INT1172NE1	CANYON DR & LANDRETH CT	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2192	INT1248SW1	CANYON DR & MOFFETT RD	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2193	INT1248NW1	CANYON DR & MOFFETT RD	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2194	INT1249SE1	CANYON DR & MOFFETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2195	INT1249NE1	CANYON DR & MOFFETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2196	INT1249NW1	CANYON DR & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2211	INT1433NW1	CANYON DR & NORTH CANYON DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
2212	INT1433SW1	CANYON DR & NORTH CANYON DR	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2169	INT1147SE1	CANYON DR & OAK RIDGE DR & ROCKYRIDGE CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2170	INT1147NE1	CANYON DR & OAK RIDGE DR & ROCKYRIDGE CT	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2205	INT1357NE1	CANYON DR & RIVERBEND DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2206	INT1357SW1	CANYON DR & RIVERBEND DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2207	INT1357NW1	CANYON DR & RIVERBEND DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2232	INT1268NW1	CANYON DR & SHADOW RIDGE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2233	INT1268NE1	CANYON DR & SHADOW RIDGE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2234	INT1268SW1	CANYON DR & SHADOW RIDGE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2208	INT1386SW1	CANYON DR & SNOW RIDGE CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2209	INT1386NW1	CANYON DR & SNOW RIDGE CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2210	INT1386NE1	CANYON DR & SNOW RIDGE CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2220	INT1307NE1	CANYON DR & STILLWATER LN	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2221	INT1307SW1	CANYON DR & STILLWATER LN	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2222	INT1307NW1	CANYON DR & STILLWATER LN	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2226	INT1291NE1	CANYON DR & VALLEY WIND WY	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2227	INT1291NW1	CANYON DR & VALLEY WIND WY	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2228	INT1291SE1	CANYON DR & VALLEY WIND WY	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2213	INT1424SW1	CANYON FALLS DR & NORTH CANYON DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
2214	INT1424NW1	CANYON FALLS DR & NORTH CANYON DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
2215	INT1424NE1	CANYON FALLS DR & NORTH CANYON DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
2216	INT1333SE1	CANYON FALLS DR & RIVER RD	SE	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
2217	INT1333SW1	CANYON FALLS DR & RIVER RD	SW	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
1796	INT1052SE1	CAPITAL DR & LAVON LN	SE	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1797	INT1054NE1	CAPITAL DR & RIDGEWAY DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1798	INT1054SE1	CAPITAL DR & RIDGEWAY DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1438	INT1395NE1	CARDINAL DR & GARRISON ST	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1439	INT1395NW1	CARDINAL DR & GARRISON ST	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1482	INT1396NW1	CARDINAL DR & STARLING DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1484	INT1396SW1	CARDINAL DR & STARLING DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1747	INT178NE1	CAROL LN & W WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	No	Ramp currently leads to	P4-a	L3	06	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2597	MID1759W1	CASA VERDE DR	W	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2598	MID1759E1	CASA VERDE DR	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
426	INT1301NE1	CASA VERDE DR & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
427	INT1301NW1	CASA VERDE DR & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2596	INT1301S1	CASA VERDE DR & MAGNOLIA ST	S	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
410	INT1349NW1	CASA VERDE DR & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
411	INT1349SW1	CASA VERDE DR & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
884	INT561NE1	CASSIE LN & GENEVIEVE WY	NE	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
877	INT562SW1	CASSIE LN & TASHA DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
878	INT562NW1	CASSIE LN & TASHA DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
879	INT562SE1	CASSIE LN & TASHA DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
836	INT766SW1	CASTIGLIONE WY & GRAHAM LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
838	INT766NW1	CASTIGLIONE WY & GRAHAM LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
788	INT767SW1	CASTIGLIONE WY & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
789	INT767SE1	CASTIGLIONE WY & HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
835	INT768NW1	CASTIGLIONE WY & INLAND LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2389	INT1035NE1	CASWELL AVE & CENTRAL AVE & SEQUOIA	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2390	INT1035NW1	CASWELL AVE & CENTRAL AVE & SEQUOIA	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2391	INT1035SW1	CASWELL AVE & CENTRAL AVE & SEQUOIA	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2392	INT1035SE1	CASWELL AVE & CENTRAL AVE & SEQUOIA	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1865	INT1062NW1	CASWELL AVE & GLENWOOD DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1866	INT1062NE1	CASWELL AVE & GLENWOOD DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1867	INT1062SE1	CASWELL AVE & GLENWOOD DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2360	INT1189NW1	CASWELL AVE & JEWEL ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2361	INT1189NE1	CASWELL AVE & JEWEL ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1566	INT1234NW1	CASWELL AVE & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1567	INT1234SW1	CASWELL AVE & MOFFETT RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
2358	INT1157NW1	CASWELL AVE & VAUGHN ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2359	INT1157NE1	CASWELL AVE & VAUGHN ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2051	INT976SW1	CATHEDRAL LN & CENTRAL PARK WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2052	INT976NE1	CATHEDRAL LN & CENTRAL PARK WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2053	INT976NW1	CATHEDRAL LN & CENTRAL PARK WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2002	INT977SW1	CATHEDRAL LN & TARBORO WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2003	INT977NW1	CATHEDRAL LN & TARBORO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2004	INT977NE1	CATHEDRAL LN & TARBORO WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1081	INT720NW1	CAULFIELD DR & PARK ROYAL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2612	INT720NE1	CAULFIELD DR & PARK ROYAL DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
857	INT1592SE1	CAVALIER CT & VALERA DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
860	INT1592NW1	CAVALIER CT & VALERA DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
863	INT1592NE1	CAVALIER CT & VALERA DR	NE	Yes	Yes	No	Yes	No	No	Yes	dws size out of	P5	L4	09	\$ 1,100
2044	INT1042NW1	CENTRAL AVE & CHABLIS WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2045	INT1042SW1	CENTRAL AVE & CHABLIS WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2393	INT1032SW1	CENTRAL AVE & DARRAH ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2394	INT1032NW1	CENTRAL AVE & DARRAH ST	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
675	INT1015SE1	CENTRAL AVE & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
676	INT1015SW1	CENTRAL AVE & DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
678	INT1015NW1	CENTRAL AVE & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
680	INT1015NE1	CENTRAL AVE & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2318	INT1026NE1	CENTRAL AVE & E HATCH RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2319	INT1026NW1	CENTRAL AVE & E HATCH RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2559	INT1026SW1	CENTRAL AVE & E HATCH RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2560	INT1026SE1	CENTRAL AVE & E HATCH RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1822	INT1013NW1	CENTRAL AVE & E SERVICE RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
101	INT1043SW1	CENTRAL AVE & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
102	INT1043SE2	CENTRAL AVE & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
103	INT1043SE1	CENTRAL AVE & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2378	INT1043NE1	CENTRAL AVE & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2379	INT1043NW1	CENTRAL AVE & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
468	INT1020SE1	CENTRAL AVE & EL CAMINO	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
467	INT1020NW1	CENTRAL AVE & EL CAMINO	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2396	INT1028NW1	CENTRAL AVE & EVANS RD	NW	No	Yes	No	No	No	No	No	No curb/gutter/sidewalk at corner. School	P2	L2-b	02	\$ 3,200
2397	INT1028NE1	CENTRAL AVE & EVANS RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2395	INT1028SW1	CENTRAL AVE & EVANS RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2409	INT1029SE1	CENTRAL AVE & GLASGOW DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2410	INT1029NE1	CENTRAL AVE & GLASGOW DR	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2377	INT1041NE1	CENTRAL AVE & GLENDA RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2384	INT1041SW1	CENTRAL AVE & GLENDA RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2385	INT1041NW1	CENTRAL AVE & GLENDA RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2386	INT1041SE1	CENTRAL AVE & GLENDA RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1777	INT1033SW1	CENTRAL AVE & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1779	INT1034NW1	CENTRAL AVE & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2398	INT1025NE1	CENTRAL AVE & HALE ALOHA WY	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2399	INT1025SE1	CENTRAL AVE & HALE ALOHA WY	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
683	INT1016SE1	CENTRAL AVE & HARDY CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
685	INT1016NE1	CENTRAL AVE & HARDY CT	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2387	INT1036SW1	CENTRAL AVE & HOLLISTER ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2388	INT1036NW1	CENTRAL AVE & HOLLISTER ST	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
689	INT1017SE1	CENTRAL AVE & LAUREL AVE	SE	Yes	Yes	No	No	No	No	No	cr leads to dirt corner on	P4-a	L4	08	\$ 1,100
2037	INT1039SW1	CENTRAL AVE & LIVE OAK CT & RIVER RD	SW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 1,100
458	INT1049NW1	CENTRAL AVE & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
459	INT1049SW1	CENTRAL AVE & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
460	INT1049SE1	CENTRAL AVE & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
461	INT1049NE1	CENTRAL AVE & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2402	INT1021SE1	CENTRAL AVE & MAUNA LOA DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2403	INT1021NE1	CENTRAL AVE & MAUNA LOA DR	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2042	INT1044NE1	CENTRAL AVE & MILLCREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2043	INT1044SE1	CENTRAL AVE & MILLCREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1937	INT1037SW1	CENTRAL AVE & NADINE AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1938	INT1037NW1	CENTRAL AVE & NADINE AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2038	INT1045NW1	CENTRAL AVE & PARK EAST DR & PARK	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2039	INT1045SW1	CENTRAL AVE & PARK EAST DR & PARK	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2040	INT1045SE1	CENTRAL AVE & PARK EAST DR & PARK	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2041	INT1045NE1	CENTRAL AVE & PARK EAST DR & PARK	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1804	INT1022SE1	CENTRAL AVE & PINE ST	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1803	INT1022NE1	CENTRAL AVE & PINE ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1799	INT1027NW1	CENTRAL AVE & PLEASANT AVE	NW	No	Yes	No	No	No	No	No	no sidewalk	P2	L3	03	\$ 3,200
1801	INT1027SW1	CENTRAL AVE & PLEASANT AVE	SW	No	Yes	No	No	No	No	No	no sidewalk	P2	L3	03	\$ 3,200
465	INT1050SW1	CENTRAL AVE & POPLAR ST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
466	INT1050NW1	CENTRAL AVE & POPLAR ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2046	INT1040NE1	CENTRAL AVE & PROMENADE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2047	INT1040SE1	CENTRAL AVE & PROMENADE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1769	INT1038SE1	CENTRAL AVE & RAILROAD AVE	SE	Yes	No	No	No	No	No	No	Leads to no other ramps	P4-a	L5	08	\$ 3,200
2400	INT1023SW1	CENTRAL AVE & RICHARD WY	SW	No	Yes	No	No	No	No	No	No curb, cutter or sidewalk at corner.	P2	L4	05	\$ 3,200

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2401	INT1023NW1	CENTRAL AVE & RICHARD WY	NW	No	Yes	No	No	No	No	No	No curb, cutter or sidewalk at corner.	P2	L4	05	\$ 3,200
2022	INT1048SW1	CENTRAL AVE & TUOLUMNE BEND LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2023	INT1048NW1	CENTRAL AVE & TUOLUMNE BEND LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2380	INT1738NE1	CENTRAL AVE & UNNAMED RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2381	INT1738SE1	CENTRAL AVE & UNNAMED RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2382	INT1738SW1	CENTRAL AVE & UNNAMED RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
2383	INT1738NW1	CENTRAL AVE & UNNAMED RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
700	INT1018NW1	CENTRAL AVE & WALNUT AVE	NW	No	Yes	No	No	No	No	No	Utility pole/PO	P2	L4	05	\$ 3,200
696	INT1018SW1	CENTRAL AVE & WALNUT AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1773	INT1024NE1	CENTRAL AVE & WEST AVE	NE	Yes	No	No	No	No	No	No	Leads to no other ramps	P4-a	L5	08	\$ 3,200
2054	INT952NE1	CENTRAL PARK WY & FREDRICKS LN	NE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2050	INT994NW1	CENTRAL PARK WY & GRAND CENTRAL DR	NW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1933	INT990NE1	CHABLIS WY & COLUMBARD WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1934	INT990SE1	CHABLIS WY & COLUMBARD WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
418	INT1362NW1	CHAHALIS WY & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
419	INT1362SW1	CHAHALIS WY & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2601	INT1362E1	CHAHALIS WY & ROSE AVE	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
420	INT1300NE1	CHAHALIS WY & VILLA RAMON DR	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
421	INT1300SE1	CHAHALIS WY & VILLA RAMON DR	SE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2607	INT1300W1	CHAHALIS WY & VILLA RAMON DR	W	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
907	INT629NW1	CHANDRA CT & GENEVIEVE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
908	INT629SW1	CHANDRA CT & GENEVIEVE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
909	INT629NE1	CHANDRA CT & GENEVIEVE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1995	INT809SE1	CHANEY DR & RICHLAND AVE	SE	No	Yes	No	No	No	No	No	SW infill	P2	L4	05	\$ 3,200
1994	INT809NE1	CHANEY DR & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	No	Ramp does not lead to	P4-a	L4	08	\$ 1,100
1992	INT838NW1	CHANEY DR & TAGGERT CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1993	INT838NE1	CHANEY DR & TAGGERT CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2157	INT1123SE1	CHANGASON WY & LEESEME LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2158	INT1123NW1	CHANGASON WY & LEESEME LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2153	INT1124NE1	CHANGASON WY & PAYNE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2154	INT1124NW1	CHANGASON WY & PAYNE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2155	INT1124SW1	CHANGASON WY & PAYNE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2156	INT1124SE1	CHANGASON WY & PAYNE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1939	INT975NE1	CHARDONNAY CT & CHARDONNAY WY & NADINE AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1940	INT975SE1	CHARDONNAY CT & CHARDONNAY WY & NADINE AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1941	INT975SW1	CHARDONNAY CT & CHARDONNAY WY & NADINE AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1942	INT975NW1	CHARDONNAY CT & CHARDONNAY WY & NADINE AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1929	INT970SW1	CHARDONNAY WY & COLUMBARD WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1930	INT970SE1	CHARDONNAY WY & COLUMBARD WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1943	INT974SW1	CHARDONNAY WY & RIESLING DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1944	INT974NW1	CHARDONNAY WY & RIESLING DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2316	INT1339NE1	CHARLOTTE AVE & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2317	INT1339NW1	CHARLOTTE AVE & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2334	INT1338NW1	CHARLOTTE AVE & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2335	INT1338NE1	CHARLOTTE AVE & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1468	INT1342SE1	CHARLOTTE AVE & ROSE AVE	SE	No	Yes	No	No	No	No	No	No sidewalks	P2	L4	05	\$ 3,200
1466	INT1342SW1	CHARLOTTE AVE & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1471	INT1342NE1	CHARLOTTE AVE & ROSE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1472	INT1342NW1	CHARLOTTE AVE & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1300	INT1502NE1	CHARLOTTESVILLE LN & MATTERHORN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1303	INT1502SE1	CHARLOTTESVILLE LN & MATTERHORN WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1256	INT1491SE1	CHARLOTTESVILLE LN & PERISBURG LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1257	INT1491NE1	CHARLOTTESVILLE LN & PERISBURG LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1258	INT1500SE1	CHARLOTTESVILLE LN & RHONE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1259	INT1500NE1	CHARLOTTESVILLE LN & RHONE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1255	INT1492NE1	CHARLOTTESVILLE LN & SUFFOLK DR	NE	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1297	INT1501NE1	CHARLOTTESVILLE LN & ZURICH LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1298	INT1501SE1	CHARLOTTESVILLE LN & ZURICH LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1299	INT1501SW1	CHARLOTTESVILLE LN & ZURICH LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
160	INT1481NW1	CHAULET LN & KONING LN	NW	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
157	INT1482SE1	CHAULET LN & ROEDING RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
158	INT1482SW1	CHAULET LN & ROEDING RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
963	INT847NW1	CHAUNCY WY & MCCORD WY	NW	Yes	Yes	No	Yes	No	No	No	bbh in ramp	P4-a	L4	08	\$ 1,100
964	INT847SW1	CHAUNCY WY & MCCORD WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
965	INT827SE1	CHAUNCY WY & WILLETTS WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
966	INT827NE1	CHAUNCY WY & WILLETTS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1949	INT955SW1	CHENIN CI & RIESLING DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1950	INT955NW1	CHENIN CI & RIESLING DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
859	INT650SW1	CHERISE CT & GEORGEANN PL	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
861	INT650SE1	CHERISE CT & GEORGEANN PL	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
862	INT650NW1	CHERISE CT & GEORGEANN PL	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
374	INT1322NW1	CHRISTY CT & CHRISTY LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
363	INT1292SE1	CHRISTY LN & EVALEE CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
369	INT1315NW1	CHRISTY LN & OMIE LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
371	INT1315NE1	CHRISTY LN & OMIE LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
372	INT1315SE1	CHRISTY LN & OMIE LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
366	INT1305SW1	CHRISTY LN & SHERRY CT	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
368	INT1305SE1	CHRISTY LN & SHERRY CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
265	INT1698SE1	CLARENDON CT & EAU CLAIRE AVE & SOMERSBY LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
268	INT1698NW1	CLARENDON CT & EAU CLAIRE AVE & SOMERSBY LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
267	INT1698SW1	CLARENDON CT & EAU CLAIRE AVE & SOMERSBY LN	SW	Yes	Yes	No	Yes	No	No	Yes	DWS size not compliant	P5	L4	09	\$ 1,100
990	INT1528SW1	CLETA CT & LINDSAY WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
994	INT1528SE1	CLETA CT & LINDSAY WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2095	INT625SW1	CLING CT & LUCCHESI LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2096	INT625SE1	CLING CT & LUCCHESI LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2066	INT698SE1	COGNAC WY & LARSEN DR	SE	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2064	INT718SE1	COGNAC WY & WINEPRESS LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2065	INT718SW1	COGNAC WY & WINEPRESS LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
182	INT1452SE1	COLLEEN WY & MITCHELL RD	SE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
183	INT1452NE1	COLLEEN WY & MITCHELL RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1817	INT1185SE1	COLLINS RD & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1935	INT992NW1	COLUMBARD WY & NADINE AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1936	INT992NE1	COLUMBARD WY & NADINE AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1927	INT956SW1	COLUMBARD WY & RIESLING DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1928	INT956SE1	COLUMBARD WY & RIESLING DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1903	INT925NW1	COLUMBARD WY & STONUM RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1904	INT925SW1	COLUMBARD WY & STONUM RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1905	INT925NE1	COLUMBARD WY & STONUM RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1906	INT925SE1	COLUMBARD WY & STONUM RD	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
129	INT1692NW1	COPPERWOOD LN & NORTHERN OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
130	INT1692SE1	COPPERWOOD LN & NORTHERN OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
131	INT1692SW1	COPPERWOOD LN & NORTHERN OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
73	INT1693NE1	COPPERWOOD LN & WILD OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
77	INT1693NW1	COPPERWOOD LN & WILD OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
75	INT1693SE1	COPPERWOOD LN & WILD OAK DR	SE	Yes	Yes	No	Yes	No	No	Yes	DWS size not compliant	P5	L3	09	\$ 1,100
592	INT1383NE1	CORDOBA CT & EL DORADO DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
593	INT1383SE1	CORDOBA CT & EL DORADO DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1722	INT217NE1	CORNUCOPIA WY & CROWS LANDING RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1723	INT217SE1	CORNUCOPIA WY & CROWS LANDING RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1647	MID1726SW1	COTY CT	SW	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1637	INT1271SE1	COTY CT & DEBLYN CT & GLASGOW DR	SE	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
1639	INT1271NE1	COTY CT & DEBLYN CT & GLASGOW DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1641	INT1271NW1	COTY CT & DEBLYN CT & GLASGOW DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1643	INT1271SW1	COTY CT & DEBLYN CT & GLASGOW DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	
1266	INT493NW1	CRESCENT MOON CT & TWILIGHT DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1267	INT493NE1	CRESCENT MOON CT & TWILIGHT DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1268	INT493SW1	CRESCENT MOON CT & TWILIGHT DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2494	INT898SE1	CRESTMoor CT & SOUTHLAWN DR & WEATHERVANE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2495	INT898SW1	CRESTMoor CT & SOUTHLAWN DR & WEATHERVANE LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1556	INT1410NE1	CRETE CT & SHUSHAN DR	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1557	INT1410SE1	CRETE CT & SHUSHAN DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1829	INT941NE1	CROWN VIEW DR & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1830	INT941NW1	CROWN VIEW DR & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1727	INT218SE1	CROWS LANDING RD & E HACKETT RD & W HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1729	INT218NE1	CROWS LANDING RD & E HACKETT RD & W HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1733	INT218SW1	CROWS LANDING RD & E HACKETT RD & W HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1731	INT218NW1	CROWS LANDING RD & E HACKETT RD & W HACKETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1442	INT216NE1	CROWS LANDING RD & E SERVICE RD & W SERVICE RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1443	INT216NW1	CROWS LANDING RD & E SERVICE RD & W SERVICE RD	NW	Yes	Yes	No	Yes	No	No	No	No SW leading to ramp	P4-a	L2-b	04	\$ 1,100
1445	INT216SW1	CROWS LANDING RD & E SERVICE RD & W SERVICE RD	SW	Yes	Yes	No	Yes	No	No	No	Sidewalk leads into ramp from south only	P4-a	L2-b	04	\$ 1,100
1446	INT216SE1	CROWS LANDING RD & E SERVICE RD & W SERVICE RD	SE	Yes	Yes	No	Yes	No	No	No	Sidewalk leads into ramp from south only	P4-a	L2-b	04	\$ 1,100
22	INT219SW1	CROWS LANDING RD & E WHITMORE AVE & W WHITMORE AVE	SW	Yes	Yes	No	No	No	No	No	No Sidewalk leading to CR	P4-a	L3	06	\$ 1,100
23	INT219SE1	CROWS LANDING RD & E WHITMORE AVE & W WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
1745	MID1756SE1	CROWS LANDING RD & PRIVATE RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1746	MID1756NE1	CROWS LANDING RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1359	INT371SE1	CRYSTAL FALLS CT & ROCKY BROOK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1360	INT371SW1	CRYSTAL FALLS CT & ROCKY BROOK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1362	INT371NE1	CRYSTAL FALLS CT & ROCKY BROOK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2074	INT722NE1	CULLEN AVE & FOSTER DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2075	INT722NW1	CULLEN AVE & FOSTER DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2078	INT666SE1	CULLEN AVE & MUSICK AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2079	INT666NE1	CULLEN AVE & MUSICK AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1511	INT682SE1	DAISY TREE LN & RED HAVEN LN	SE	Yes	No	No	Yes	No	Yes	No	bbh in ramp	P3	L4	07	\$ 3,200
2573	INT1455SE1	DALE AVE & DALE CT & MITCHELL RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2574	INT1455NE1	DALE AVE & DALE CT & MITCHELL RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2575	INT1455NW1	DALE AVE & DALE CT & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2576	INT1455SW1	DALE AVE & DALE CT & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2338	INT1256NW1	DALE AVE & E WHITMORE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2339	INT1256NE1	DALE AVE & E WHITMORE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1587	INT1266NW1	DALE AVE & ELOISE AVE	NW	No	No	No	Yes	No	No	No	No sidewalks	P4-a	L4	08	
1588	INT1266NE1	DALE AVE & ELOISE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1590	INT1266SE1	DALE AVE & ELOISE AVE	SW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1591	INT1266SW1	DALE AVE & ELOISE AVE	NW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1424	INT1415SE1	DALE AVE & LOUISE AVE	SE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1425	INT1415NE1	DALE AVE & LOUISE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1426	INT1415SW1	DALE AVE & LOUISE AVE	SW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1427	INT1415NW1	DALE AVE & LOUISE AVE	NW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1452	INT1340SW1	DALE AVE & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1454	INT1340NE1	DALE AVE & ROSE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1455	INT1340SE1	DALE AVE & ROSE AVE	SE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1456	INT1340NW1	DALE AVE & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1021	INT593NW1	DANIEL WY & VALENTINA WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1526	INT777NW1	DANO CT & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1527	INT777NE1	DANO CT & DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1528	INT777SE1	DANO CT & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2440	INT899SW1	DARBY LN & MANNY LN	SW	Yes	Yes	No	Yes	No	Yes	Yes		P3	L4	07	\$ 5,600
2439	INT899SE1	DARBY LN & MANNY LN	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2437	INT888NW1	DARBY LN & MONICA LN	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2438	INT888NE1	DARBY LN & MONICA LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2450	INT787NE1	DARBY LN & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2451	INT787SE1	DARBY LN & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2515	INT966SW1	DARRAH ST & LOIS WY	SW	No	Yes	No	No	No	No	No	Fire Hydrant	P2	L4	05	\$ 3,200
2512	INT966NE1	DARRAH ST & LOIS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2513	INT966NW1	DARRAH ST & LOIS WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2514	INT966SE1	DARRAH ST & LOIS WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2517	INT935SE1	DARRAH ST & MEMORIAL DR	SE	No	Yes	No	No	No	No	No	No ramp	P2	L2-b	02	\$ 3,200
1548	INT1303NW1	DARWIN AVE & FOWLER RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1549	INT1303NE1	DARWIN AVE & FOWLER RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1720	INT1331SE1	DARWIN AVE & ROSE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1721	INT1331NW1	DARWIN AVE & ROSE AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1724	INT1331SW1	DARWIN AVE & ROSE AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
207	INT1634NW1	DAWNVIEW AVE & EASTGATE BLV	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
210	INT1634NE1	DAWNVIEW AVE & EASTGATE BLV	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
634	INT1620NW1	DAWNVIEW AVE & YOLANDA ST	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
636	INT1620SE1	DAWNVIEW AVE & YOLANDA ST	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
638	INT1620NE1	DAWNVIEW AVE & YOLANDA ST	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
1221	INT395NW1	DAY BREAK WY & MALIK AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1222	INT395SW1	DAY BREAK WY & MALIK AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1216	INT366NE1	DAY BREAK WY & SOLEADO DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1217	INT366SE1	DAY BREAK WY & SOLEADO DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1218	INT366SW1	DAY BREAK WY & SOLEADO DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
897	INT605SW1	DELAINE CT & JORDANOLO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
899	INT605NW1	DELAINE CT & JORDANOLO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
900	INT605NE1	DELAINE CT & JORDANOLO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
145	INT1475SW1	DELLA DR & E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No sidewalk behind CR	P5	L3	09	
146	INT1475SE1	DELLA DR & E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
952	INT1529NE1	DENNY CT & PUMA WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
954	INT1529NW1	DENNY CT & PUMA WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
651	INT1221NW1	DIRK CT & ROEDING RD	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1539	INT859NW1	DON PEDRO CT & DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1540	INT859SW1	DON PEDRO CT & DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1541	INT859SE1	DON PEDRO CT & DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
263	MID1740NE1	DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
264	MID1740NW1	DON PEDRO RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
266	MID1740SE1	DON PEDRO RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
672	MID1741SW1	DON PEDRO RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
674	MID1741NE1	DON PEDRO RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
360	INT1298SW1	DON PEDRO RD & EVALEE LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
361	INT1298SE1	DON PEDRO RD & EVALEE LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
357	INT1298NW1	DON PEDRO RD & EVALEE LN	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
358	INT1298NE1	DON PEDRO RD & EVALEE LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1603	INT947SW1	DON PEDRO RD & GAZA LN	SW	Yes	Yes	Yes	Yes	Yes	No	No		P4-a	L4	08	\$ 3,200
1604	INT947SE1	DON PEDRO RD & GAZA LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1505	INT657NE1	DON PEDRO RD & GEORGEANN PL	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1507	INT657NW1	DON PEDRO RD & GEORGEANN PL	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1508	INT657SW1	DON PEDRO RD & GEORGEANN PL	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1584	INT928NW1	DON PEDRO RD & JOPPA LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1593	INT928NE1	DON PEDRO RD & JOPPA LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
184	INT1448SE2	DON PEDRO RD & MITCHELL RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
185	INT1448SE1	DON PEDRO RD & MITCHELL RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
186	INT1448NE1	DON PEDRO RD & MITCHELL RD	NE	Yes	Yes	No	Yes	No	No	Yes	No SW behind cr	P5	L3	09	
187	INT1448SW1	DON PEDRO RD & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
188	INT1448NW1	DON PEDRO RD & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
376	INT1313SW1	DON PEDRO RD & OMIE LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
378	INT1313SE1	DON PEDRO RD & OMIE LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1502	INT681NE1	DON PEDRO RD & RED HAVEN LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1503	INT681NW1	DON PEDRO RD & RED HAVEN LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1504	INT681SW1	DON PEDRO RD & RED HAVEN LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1473	INT634SW1	DON PEDRO RD & RICKMAN WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1474	INT634SE1	DON PEDRO RD & RICKMAN WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1475	INT634NE1	DON PEDRO RD & RICKMAN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1573	INT880NW1	DON PEDRO RD & ROYAL ANN DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1574	INT880SW1	DON PEDRO RD & ROYAL ANN DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1575	INT880SE1	DON PEDRO RD & ROYAL ANN DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1493	INT719SW1	DON PEDRO RD & SWEET GUM DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1494	INT719NW1	DON PEDRO RD & SWEET GUM DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1496	INT719SE1	DON PEDRO RD & SWEET GUM DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
379	INT1330NW1	DON PEDRO RD & TIMBERLY LN	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
380	INT1330NE1	DON PEDRO RD & TIMBERLY LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1607	INT1002NW1	DON PEDRO RD & URMI AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1609	INT1002NE1	DON PEDRO RD & URMI AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1610	INT1002SW1	DON PEDRO RD & URMI AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1611	INT1002SE1	DON PEDRO RD & URMI AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1576	INT914SW1	DON PEDRO RD & WOODVIEW DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1577	INT914NW1	DON PEDRO RD & WOODVIEW DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1578	INT913SW1	DON PEDRO RD & WOODVIEW DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1579	INT913NE1	DON PEDRO RD & WOODVIEW DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1580	INT913SE1	DON PEDRO RD & WOODVIEW DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2530	INT999SW1	DONNA WY & FRED A WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2531	INT999NW1	DONNA WY & FRED A WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
2532	INT950NE1	DONNA WY & GLENDA RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
2533	INT950SW1	DONNA WY & GLENDA RD	SW	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
2132	INT1058NW1	DONNE BROOK LN & MILLCREEK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2133	INT1058NE1	DONNE BROOK LN & MILLCREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2134	INT1058SE1	DONNE BROOK LN & MILLCREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2135	INT1059SE1	DONNE BROOK LN & SHADOWBROOK WY	SE	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 3,200
886	INT587SE1	DORMEA CT & GENEVIEVE WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
887	INT587NW1	DORMEA CT & GENEVIEVE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
888	INT587NE1	DORMEA CT & GENEVIEVE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1805	INT1156NE1	DOUGLAS DR & LYNLEY DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1808	INT1211NW1	DOUGLAS DR & RUNNING LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1806	INT1196SW1	DOUGLAS DR & WALLACE AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1807	INT1196SE1	DOUGLAS DR & WALLACE AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1635	INT874NE1	DRAKEWOOD CT & SOUTHWOOD DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1636	INT874NW1	DRAKEWOOD CT & SOUTHWOOD DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
997	INT1539SW1	DUPRE DR & LINDSAY WY	SW	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
949	INT1533NW1	DUPRE DR & PUMA WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
947	INT1534NE1	DUPRE DR & VERA WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
948	INT1534SE1	DUPRE DR & VERA WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
334	INT1694NW1	DUSTY MILLER LN & KIWI DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
337	INT1694NE1	DUSTY MILLER LN & KIWI DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
339	INT1694SW1	DUSTY MILLER LN & KIWI DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1748	MID1755SE1	E HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1749	MID1755NW1	E HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2551	INT1626SE1	E HATCH RD & EASTGATE BLV &	SE	No	Yes	No	No	No	No	No		P1	L2-a	01	\$ 3,200
2552	INT1626SW1	E HATCH RD & EASTGATE BLV &	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2304	INT586NE1	E HATCH RD & HERNDON AVE &	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2588	INT586SW1	E HATCH RD & HERNDON AVE &	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2589	INT586SE1	E HATCH RD & HERNDON AVE &	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2305	INT577NE1	E HATCH RD & HWY 99 (OFF RAMP) N	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2308	INT1460NE1	E HATCH RD & MITCHELL RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2309	INT1460NW1	E HATCH RD & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2563	INT1460SE1	E HATCH RD & MITCHELL RD	SE	Yes	Yes	No	Yes	No	No	Yes	Ramp for each direction	P5	L3	09	
2564	INT1460SW1	E HATCH RD & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes	Ramp for each direction	P5	L3	09	
2561	INT1244SW1	E HATCH RD & MOFFETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2562	INT1244SE1	E HATCH RD & MOFFETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2312	INT1244NE1	E HATCH RD & MOFFETT RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2313	INT1244NW1	E HATCH RD & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2555	MID1719SW1	E HATCH RD & PRIVATE RD	SW	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
2556	MID1719SE1	E HATCH RD & PRIVATE RD	SE	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
2314	MID1722NE1	E HATCH RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2315	MID1722NW1	E HATCH RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2329	MID1719NE1	E HATCH RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2330	MID1719NW1	E HATCH RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2553	MID1718SW1	E HATCH RD & PRIVATE RD	SW	No	No	No	No	No	No	No	PRIVATE DRIVEWAY	P4-a	L3	06	\$ -
2554	MID1718SE1	E HATCH RD & PRIVATE RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2331	MID1718NE1	E HATCH RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2332	MID1718NE2	E HATCH RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2333	MID1718NW1	E HATCH RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2325	INT784NW1	E HATCH RD & RICHLAND AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2557	INT784SW1	E HATCH RD & RICHLAND AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2558	INT784SE1	E HATCH RD & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
2324	INT784NE1	E HATCH RD & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2321	INT919NE1	E HATCH RD & STONUM RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1451	INT383SW1	E SERVICE RD & FARM SUPPLY DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1453	INT383SE1	E SERVICE RD & FARM SUPPLY DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
205	INT1447NW1	E SERVICE RD & MITCHELL RD	NW	No	Yes	No	No	No	No	No	Dirt lot. Leads to cr in	P2	L3	03	\$ 3,200
217	INT1447SW2	E SERVICE RD & MITCHELL RD	SW	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
218	INT1447SW1	E SERVICE RD & MITCHELL RD	SW	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
2590	INT1447NW2	E SERVICE RD & MITCHELL RD	NW	No	Yes	No	No	No	No	Yes	PED REFUGE	P2	L3	03	\$ 3,200
2591	INT1447NW3	E SERVICE RD & MITCHELL RD	NW	No	Yes	No	No	No	No	Yes	PED REFUGE	P2	L3	03	\$ 3,200
2592	INT1447NW4	E SERVICE RD & MITCHELL RD	NW	No	Yes	No	No	No	No	Yes	PED REFUGE	P2	L3	03	\$ 3,200
2593	INT1447NE2	E SERVICE RD & MITCHELL RD	NE	No	Yes	No	No	No	No	Yes	PED REFUGE	P2	L3	03	\$ 3,200
2594	INT1447NE3	E SERVICE RD & MITCHELL RD	NE	No	Yes	No	No	No	No	Yes	PED REFUGE	P2	L3	03	\$ 3,200
2595	INT1447NE4	E SERVICE RD & MITCHELL RD	NE	No	Yes	No	No	No	No	Yes	PED REFUGE	P2	L3	03	\$ 3,200
229	INT1447NE1	E SERVICE RD & MITCHELL RD	NE	Yes	Yes	Yes	Yes	No	Yes	Yes	Pavement raised at lip	P3	L3	05	\$ 3,200
235	INT1447SE1	E SERVICE RD & MITCHELL RD	SE	Yes	Yes	No	Yes	No	Yes	Yes	Vertical curb obstructs ped travel from SE	P3	L3	05	\$ 5,600
1457	INT535NE1	E SERVICE RD & MORGAN RD	NE	Yes	No	No	Yes	No	No	No	Ramp not needed at this time - no other ramps/sidewalk at	P4-a	L4	08	\$ 1,100
139	MID1733SW1	E WHITMORE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
140	MID1733SE1	E WHITMORE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2549	INT1614NW1	E WHITMORE AVE & EASTGATE BLV	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2550	INT1614NE1	E WHITMORE AVE & EASTGATE BLV	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
134	INT1381SW1	E WHITMORE AVE & EL DORADO DR	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
135	INT1381SE1	E WHITMORE AVE & EL DORADO DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
79	INT740SW1	E WHITMORE AVE & FAIRVIEW DR	SW	Yes	Yes	No	Yes	No	Yes	Yes	No crosswalk. Leads across major roadway.	P3	L3	05	\$ 5,600
48	INT590SW1	E WHITMORE AVE & FIESTA WY	SW	No	Yes	No	No	No	No	No	No sidewalk	P2	L3	03	\$ 3,200
49	INT590SE1	E WHITMORE AVE & FIESTA WY	SE	No	Yes	No	No	No	No	No	No sidewalk	P2	L3	03	\$ 3,200
91	INT1736SW1	E WHITMORE AVE & HWY 99 (ON RAMP)	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
92	INT1736NE1	E WHITMORE AVE & HWY 99 (ON RAMP)	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2336	INT1269NW1	E WHITMORE AVE & JOY AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2337	INT1269NE1	E WHITMORE AVE & JOY AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
125	INT1265SW1	E WHITMORE AVE & KAY ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
126	INT1265SE1	E WHITMORE AVE & KAY ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2327	INT1312NW1	E WHITMORE AVE & LILAC CT	NW	Yes	Yes	No	Yes	No	Yes	Yes	partial lack of sidewalk	P3	L3	05	\$ 5,600
2328	INT1312NE1	E WHITMORE AVE & LILAC CT	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2310	INT1411NE1	E WHITMORE AVE & LOUISE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2311	INT1411NW1	E WHITMORE AVE & LOUISE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2545	INT1515NW1	E WHITMORE AVE & LUNAR DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2546	INT1515NE1	E WHITMORE AVE & LUNAR DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
30	INT397SW1	E WHITMORE AVE & MALIK AVE	SW	Yes	Yes	No	No	No	No	Yes	Out of spec	P4-b	L3	07	\$ 1,100
32	INT397SE1	E WHITMORE AVE & MALIK AVE	SE	Yes	Yes	No	Yes	No	No	Yes	DWS size not compliant	P5	L3	09	\$ 1,100
143	INT1453SE1	E WHITMORE AVE & MITCHELL RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
142	INT1453SW1	E WHITMORE AVE & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2306	INT1453NE1	E WHITMORE AVE & MITCHELL RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2307	INT1453NW1	E WHITMORE AVE & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
152	INT1490SW1	E WHITMORE AVE & MOORE RD	SW	No	Yes	No	No	No	No	No	CR North from location	P2	L3	03	\$ 3,200
45	INT547SW1	E WHITMORE AVE & MORGAN RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
46	INT547SE1	E WHITMORE AVE & MORGAN RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
54	INT705SW1	E WHITMORE AVE & NO NAME ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
56	INT705SE1	E WHITMORE AVE & NO NAME ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
61	INT706SW1	E WHITMORE AVE & NO NAME ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
63	INT706SE1	E WHITMORE AVE & NO NAME ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
24	MID1757SW1	E WHITMORE AVE & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
25	MID1757SE1	E WHITMORE AVE & PRIVATE RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
27	MID1758SE1	E WHITMORE AVE & PRIVATE RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
40	MID1749SW1	E WHITMORE AVE & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
43	MID1749SE1	E WHITMORE AVE & PRIVATE RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
26	MID1758SW1	E WHITMORE AVE & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
36	MID1750SW1	E WHITMORE AVE & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
38	MID1750SE1	E WHITMORE AVE & PRIVATE RD	SE	Yes	Yes	No	Yes	No	No	Yes	No sidewalk behind ramp, ASSUMED	P5	L3	09	
85	INT911SW2	E WHITMORE AVE & RAILROAD AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
86	INT911SW1	E WHITMORE AVE & RAILROAD AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
87	INT911SE1	E WHITMORE AVE & RAILROAD AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
51	INT674SW1	E WHITMORE AVE & ROCKEFELLER DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
52	INT674SE1	E WHITMORE AVE & ROCKEFELLER DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
132	INT1344SW1	E WHITMORE AVE & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
133	INT1344SE1	E WHITMORE AVE & ROSE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2323	INT1344NW1	E WHITMORE AVE & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2326	INT1344NE1	E WHITMORE AVE & ROSE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
93	INT998NE1	E WHITMORE AVE & WHITMORE PL	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
95	INT998SW2	E WHITMORE AVE & WHITMORE PL	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
96	INT998SW1	E WHITMORE AVE & WHITMORE PL	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
324	INT1336NW1	EAST LN & HAYES CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
325	INT1336SW1	EAST LN & HAYES CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
321	INT1335SW1	EAST LN & ROEDING RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
320	INT1335SE1	EAST LN & ROEDING RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
508	INT1641NW1	EASTGATE BLV & EAU CLAIRE AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
511	INT1641NE1	EASTGATE BLV & EAU CLAIRE AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
514	INT1641SE1	EASTGATE BLV & EAU CLAIRE AVE	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
517	INT1640NW2	EASTGATE BLV & HELEN PERRY RD	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
519	INT1640NE1	EASTGATE BLV & HELEN PERRY RD	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
520	INT1640NE2	EASTGATE BLV & HELEN PERRY RD	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
521	INT1640NW1	EASTGATE BLV & HELEN PERRY RD	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
523	INT1640SW2	EASTGATE BLV & HELEN PERRY RD	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
524	INT1640SW1	EASTGATE BLV & HELEN PERRY RD	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
525	INT1640SE2	EASTGATE BLV & HELEN PERRY RD	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
527	INT1640SE1	EASTGATE BLV & HELEN PERRY RD	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
490	INT1642NE1	EASTGATE BLV & KIWI DR	NE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
491	INT1642SE1	EASTGATE BLV & KIWI DR	SE	Yes	No	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
805	INT1637NW1	EASTGATE BLV & LARIAN WY	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
806	INT1637SW1	EASTGATE BLV & LARIAN WY	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
168	INT1617NW1	EASTGATE BLV & MIRA SOL DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
171	INT1617NE1	EASTGATE BLV & MIRA SOL DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
172	INT1617SE1	EASTGATE BLV & MIRA SOL DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
159	INT1616NW1	EASTGATE BLV & NORTHERN OAK DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
164	INT1616NE1	EASTGATE BLV & NORTHERN OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
165	INT1616SE1	EASTGATE BLV & NORTHERN OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
498	INT1644NW1	EASTGATE BLV & PODOCARPU DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
499	INT1644NE1	EASTGATE BLV & PODOCARPU DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
500	INT1644SE1	EASTGATE BLV & PODOCARPU DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
495	INT1645NW1	EASTGATE BLV & POMEGRANATE AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
497	INT1645SW1	EASTGATE BLV & POMEGRANATE AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
504	INT1643NW1	EASTGATE BLV & WAYNESBORO DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
506	INT1643SW1	EASTGATE BLV & WAYNESBORO DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
204	INT1625SW1	EASTGATE BLV & WHITEHAVEN AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
206	INT1625NW1	EASTGATE BLV & WHITEHAVEN AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
200	INT1615SE1	EASTGATE BLV & WILD OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
201	INT1615SW1	EASTGATE BLV & WILD OAK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
202	INT1615NW1	EASTGATE BLV & WILD OAK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
203	INT1615NE1	EASTGATE BLV & WILD OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
260	INT1650SE1	EAU CLAIRE AVE & SAN MORITZ	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
261	INT1650NW1	EAU CLAIRE AVE & SAN MORITZ	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
262	INT1650NE1	EAU CLAIRE AVE & SAN MORITZ	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2018	INT1006SW1	EHLERS DR & LARS CT & TUOLUMNE BEND	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2019	INT1006SE1	EHLERS DR & LARS CT & TUOLUMNE BEND	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2020	INT1006NE1	EHLERS DR & LARS CT & TUOLUMNE BEND	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2021	INT1006NW1	EHLERS DR & LARS CT & TUOLUMNE BEND	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
509	INT1086NE1	EL CAMINO & LAWRENCE ST	NE	No	Yes	No	No	No	No	No	Pole/street signs	P2	L2-b	02	\$ 3,200
507	INT1086SE1	EL CAMINO & LAWRENCE ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
462	INT991NE1	EL CAMINO & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
463	INT991SE1	EL CAMINO & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
529	INT1149NW1	EL CAMINO & PARK ST & PINE ST	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
530	INT1149SE1	EL CAMINO & PARK ST & PINE ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
531	INT1149NE1	EL CAMINO & PARK ST & PINE ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
518	MID1735NE1	EL CAMINO & PRIVATE RD	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
522	MID1735SE1	EL CAMINO & PRIVATE RD	NE	No	Yes	No	No	No	No	No	Vegetation/landscape comes to back of curb,	P2	L4	05	\$ 3,200
589	INT1385NE1	EL DORADO DR & EL FARRARI CT	NE	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
590	INT1385SE1	EL DORADO DR & EL FARRARI CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
302	INT1382NE1	EL DORADO DR & STANDFORD AVE	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L2-a	09	
303	INT1382NW1	EL DORADO DR & STANDFORD AVE	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L2-a	09	
2602	INT1382S1	EL DORADO DR & STANDFORD AVE	S	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L2-a	09	
2583	INT831NW1	EL MONTE AVE & EL ROSAL AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2584	INT830SW1	EL MONTE AVE & RANCHO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2579	INT820NE1	EL ROSAL AVE & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2580	INT820SE1	EL ROSAL AVE & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1880	INT773SE1	ELECTRIC CT & FANTASY LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1881	INT773NE1	ELECTRIC CT & FANTASY LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1581	INT1257SW1	ELOISE AVE & GARRISON ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1582	INT1257SE1	ELOISE AVE & GARRISON ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1583	INT1257NE1	ELOISE AVE & GARRISON ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1592	INT1274NE1	ELOISE AVE & JOY AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1594	INT1274NW1	ELOISE AVE & JOY AVE	NW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1283	INT475SW1	ESTEBAN AVE & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1285	INT475NW1	ESTEBAN AVE & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1287	INT475NW2	ESTEBAN AVE & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1288	INT475NE1	ESTEBAN AVE & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1289	INT475SE1	ESTEBAN AVE & HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2285	INT548SE1	EUGENE AVE & HERNDON RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2286	INT548NE1	EUGENE AVE & HERNDON RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
364	INT1293NE1	EVALEE CT & EVALEE LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
386	INT1296SE1	EVALEE LN & VEDA DR	SE	No	Yes	No	No	No	No	No		P1	L2-a	01	\$ 3,200

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
387	INT1296SW1	EVALEE LN & VEDA DR	SW	No	Yes	No	No	No	No	No		P1	L2-a	01	\$ 3,200
2504	INT937SW1	EVANS RD & GAIL CT	SW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2505	INT937SE1	EVANS RD & GAIL CT	SE	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2506	INT940NE1	EVANS RD & GENE RD	NE	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2507	INT940NW1	EVANS RD & GENE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2475	INT707SE1	EVANS RD & HERNDON RD	SE	No	Yes	No	No	No	No	No		P2	L5	05	\$ 3,200
2474	INT707NE1	EVANS RD & HERNDON RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
2508	INT965NE1	EVANS RD & LOIS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2509	INT965NW1	EVANS RD & LOIS WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2511	INT989NW1	EVANS RD & MARGARET WY	NW	Yes	Yes	No	Yes	No	Yes	No	Utility pole obstruction	P3	L4	07	\$ 5,600
2510	INT989NE1	EVANS RD & MARGARET WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2476	INT758NW1	EVANS RD & NORWOOD HEIGHTS LN	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2477	INT758NE1	EVANS RD & NORWOOD HEIGHTS LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2482	INT816NW1	EVANS RD & RICHLAND AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2483	INT816SW1	EVANS RD & RICHLAND AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2484	INT816SE1	EVANS RD & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2485	INT816NE1	EVANS RD & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2492	INT897NW1	EVANS RD & SOUTHLAWN DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2493	INT897NE1	EVANS RD & SOUTHLAWN DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2498	INT903SE1	EVANS RD & STONEHENGE WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2503	INT903SW1	EVANS RD & STONEHENGE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2486	INT824NW1	EVANS RD & WESTVIEW DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2487	INT824NE1	EVANS RD & WESTVIEW DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1664	INT1401NW1	FALLQUIST WY & GLASGOW DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1667	INT1402SW1	FALLQUIST WY & MC NEIL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
591	INT1561NE1	FALLVIEW AVE & PALLADIN ST	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
594	INT1561SE1	FALLVIEW AVE & PALLADIN ST	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
595	INT1606SW1	FALLVIEW AVE & PARTRIDGE ST	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
598	INT1606NW1	FALLVIEW AVE & PARTRIDGE ST	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1067	INT539SE1	FANNELL DR & MORGAN RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1068	INT539NE1	FANNELL DR & MORGAN RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1071	INT621NW1	FANNELL DR & ROBNELL WY	NW	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1065	INT566SW1	FANNELL DR & VICKINELL PL	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1066	INT566SE1	FANNELL DR & VICKINELL PL	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1878	INT772SE1	FANTASY CT & FANTASY LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1879	INT772NE1	FANTASY CT & FANTASY LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1882	INT774SE1	FANTASY LN & MAGIC LN	SE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 1,100
1877	INT775SE1	FANTASY LN & PHIL WY	SE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 1,100
1709	INT381SE1	FARM SUPPLY DR & PARTEE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1710	INT381NE1	FARM SUPPLY DR & PARTEE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1851	INT875SE1	FARRIS AVE & HACKETT RD	SE	No	Yes	No	No	No	No	No	no sidewalk	P2	L4	05	\$ 3,200
1852	INT875SW1	FARRIS AVE & HACKETT RD	SW	No	Yes	No	No	No	No	No	no sidewalk	P2	L4	05	\$ 3,200
1846	INT875NE1	FARRIS AVE & HACKETT RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1849	INT875NW1	FARRIS AVE & HACKETT RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1760	INT877SW1	FARRIS AVE & KINSER RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1762	INT877SE1	FARRIS AVE & KINSER RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
704	INT868NW1	FARRIS AVE & WALNUT AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
705	INT868NE1	FARRIS AVE & WALNUT AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1890	INT896SW1	FERNRIDGE CT & STONUM RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1891	INT896SE1	FERNRIDGE CT & STONUM RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1892	INT896NE1	FERNRIDGE CT & STONUM RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
664	INT1599NE1	FICUS ST & HELEN PERRY RD	NE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
665	INT1599NW1	FICUS ST & HELEN PERRY RD	NW	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
701	INT1600NE1	FICUS ST & WAYNESBORO DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
702	INT1600SE1	FICUS ST & WAYNESBORO DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
703	INT1600SW1	FICUS ST & WAYNESBORO DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
314	INT1663SW1	FIDDLELEAF LN & HYACINTH DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
317	INT1663NW1	FIDDLELEAF LN & HYACINTH DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
318	INT1663NE1	FIDDLELEAF LN & HYACINTH DR	NE	Yes	Yes	No	Yes	No	No	Yes	DWS size out of	P5	L4	09	\$ 1,100
355	INT1664NW1	FIDDLELEAF LN & KIWI DR	NW	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
356	INT1664NE1	FIDDLELEAF LN & KIWI DR	NE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
359	INT1664SE1	FIDDLELEAF LN & KIWI DR	SE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
362	INT1664SW1	FIDDLELEAF LN & KIWI DR	SW	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
724	INT1631SE1	FILBERT DR & KEMPAS CT & KEMPAS WY	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
726	INT1631NE1	FILBERT DR & KEMPAS CT & KEMPAS WY	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
727	INT1631NW1	FILBERT DR & KEMPAS CT & KEMPAS WY	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
715	INT1632NW1	FILBERT DR & WAYNESBORO DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
717	INT1632SE1	FILBERT DR & WAYNESBORO DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
718	INT1632SW1	FILBERT DR & WAYNESBORO DR	SW	Yes	Yes	No	Yes	No	No	Yes	dws size out of	P5	L4	09	\$ 1,100
690	INT1573SW1	FIR LN & WAYNESBORO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
691	INT1573SE1	FIR LN & WAYNESBORO DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1861	INT1100SW1	FOREST LN & MYRTLEWOOD DR	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1864	INT1100NW1	FOREST LN & MYRTLEWOOD DR	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2081	INT723SE1	FOSTER DR & LUCCHESI LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2082	INT723SW1	FOSTER DR & LUCCHESI LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1107	INT1480NE1	FOWLER RD & GLEN HARBOR DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1109	INT1480SE1	FOWLER RD & GLEN HARBOR DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1110	INT1480SW1	FOWLER RD & GLEN HARBOR DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1113	INT1469SW1	FOWLER RD & GLEN RIDGE DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1114	INT1469SE1	FOWLER RD & GLEN RIDGE DR	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1088	INT1505NE1	FOWLER RD & JUPITER CT	NE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1089	INT1505NW1	FOWLER RD & JUPITER CT	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1091	INT1498NE1	FOWLER RD & LARKSPUR LN	NE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1093	INT1498NW1	FOWLER RD & LARKSPUR LN	NW	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1069	INT1527SW1	FOWLER RD & LUNAR DR	SW	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1070	INT1527SE1	FOWLER RD & LUNAR DR	SE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1083	INT1527NW1	FOWLER RD & LUNAR DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1084	INT1518NE1	FOWLER RD & LUPIN LN	NE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1085	INT1518NW1	FOWLER RD & LUPIN LN	NW	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
2567	INT1457NW1	FOWLER RD & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2568	INT1457NE1	FOWLER RD & MITCHELL RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2569	INT1457SE1	FOWLER RD & MITCHELL RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2570	INT1457SW1	FOWLER RD & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1075	INT1541NW1	FOWLER RD & POPPY LN	NW	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1078	INT1541NE1	FOWLER RD & POPPY LN	NE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1098	MID1732NW1	FOWLER RD & PRIVATE RD	NW	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1099	MID1732SE1	FOWLER RD & PRIVATE RD	SE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1544	INT1332NE1	FOWLER RD & ROSE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1545	INT1332SE1	FOWLER RD & ROSE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1546	INT1332NW1	FOWLER RD & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1547	INT1332SW1	FOWLER RD & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1073	INT1530NW1	FOWLER RD & SATURN CT	NW	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1074	INT1530NE1	FOWLER RD & SATURN CT	NE	Yes	Yes	No	No	No	No	Yes		P4-b	L4	08	\$ 1,100
1554	INT1434SE1	FOWLER RD & SHUSHAN DR	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1555	INT1434SW1	FOWLER RD & SHUSHAN DR	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1398	INT494NW1	FOX RIVER WY & GRANITE FALLS DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1399	INT494SW1	FOX RIVER WY & GRANITE FALLS DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1400	INT468SE1	FOX RIVER WY & RIVER SPRINGS WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1401	INT468NE1	FOX RIVER WY & RIVER SPRINGS WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2529	INT1000SW1	FREDA WY & GLENDA RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2534	INT1000NE1	FREDA WY & GLENDA RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1999	INT954SW1	FREDRICKS LN & TARBORO WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2000	INT954SE1	FREDRICKS LN & TARBORO WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2001	INT954NE1	FREDRICKS LN & TARBORO WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1311	INT1540NE1	FRIBOURG LN & MATTERHORN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1314	INT1540SW1	FRIBOURG LN & MATTERHORN WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1318	INT1538SE1	FRIBOURG LN & ZURICH LN	SE	Yes	Yes	No	Yes	No	No	No	Does not line up	P4-a	L4	08	\$ 1,100
1319	INT1538NE1	FRIBOURG LN & ZURICH LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1320	INT1538NW1	FRIBOURG LN & ZURICH LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2181	INT1218NW1	FRUITRIDGE DR & MOUNTAIN RIDGE DR	NW	Yes	No	No	No	No	No	No		P4-a	L4	08	\$ 1,100
611	INT1590SW1	GARLAND CT & WHITEHAVEN AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
612	INT1590NE1	GARLAND CT & WHITEHAVEN AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
614	INT1590NW1	GARLAND CT & WHITEHAVEN AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1431	INT1416SE1	GARRISON ST & LOUISE AVE	SE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1434	INT1416SW1	GARRISON ST & LOUISE AVE	SW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
2571	INT1456SW1	GARRISON ST & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2572	INT1456NW1	GARRISON ST & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1570	INT1232SE1	GARRISON ST & MOFFETT RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1571	INT1232NE1	GARRISON ST & MOFFETT RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1572	INT1232NW1	GARRISON ST & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1440	INT1372NW1	GARRISON ST & ORIOLE DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1441	INT1372NE1	GARRISON ST & ORIOLE DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1444	INT1337NW1	GARRISON ST & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1447	INT1337SE1	GARRISON ST & ROSE AVE	SE	Yes	Yes	No	Yes	No	No	Yes	No sidewalks connecting	P5	L2-a	09	
1449	INT1337NE1	GARRISON ST & ROSE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1450	INT1337SW1	GARRISON ST & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1436	INT1431NW1	GARRISON ST & SHUSHAN DR	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1437	INT1431NE1	GARRISON ST & SHUSHAN DR	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
922	INT607SE1	GATSBY CT & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
923	INT607NE1	GATSBY CT & SAN PEDRO AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
924	INT607SW1	GATSBY CT & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2420	INT939NW1	GENE RD & RICHARD WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2421	INT939SW1	GENE RD & RICHARD WY	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2422	INT939NE1	GENE RD & RICHARD WY	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2423	INT939SE1	GENE RD & RICHARD WY	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
904	INT648SE1	GENEVIEVE WY & GEORGEANN PL	SE	Yes	Yes	Yes	Yes	Yes	No	No		P4-a	L4	08	\$ 3,200
911	INT648SW1	GENEVIEVE WY & GEORGEANN PL	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
912	INT648NW1	GENEVIEVE WY & GEORGEANN PL	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
890	INT603NW1	GENEVIEVE WY & JORDANOLO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
891	INT603NE1	GENEVIEVE WY & JORDANOLO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
943	INT646SW1	GEORGEANN PL & HACKETT RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
944	INT646SE1	GEORGEANN PL & HACKETT RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
913	INT652NW1	GEORGEANN PL & SAN PEDRO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
914	INT652SW1	GEORGEANN PL & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
915	INT652SE1	GEORGEANN PL & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
855	INT649NE1	GEORGEANN PL & ZENA WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
856	INT649SE1	GEORGEANN PL & ZENA WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
858	INT649NW1	GEORGEANN PL & ZENA WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
141	INT1668NE1	GIANT OAK LN & NORTHERN OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
144	INT1668SE1	GIANT OAK LN & NORTHERN OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
147	INT1668SW1	GIANT OAK LN & NORTHERN OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
57	INT1667NW1	GIANT OAK LN & WILD OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
58	INT1667NE1	GIANT OAK LN & WILD OAK DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
59	INT1667SW1	GIANT OAK LN & WILD OAK DR	SW	Yes	Yes	No	Yes	No	No	Yes	DWS size not compliant	P5	L4	09	\$ 1,100
2463	INT686SE1	GIDDINGS ST & PARAMOUNT AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
2454	INT746SE1	GIDDINGS ST & PELTOLA ST	SE	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
2455	INT746SW1	GIDDINGS ST & PELTOLA ST	SW	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
2452	INT786NW1	GIDDINGS ST & RICHLAND AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
2453	INT786SW1	GIDDINGS ST & RICHLAND AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
751	INT754SE1	GIDEON WY & HUGO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
753	INT754NE1	GIDEON WY & HUGO AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
748	INT761SE1	GIDEON WY & PINK AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
749	INT761SW1	GIDEON WY & PINK AVE	SW	Yes	Yes	Yes	Yes	No	No	No		P4-a	L4	08	\$ 3,200
750	INT760NE1	GIDEON WY & PINK AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
763	INT762NW1	GIDEON WY & POSHO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
764	INT762SE1	GIDEON WY & POSHO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
684	INT1567NW1	GINKGO AVE & GINKGO CT & WAYNESBORO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
686	INT1567SW1	GINKGO AVE & GINKGO CT & WAYNESBORO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
687	INT1567NE1	GINKGO AVE & GINKGO CT & WAYNESBORO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
688	INT1567SE1	GINKGO AVE & GINKGO CT & WAYNESBORO DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
771	INT1566NW1	GINKGO AVE & POMEGRANATE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
773	INT1566SE1	GINKGO AVE & POMEGRANATE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1658	INT1320SW1	GLASGOW DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1661	INT1320SE1	GLASGOW DR	SE	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
1632	INT1261SE1	GLASGOW DR & HICKEY CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1634	INT1261SW1	GLASGOW DR & HICKEY CT	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1656	INT1316NW1	GLASGOW DR & JARED AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1657	INT1316NE1	GLASGOW DR & JARED AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1752	INT1053NW1	GLASGOW DR & KEATING CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1753	INT1053NE1	GLASGOW DR & KEATING CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1735	INT1154SW1	GLASGOW DR & LYNLEY DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1736	INT1154SE1	GLASGOW DR & LYNLEY DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1737	INT1154NE1	GLASGOW DR & LYNLEY DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1738	INT1154NW1	GLASGOW DR & LYNLEY DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1622	INT1245NE1	GLASGOW DR & MOFFETT RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1625	INT1245NW1	GLASGOW DR & MOFFETT RD	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1627	INT1245SW1	GLASGOW DR & MOFFETT RD	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1628	INT1245SE1	GLASGOW DR & MOFFETT RD	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1750	INT1093SE1	GLASGOW DR & MYRTLEWOOD DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1751	INT1093SW1	GLASGOW DR & MYRTLEWOOD DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1650	INT1295NE1	GLASGOW DR & PEACHWOOD AVE & PEACHWOOD CT	NE	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
1652	INT1295NW1	GLASGOW DR & PEACHWOOD AVE & PEACHWOOD CT	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1654	INT1295SW1	GLASGOW DR & PEACHWOOD AVE & PEACHWOOD CT	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1655	INT1295SE1	GLASGOW DR & PEACHWOOD AVE & PEACHWOOD CT	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1725	INT1215NW1	GLASGOW DR & RUNNING LN	NW	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
1726	INT1215SW1	GLASGOW DR & RUNNING LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1728	INT1215SE1	GLASGOW DR & RUNNING LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1730	INT1215NE1	GLASGOW DR & RUNNING LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1739	INT1104NW1	GLASGOW DR & SENIMI CI	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1740	INT1104NE1	GLASGOW DR & SENIMI CI	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1741	INT1104SW1	GLASGOW DR & SENIMI CI	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1743	INT1103NW1	GLASGOW DR & SENIMI CI	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1744	INT1103NE1	GLASGOW DR & SENIMI CI	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1341	INT1478NW1	GLEN FIELD LN & GLEN HARBOR DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1344	INT1478NE1	GLEN FIELD LN & GLEN HARBOR DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1348	INT1465SW1	GLEN FIELD LN & GLEN RIDGE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1350	INT1465NE1	GLEN FIELD LN & GLEN RIDGE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1353	INT1466NE1	GLEN GROVE CT & GLEN RIDGE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1355	INT1466SE1	GLEN GROVE CT & GLEN RIDGE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1361	INT1466NW1	GLEN GROVE CT & GLEN RIDGE DR	NW	Yes	Yes	No	Yes	No	No	No	Does not line up with	P4-a	L4	08	\$ 1,100
1332	INT1479NW1	GLEN HARBOR DR & GLEN PARK WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1335	INT1479SW1	GLEN HARBOR DR & GLEN PARK WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1370	INT1467NE1	GLEN MEADOW CT & GLEN RIDGE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1372	INT1467SE1	GLEN MEADOW CT & GLEN RIDGE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1375	INT1467SW1	GLEN MEADOW CT & GLEN RIDGE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1378	INT1468NE1	GLEN PARK WY & GLEN RIDGE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1379	INT1468NW1	GLEN PARK WY & GLEN RIDGE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1382	INT1468SE1	GLEN PARK WY & GLEN RIDGE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2527	INT993SW1	GLENDA RD & LINDA WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2528	INT993NW1	GLENDA RD & LINDA WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1272	INT511NW1	GLIDER CT & TWILIGHT DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1273	INT511NE1	GLIDER CT & TWILIGHT DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1275	INT511SW1	GLIDER CT & TWILIGHT DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
276	INT1669SE1	GOSSAMER WY & LA CRESTA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
277	INT1669NE1	GOSSAMER WY & LA CRESTA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
278	INT1669NW1	GOSSAMER WY & LA CRESTA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
273	INT1649SE1	GOSSAMER WY & SAN MORITZ	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
283	INT1699SE1	GOSSAMER WY & SOMERSBY LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
285	INT1699NW1	GOSSAMER WY & SOMERSBY LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
287	INT1699SW1	GOSSAMER WY & SOMERSBY LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2055	INT995NE1	GRAND CENTRAL DR & PARK WEST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2056	INT995SE1	GRAND CENTRAL DR & PARK WEST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2057	INT995SW1	GRAND CENTRAL DR & PARK WEST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2472	INT589NE1	GRAND VIEW AVE & HERNDON RD	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L2-b	04	\$ -
2473	INT589SE1	GRAND VIEW AVE & HERNDON RD	NE	No	No	No	No	No	No	No	No sidewalks,	P4-a	L2-b	04	\$ -
2464	INT687NW1	GRAND VIEW AVE & PARAMOUNT AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2465	INT687SW1	GRAND VIEW AVE & PARAMOUNT AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2466	INT687SE1	GRAND VIEW AVE & PARAMOUNT AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1389	INT496NW1	GRANITE FALLS DR & MOON RIVER WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1390	INT496SW1	GRANITE FALLS DR & MOON RIVER WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1391	INT496SE1	GRANITE FALLS DR & MOON RIVER WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1384	INT497SW1	GRANITE FALLS DR & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1385	INT497SE1	GRANITE FALLS DR & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1392	INT495NE1	GRANITE FALLS DR & TRANQUIL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1393	INT495NW1	GRANITE FALLS DR & TRANQUIL LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1394	INT495SW1	GRANITE FALLS DR & TRANQUIL LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1395	INT495SE1	GRANITE FALLS DR & TRANQUIL LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2089	INT637SE1	GREENBACK LN & LUCCHESI LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2090	INT637SW1	GREENBACK LN & LUCCHESI LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2091	INT635NW1	GREENBACK LN & VLACH WY	NW	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2182	INT1205NE1	GROVER DR & MOUNTAIN RIDGE DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2183	INT1205NW1	GROVER DR & MOUNTAIN RIDGE DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2184	INT1206SW1	GROVER DR & PINERIDGE DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2185	INT1206NW1	GROVER DR & PINERIDGE DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2186	INT1207SW1	GROVER DR & WALTER DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2187	INT1207NW1	GROVER DR & WALTER DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1784	INT1057NE1	HACKETT RD & HAROLD AVE	NE	Yes	No	No	Yes	No	No	No		P1	L2-a	01	\$ 3,200
941	INT613NW1	HACKETT RD & JEFFNELL PL	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
942	INT613NE1	HACKETT RD & JEFFNELL PL	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1174	INT431NW1	HACKETT RD & MALIK AVE	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1175	INT431NE1	HACKETT RD & MALIK AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
937	INT538SE1	HACKETT RD & MORGAN RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
938	INT538NE1	HACKETT RD & MORGAN RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
939	INT538NW1	HACKETT RD & MORGAN RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
940	INT538SW1	HACKETT RD & MORGAN RD	SW	Yes	Yes	No	Yes	No	No	Yes	No sidewalk behind cr	P5	L4	09	
1843	INT916NE1	HACKETT RD & PEOPLES LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1844	INT916NW1	HACKETT RD & PEOPLES LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1787	INT1080SW1	HACKETT RD & RAILROAD AVE	SW	Yes	No	No	Yes	No	No	No		P1	L2-a	01	\$ 3,200
774	INT677NW1	HACKETT RD & SANKO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
775	INT677NE1	HACKETT RD & SANKO AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
776	INT677SW1	HACKETT RD & SANKO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
777	INT696SW1	HACKETT RD & SODA CANYON DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
778	INT696SE1	HACKETT RD & SODA CANYON DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1813	INT1098SW1	HALE ALOHA WY & MYRTLEWOOD DR	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1819	INT1098NW1	HALE ALOHA WY & MYRTLEWOOD DR	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1816	INT1056SE1	HALE ALOHA WY & PIKAKE CT	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1818	INT1056SW1	HALE ALOHA WY & PIKAKE CT	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1792	INT1074SW1	HAROLD AVE & PINE ST	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1794	INT1074NW1	HAROLD AVE & PINE ST	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1642	MID1742NW1	HARVESTWOOD CI	NW	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1644	MID1743NE1	HARVESTWOOD CI	NE	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1645	INT828SW1	HARVESTWOOD CI & SOUTHWOOD CT & SOUTHWOOD DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1646	INT828SE1	HARVESTWOOD CI & SOUTHWOOD CT & SOUTHWOOD DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1648	INT828NW1	HARVESTWOOD CI & SOUTHWOOD CT & SOUTHWOOD DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1649	INT828NE1	HARVESTWOOD CI & SOUTHWOOD CT & SOUTHWOOD DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1638	INT862SE1	HARVESTWOOD CI & SOUTHWOOD DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1640	INT862SW1	HARVESTWOOD CI & SOUTHWOOD DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
828	INT710SE1	HAVENWOOD WY & INLAND LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
824	INT709SE1	HAVENWOOD WY & MARAZZI LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
826	INT709NE1	HAVENWOOD WY & MARAZZI LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
827	INT709NW1	HAVENWOOD WY & MARAZZI LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
819	INT708SW1	HAVENWOOD WY & SUNGATE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
821	INT708NW1	HAVENWOOD WY & SUNGATE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
822	INT708NE1	HAVENWOOD WY & SUNGATE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1668	INT771SW1	HEATH WY & SUNCREST DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1669	INT771NW1	HEATH WY & SUNCREST DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1670	INT752SE1	HEATH WY & WADE DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1672	INT752SW1	HEATH WY & WADE DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1173	INT1506SW1	HEATHER LN & LOTUS CT	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1177	INT1506SE1	HEATHER LN & LOTUS CT	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1178	INT1519SW1	HEATHER LN & LUPIN LN	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1181	INT1519SE1	HEATHER LN & LUPIN LN	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1184	INT1531SW1	HEATHER LN & ORCHID CT	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1188	INT1531SE1	HEATHER LN & ORCHID CT	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1189	INT1543SW1	HEATHER LN & POPPY LN	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
953	INT842SW1	HEAVENLY WY & MCCORD WY	SW	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
657	INT1609NE1	HELEN PERRY RD & LIQUIDAMBAR LN	NE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
658	INT1609NW1	HELEN PERRY RD & LIQUIDAMBAR LN	NW	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
659	INT1609SW1	HELEN PERRY RD & LIQUIDAMBAR LN	SW	No	Yes	No	No	No	No	No	School crosswalk, no	P1	L2-a	01	\$ 3,200
666	INT1587NE1	HELEN PERRY RD & MONTEREY PINE AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
667	INT1587NW1	HELEN PERRY RD & MONTEREY PINE AVE	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
668	INT1587SE1	HELEN PERRY RD & MONTEREY PINE AVE	SE	No	Yes	No	No	No	No	No	School crosswalk, no	P1	L2-a	01	\$ 3,200
241	INT1687SE1	HELEN PERRY RD & TARAMEA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
243	INT1687NE1	HELEN PERRY RD & TARAMEA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
244	INT1687SW1	HELEN PERRY RD & TARAMEA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
245	INT1662NW1	HELEN PERRY RD & TOSCANA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
246	INT1662SW1	HELEN PERRY RD & TOSCANA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
247	INT1662SE1	HELEN PERRY RD & TOSCANA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
653	INT1623SE1	HELEN PERRY RD & YOLANDA ST	SE	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
654	INT1623SW1	HELEN PERRY RD & YOLANDA ST	SW	Yes	Yes	No	No	No	No	Yes	DWS not in compliance	P1	L2-a	01	\$ 1,100
1562	INT1236NW1	HENRY AVE & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1563	INT1236SW1	HENRY AVE & MOFFETT RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
2362	INT1198NE1	HENRY AVE & WALLACE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2363	INT1198NW1	HENRY AVE & WALLACE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2283	INT546SE1	HERNDON AVE & HERNDON RD & JOYCE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
2284	INT546NE1	HERNDON AVE & HERNDON RD & JOYCE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1199	INT544SE1	HERNDON CT & HERNDON RD	SE	No	Yes	No	No	No	No	No		P2	L5	05	\$ 3,200
2099	INT557SE1	HERNDON RD & LUCCHESI LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2100	INT557NE1	HERNDON RD & LUCCHESI LN	NE	Yes	Yes	No	No	No	No	No	No ramp on west side where cross walk leads	P4-a	L4	08	\$ 1,100
2303	INT549SE1	HERNDON RD & NADINE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2543	INT878NE1	HERNDON RD & PLOUTZ RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2544	INT878SE1	HERNDON RD & PLOUTZ RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2586	INT783SE1	HERNDON RD & RICHLAND AVE	SE	No	Yes	No	No	No	No	No		P2	L2-b	02	\$ 3,200
2587	INT783NW1	HERNDON RD & RICHLAND AVE	NW	No	Yes	No	No	No	No	No		P2	L2-b	02	\$ 3,200
2535	INT932NE1	HERNDON WY & PANERO WY	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2536	INT932NW1	HERNDON WY & PANERO WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2537	INT932SE1	HERNDON WY & PANERO WY	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
563	INT1562NW1	HIDDEN OAK CT & HIDDEN OAK LN & SOUTHERN OAK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
564	INT1562NE1	HIDDEN OAK CT & HIDDEN OAK LN & SOUTHERN OAK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
565	INT1562SE1	HIDDEN OAK CT & HIDDEN OAK LN & SOUTHERN OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
577	INT1565NE1	HIDDEN OAK LN & VALLEY OAK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
578	INT1565SE1	HIDDEN OAK LN & VALLEY OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
579	INT1565SW1	HIDDEN OAK LN & VALLEY OAK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
566	INT1564NW1	HIDDEN OAK LN & WHISPERING OAK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
570	INT1564NE1	HIDDEN OAK LN & WHISPERING OAK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
571	INT1564SE1	HIDDEN OAK LN & WHISPERING OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
567	INT1563NW1	HIDDEN OAK LN & WILD OAK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
568	INT1563NE1	HIDDEN OAK LN & WILD OAK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
569	INT1563SE1	HIDDEN OAK LN & WILD OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1115	INT437NE1	HIGHLANDS PARK DR & MALIK AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1116	INT437SE1	HIGHLANDS PARK DR & MALIK AVE	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1108	INT498NW1	HIGHLANDS PARK DR & STARBOARD WY	NW	Yes	Yes	No	Yes	No	No	No	Crossing ramp part of	P4-a	L4	08	\$ 1,100
1828	INT1176NW1	HILO LN & KAILUA WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1827	INT1131NE1	HILO LN & LEILANI WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2522	INT968NW1	HOLLISTER ST & LOIS WY	NW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2523	INT968NE1	HOLLISTER ST & LOIS WY	NE	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2524	INT968SW1	HOLLISTER ST & LOIS WY	SW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2525	INT968SE1	HOLLISTER ST & LOIS WY	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1558	INT1430SE1	HOYLE CT & SHUSHAN DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1559	INT1430SW1	HOYLE CT & SHUSHAN DR	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1506	INT1399NE1	HUMMINGBIRD DR & ROBIN DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1532	INT1399NW1	HUMMINGBIRD DR & ROBIN DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1523	INT1346SE1	HUMMINGBIRD DR & ROSE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1524	INT1346NE1	HUMMINGBIRD DR & ROSE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1525	INT1346NW1	HUMMINGBIRD DR & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
830	INT756SW1	INLAND CT & INLAND LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
831	INT756SE1	INLAND CT & INLAND LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
833	INT756NE1	INLAND CT & INLAND LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	COST EST (\$)
1415	INT424SW1	JANICE CT & KATIE LN & SEBASTIAN WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1416	INT424SE1	JANICE CT & KATIE LN & SEBASTIAN WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1418	INT424NW1	JANICE CT & KATIE LN & SEBASTIAN WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1676	INT769NW1	JANNI WY & SUNCREST DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1677	INT769SE1	JANNI WY & SUNCREST DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1679	INT769NE1	JANNI WY & SUNCREST DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1673	INT751NE1	JANNI WY & WADE DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1674	INT751SE1	JANNI WY & WADE DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1671	INT1317SE1	JARED AVE & MC NEIL DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1059	INT614SE1	JEFFNELL PL & THOMASNELL WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1060	INT614SW1	JEFFNELL PL & THOMASNELL WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1061	INT614NW1	JEFFNELL PL & THOMASNELL WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1958	INT850NW1	JENNER CI & SAUSALITO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1959	INT850SW1	JENNER CI & SAUSALITO WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1960	INT850SE1	JENNER CI & SAUSALITO WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1620	INT930SE1	JOPPA LN & NIMROOD DR	SE	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 3,200
893	INT604SW1	JORDANOLO DR & VANESSA CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
894	INT604NW1	JORDANOLO DR & VANESSA CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
896	INT604SE1	JORDANOLO DR & VANESSA CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1693	INT1425NW1	JOSEPH LN & ROSEWOOD AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1694	INT1425NE1	JOSEPH LN & ROSEWOOD AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1417	INT1414SE1	JOY AVE & LOUISE AVE	SE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
1420	INT1414NE1	JOY AVE & LOUISE AVE	NE	No	No	No	No	No	No	No		P4-a	L4	08	
1422	INT1414SW1	JOY AVE & LOUISE AVE	SW	No	No	No	No	No	No	No		P4-a	L4	08	
1423	INT1414NW1	JOY AVE & LOUISE AVE	NW	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	
2577	INT1454SW1	JOY AVE & MITCHELL RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2578	INT1454NW1	JOY AVE & MITCHELL RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1459	INT1341NE1	JOY AVE & ROSE AVE	NE	No	No	No	No	No	No	No	No sidewalks	P4-a	L4	08	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1461	INT1341SE1	JOY AVE & ROSE AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1463	INT1341SW1	JOY AVE & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1465	INT1341NW1	JOY AVE & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1292	INT1507SW1	JURA LN & ST GOTTHARD WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1293	INT1507NE1	JURA LN & ST GOTTHARD WY	NE	Yes	Yes	No	Yes	No	No	No	Ramp cracking	P4-a	L4	08	\$ 1,100
1294	INT1508SE1	JURA LN & ZURICH LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1295	INT1508NE1	JURA LN & ZURICH LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1296	INT1508SW1	JURA LN & ZURICH LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1833	INT1177SW1	KAILUA WY & KONA LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1835	INT1177NW1	KAILUA WY & KONA LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1838	INT1178SW1	KAILUA WY & MAUNA KEA DR	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1840	INT1178SE1	KAILUA WY & MAUNA KEA DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1051	INT654NW1	KARENELL WY & LARRYNELLE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1052	INT654SW1	KARENELL WY & LARRYNELLE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1054	INT654SE1	KARENELL WY & LARRYNELLE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
428	INT1264NW1	KAY ST & MAGNOLIA ST	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
429	INT1264SW1	KAY ST & MAGNOLIA ST	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
430	INT1264SE1	KAY ST & MAGNOLIA ST	SE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
431	INT1264NE1	KAY ST & MAGNOLIA ST	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
647	INT1262NW1	KAY ST & ROEDING RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
648	INT1262NE1	KAY ST & ROEDING RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
596	INT1263NE1	KAY ST & STANDFORD AVE	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
597	INT1263NW1	KAY ST & STANDFORD AVE	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
729	INT1610NE1	KEMPAS WY & LIQUIDAMBAR LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
730	INT1610SE1	KEMPAS WY & LIQUIDAMBAR LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1141	INT341SE1	KIMBALL HILL DR & WILLOW LAKE WY	SE	Yes	Yes	No	Yes	No	No	No	ramp is part of	P4-a	L4	08	\$ 1,100
995	INT658SW1	KINSER RD & LARRYNELLE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
996	INT658NE1	KINSER RD & LARRYNELLE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1764	INT910SW1	KINSER RD & MC KITTRICK CT	SW	Yes	Yes	No	No	No	No	No	No SW leading into ramp	P4-a	L5	08	\$ 1,100
1765	INT910SE1	KINSER RD & MC KITTRICK CT	SE	Yes	Yes	No	No	No	No	No	No SW leading into ramp	P4-a	L5	08	\$ 1,100
956	INT848NW1	KINSER RD & MCCORD WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
958	INT848SW1	KINSER RD & MCCORD WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
959	INT848SE1	KINSER RD & MCCORD WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
960	INT848NE1	KINSER RD & MCCORD WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1009	INT543NE1	KINSER RD & MORGAN RD	NE	Yes	Yes	No	Yes	No	No	No	Telephone pole in ramp. No SW coming into ramp	P4-a	L4	08	\$ 1,100
1010	INT543SE1	KINSER RD & MORGAN RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
987	INT721NW1	KINSER RD & PARK ROYAL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
988	INT721SE1	KINSER RD & PARK ROYAL DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
989	INT721SW1	KINSER RD & PARK ROYAL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
981	MID1744NE1	KINSER RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
982	MID1744NW1	KINSER RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
985	MID1745NW1	KINSER RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
986	MID1745NE1	KINSER RD & PRIVATE RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
999	INT661NE1	KINSER RD & TWIN BRIDGES DR	NE	No	Yes	No	No	No	No	No	No sidewalk at this	P2	L2-b	02	\$ 3,200
998	INT661SW1	KINSER RD & TWIN BRIDGES DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1002	INT595SE1	KINSER RD & VALENTINA WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1003	INT595SW1	KINSER RD & VALENTINA WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
968	INT829SE1	KINSER RD & WILLETTS WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
970	INT829SW1	KINSER RD & WILLETTS WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
340	INT1677SW1	KIWI DR & MANDEVILLA LN	SW	Yes	Yes	No	No	No	Yes	No		P3	L4	07	\$ 5,600
344	INT1677NW1	KIWI DR & MANDEVILLA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
346	INT1677NE1	KIWI DR & MANDEVILLA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
330	INT1690NW1	KIWI DR & WATER LILY LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
331	INT1690NE1	KIWI DR & WATER LILY LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
332	INT1690SE1	KIWI DR & WATER LILY LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1825	INT1129NE1	KONA LN & LEILANI WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1826	INT1129SE1	KONA LN & LEILANI WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
161	INT1473NE1	KONING LN & MULLEN WY	NE	Yes	No	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
297	INT1670NE1	LA CRESTA LN & PODOCARPU DR & PODOCARPUS DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
298	INT1670SE1	LA CRESTA LN & PODOCARPU DR & PODOCARPUS DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
299	INT1670SW1	LA CRESTA LN & PODOCARPU DR & PODOCARPUS DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
815	INT1595NW1	LARIAN WY & MONTEREY PINE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
816	INT1595SW1	LARIAN WY & MONTEREY PINE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
817	INT1595NE1	LARIAN WY & MONTEREY PINE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
818	INT1595SE1	LARIAN WY & MONTEREY PINE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
798	INT1633NW1	LARIAN WY & MORELLO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
800	INT1633SW1	LARIAN WY & MORELLO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
803	INT1633SE1	LARIAN WY & MORELLO DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
804	INT1633NE1	LARIAN WY & MORELLO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
885	INT1569SW1	LARIAN WY & VANDALAY DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
889	INT1569NE1	LARIAN WY & VANDALAY DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
892	INT1569SE1	LARIAN WY & VANDALAY DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
382	INT1309SE1	LARISA LN & VEDA DR	SE	No	Yes	No	No	No	No	No		P1	L2-a	01	\$ 3,200
383	INT1309SW1	LARISA LN & VEDA DR	SW	No	Yes	No	No	No	No	No		P1	L2-a	01	\$ 3,200
2093	INT597SW1	LARMUSEAU LN & LUCCHESI LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2094	INT597SE1	LARMUSEAU LN & LUCCHESI LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2092	INT598NE1	LARMUSEAU LN & VLACH WY	NE	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1042	INT656NW1	LARRYNELL DR & MARYNELL DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1043	INT656SW1	LARRYNELL DR & MARYNELL DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1044	INT656SE1	LARRYNELL DR & MARYNELL DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1047	INT655NW1	LARRYNELL DR & PAULANELL CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1048	INT655SW1	LARRYNELL DR & PAULANELL CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1049	INT655SE1	LARRYNELL DR & PAULANELL CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1055	INT653NW1	LARRYNELL DR & THOMASNELL WY	NW	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
2067	INT697NW1	LARSEN DR & WOODWORTH AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2068	INT697NE1	LARSEN DR & WOODWORTH AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1841	INT917SE1	LAURELWOOD CT & PEOPLES LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1842	INT917SW1	LAURELWOOD CT & PEOPLES LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1793	INT1136SE1	LAVON LN & LINDEN DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1795	INT1136SW1	LAVON LN & LINDEN DR	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1788	INT1167SE1	LAVON LN & LYNLEY DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1789	INT1167SW1	LAVON LN & LYNLEY DR	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1790	INT1166NE1	LAVON LN & LYNLEY DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1791	INT1166NW1	LAVON LN & LYNLEY DR	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1754	INT1094SW1	LAVON LN & MYRTLEWOOD DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1755	INT1094SE1	LAVON LN & MYRTLEWOOD DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1756	INT1094NE1	LAVON LN & MYRTLEWOOD DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1757	INT1094NW1	LAVON LN & MYRTLEWOOD DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1785	INT1214SW1	LAVON LN & RUNNING LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1786	INT1214NW1	LAVON LN & RUNNING LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
845	INT692NW1	LEAVITT PEAK CT & SODA CANYON DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
847	INT692SW1	LEAVITT PEAK CT & SODA CANYON DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
848	INT692SE1	LEAVITT PEAK CT & SODA CANYON DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2159	INT1092NE1	LEESEME LN & PAYNE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2160	INT1092SE1	LEESEME LN & PAYNE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2164	INT1078NE1	LEHI AVE & PAYNE AVE	NE	Yes	Yes	No	Yes	No	No	No	Leads to no other ramps	P4-a	L4	08	\$ 1,100
1823	INT1127NE1	LEILANI WY & MAUNA KEA DR	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1824	INT1127SE1	LEILANI WY & MAUNA KEA DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1820	INT1128SE1	LEILANI WY & MAUNA LOA DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1821	INT1128SW1	LEILANI WY & MAUNA LOA DR	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1564	INT1235NW1	LESLIE AVE & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1565	INT1235SW1	LESLIE AVE & MOFFETT RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
1396	INT513NE1	LEXAR DR & TRANQUIL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1397	INT513NW1	LEXAR DR & TRANQUIL LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
980	INT1521NW1	LINDSAY WY & LUNAR DR	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
983	INT1521NE1	LINDSAY WY & LUNAR DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
984	INT1521SE1	LINDSAY WY & LUNAR DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
739	INT1613NW1	LIQUIDAMBAR LN & MACADAMIA LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
740	INT1613NE1	LIQUIDAMBAR LN & MACADAMIA LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
742	INT1613SW1	LIQUIDAMBAR LN & MACADAMIA LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
744	INT1613SE1	LIQUIDAMBAR LN & MACADAMIA LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
745	INT1618SE1	LIQUIDAMBAR LN & POMEGRANATE AVE	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
746	INT1618NE1	LIQUIDAMBAR LN & POMEGRANATE AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
747	INT1618SW1	LIQUIDAMBAR LN & POMEGRANATE AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
706	INT1611NW1	LIQUIDAMBAR LN & WAYNESBORO DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
707	INT1611NE1	LIQUIDAMBAR LN & WAYNESBORO DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
709	INT1611SW1	LIQUIDAMBAR LN & WAYNESBORO DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
711	INT1611SE1	LIQUIDAMBAR LN & WAYNESBORO DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2415	INT964NE1	LOIS WY & RICHARD WY	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2417	INT964NW1	LOIS WY & RICHARD WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2418	INT964SW1	LOIS WY & RICHARD WY	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2419	INT964SE1	LOIS WY & RICHARD WY	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2518	INT967NW1	LOIS WY & SEQUOIA ST	NW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2519	INT967NE1	LOIS WY & SEQUOIA ST	NE	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2520	INT967SW1	LOIS WY & SEQUOIA ST	SW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2521	INT967SE1	LOIS WY & SEQUOIA ST	SE	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
1689	INT1376NW1	LORETTA LN & ROSEWOOD AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1690	INT1376NE1	LORETTA LN & ROSEWOOD AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
607	INT1598NE1	LORING CT & WHITEHAVEN AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
610	INT1598NW1	LORING CT & WHITEHAVEN AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2085	INT671NE1	LUCCHESI LN & MUSICK AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2086	INT671SE1	LUCCHESI LN & MUSICK AVE	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2087	INT671SW1	LUCCHESI LN & MUSICK AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2088	INT671NW1	LUCCHESI LN & MUSICK AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2097	INT584SE1	LUCCHESI LN & WESLEY DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2098	INT584SW1	LUCCHESI LN & WESLEY DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1274	INT1520NW1	LUGANO CT & RHONE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1276	INT1520NE1	LUGANO CT & RHONE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1045	INT1523NE1	LUNAR DR & MOONVIEW DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1046	INT1523NW1	LUNAR DR & MOONVIEW DR	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1050	INT1523SW1	LUNAR DR & MOONVIEW DR	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1053	INT1523SE1	LUNAR DR & MOONVIEW DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1058	INT1525SE1	LUNAR DR & PISCES WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1062	INT1525SW1	LUNAR DR & PISCES WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1064	INT1525NW1	LUNAR DR & PISCES WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
955	INT1516NE1	LUNAR DR & PUMA WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
957	INT1516NW1	LUNAR DR & PUMA WY	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
961	INT1516SW1	LUNAR DR & PUMA WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
962	INT1516SE1	LUNAR DR & PUMA WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1056	INT1524NW1	LUNAR DR & SAGITTARIUS AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1057	INT1524SW1	LUNAR DR & SAGITTARIUS AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
977	INT1517NW1	LUNAR DR & TRINA LN	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
978	INT1517SW1	LUNAR DR & TRINA LN	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
979	INT1517NE1	LUNAR DR & TRINA LN	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1023	INT1526NE1	LUNAR DR & URANUS DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1026	INT1526NW1	LUNAR DR & URANUS DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1027	INT1526SE1	LUNAR DR & URANUS DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1029	INT1526SW1	LUNAR DR & URANUS DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1734	INT1155SE1	LYNLEY DR & MARGUERITE WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
752	INT1591SW1	MACADAMIA LN & MONTEREY PINE AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
754	INT1591SE1	MACADAMIA LN & MONTEREY PINE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
755	INT1591NW1	MACADAMIA LN & MONTEREY PINE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
756	INT1591NE1	MACADAMIA LN & MONTEREY PINE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1883	INT810SW1	MAGIC LN & RICHLAND AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1884	INT810NW1	MAGIC LN & RICHLAND AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
414	INT1364NW1	MAGNOLIA ST & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
415	INT1364SW1	MAGNOLIA ST & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2599	INT1364E1	MAGNOLIA ST & ROSE AVE	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
1224	MID1753NE1	MALIK AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1225	MID1753NW1	MALIK AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1229	INT418SW1	MALIK AVE & POMPEII LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1231	INT418SE1	MALIK AVE & POMPEII LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1232	INT418NE1	MALIK AVE & POMPEII LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1226	INT410NW1	MALIK AVE & SUNDALE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1227	INT410NE1	MALIK AVE & SUNDALE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1260	INT441NE1	MALIK AVE & TWILIGHT DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1261	INT441SE1	MALIK AVE & TWILIGHT DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1629	INT907NE1	MANASSAS CT & WOODVIEW DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1630	INT907SE1	MANASSAS CT & WOODVIEW DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2441	INT900SE1	MANNY CT & MANNY LN	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2442	INT900SW1	MANNY CT & MANNY LN	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2443	INT900NW1	MANNY CT & MANNY LN	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2411	INT988NW1	MARGARET WY & RICHARD WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2412	INT988NE1	MARGARET WY & RICHARD WY	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2413	INT988SE1	MARGARET WY & RICHARD WY	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2414	INT988SW1	MARGARET WY & RICHARD WY	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1732	INT1216SW1	MARGUERITE WY & RUNNING LN	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1142	INT375NW1	MARSHFIELD LN & WILLOW LAKE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1143	INT375NE1	MARSHFIELD LN & WILLOW LAKE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1072	INT620SE1	MARYNELL DR & ROBNELL WY	SE	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1605	INT1240NW1	MAUNA KEA DR & MOFFETT RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1606	INT1240SW1	MAUNA KEA DR & MOFFETT RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1608	INT1240NE1	MAUNA KEA DR & MOFFETT RD	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1845	INT1194NE1	MAUNA KEA DR & WALLACE AVE	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1847	INT1194NW1	MAUNA KEA DR & WALLACE AVE	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1848	INT1194SE1	MAUNA KEA DR & WALLACE AVE	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1850	INT1194SW1	MAUNA KEA DR & WALLACE AVE	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1809	INT1097SW1	MAUNA LOA DR & MYRTLEWOOD DR	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1810	INT1097SE1	MAUNA LOA DR & MYRTLEWOOD DR	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1811	INT1097NE1	MAUNA LOA DR & MYRTLEWOOD DR	NE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1812	INT1097NW1	MAUNA LOA DR & MYRTLEWOOD DR	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
2613	INT514NW1	MAXIM DR & POINT GREY RD	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1100	INT514NE1	MAXIM DR & POINT GREY RD	NE	Yes	Yes	No	Yes	No	No	Yes	DWS size out of	P5	L4	09	\$ 1,100
1101	INT525SW1	MAXIM DR & SARIYA WY	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1102	INT525NW1	MAXIM DR & SARIYA WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
627	INT1608SE1	MCINTOSH AVE & PARTRIDGE ST	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2611	INT1608SW1	MCINTOSH AVE & PARTRIDGE ST	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
628	INT1619SE1	MCINTOSH AVE & YOLANDA ST	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
629	INT1619NW1	MCINTOSH AVE & YOLANDA ST	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L2-b	06	\$ 1,100
2240	INT1259NW1	MCKNIGHT CT & MCKNIGHT WY & RIVERPARK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2241	INT1259NE1	MCKNIGHT CT & MCKNIGHT WY & RIVERPARK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2242	INT1259SE1	MCKNIGHT CT & MCKNIGHT WY & RIVERPARK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2243	INT1259SW1	MCKNIGHT CT & MCKNIGHT WY & RIVERPARK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2244	INT1258NE1	MCKNIGHT WY & RIVER VALLEY CI	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2245	INT1258SW1	MCKNIGHT WY & RIVER VALLEY CI	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2516	INT936NE1	MEMORIAL DR & SEQUOIA ST	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1907	INT922NW1	MERLOT DR & STONUM RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1908	INT922SW1	MERLOT DR & STONUM RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1037	MID1730NE1	MILKY WY	NE	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1038	MID1729SW1	MILKY WY	SW	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1039	INT1544NE1	MILKY WY & MOONVIEW DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1041	INT1544NW1	MILKY WY & MOONVIEW DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1032	INT1532SW1	MILKY WY & URANUS DR	SW	Yes	Yes	No	No	No	No	No	ramp is part of	P4-a	L4	08	\$ 1,100
2111	INT1153NW1	MILLCREEK CT & MILLCREEK DR & RIVER RAFT CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2112	INT1153SW1	MILLCREEK CT & MILLCREEK DR & RIVER RAFT CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2113	INT1153NE1	MILLCREEK CT & MILLCREEK DR & RIVER RAFT CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2105	INT1091SW1	MILLCREEK DR & OAK GROVE RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2106	INT1091SE1	MILLCREEK DR & OAK GROVE RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2107	INT1091NW1	MILLCREEK DR & OAK GROVE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1651	INT855NW1	MISSIONWOOD CT & SOUTHWOOD DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1653	INT855NE1	MISSIONWOOD CT & SOUTHWOOD DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2277	INT1462SW1	MITCHELL RD & NICHOLAS WY	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2278	INT1462NW1	MITCHELL RD & NICHOLAS WY	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
177	MID1734SW1	MITCHELL RD & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	Yes	Institute of Learning	P5	L3	09	
178	MID1734SW2	MITCHELL RD & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	Yes	Institute of Learning	P5	L3	09	
180	MID1734NW1	MITCHELL RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	Yes	Institute of Learning	P5	L3	09	
181	MID1734NW2	MITCHELL RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	Yes	Institute of Learning	P5	L3	09	
2341	INT1463SW1	MITCHELL RD & RIVER RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
2343	INT1463NW1	MITCHELL RD & RIVER RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
167	INT1451SE1	MITCHELL RD & ROEDING RD	SE	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
169	INT1451NW1	MITCHELL RD & ROEDING RD	NW	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
170	INT1451SW1	MITCHELL RD & ROEDING RD	SW	No	Yes	No	No	No	No	No		P2	L3	03	\$ 3,200
166	INT1451NE1	MITCHELL RD & ROEDING RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L3	06	\$ 1,100
1697	INT1458NW1	MITCHELL RD & ROSEWOOD AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1698	INT1458SW1	MITCHELL RD & ROSEWOOD AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
1534	INT1398SW1	MOCKINGBIRD DR & ROBIN DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1542	INT1347SE1	MOCKINGBIRD DR & ROSE AVE	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1543	INT1347NE1	MOCKINGBIRD DR & ROSE AVE	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1955	INT901NW1	MOET WY & MONDAVI DR	NW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1619	INT1243SE1	MOFFETT RD & PARKLANE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1621	INT1243NE1	MOFFETT RD & PARKLANE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1612	INT1241SE1	MOFFETT RD & PARKWAY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1614	INT1241NE1	MOFFETT RD & PARKWAY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2140	INT1251NE1	MOFFETT RD & PAYNE AVE & RIVERVIEW	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2142	INT1251SW1	MOFFETT RD & PAYNE AVE & RIVERVIEW	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2143	INT1251NW1	MOFFETT RD & PAYNE AVE & RIVERVIEW	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2141	INT1251SE1	MOFFETT RD & PAYNE AVE & RIVERVIEW	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1597	INT1239NW1	MOFFETT RD & PLUMERIA CT	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1598	INT1239SW2	MOFFETT RD & PLUMERIA CT	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1601	INT1239SW1	MOFFETT RD & PLUMERIA CT	SW	Yes	Yes	No	Yes	No	No	Yes	Crossing for school	P5	L2-b	09	
1602	INT1239SE1	MOFFETT RD & PLUMERIA CT	SE	Yes	Yes	No	Yes	No	No	Yes	Crossing for school	P5	L2-b	09	
2273	INT1246NE1	MOFFETT RD & RIVER CREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2274	INT1246SE1	MOFFETT RD & RIVER CREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2137	INT1254SW1	MOFFETT RD & RIVER RD	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
2136	INT1254SE1	MOFFETT RD & RIVER RD	SE	Yes	Yes	No	Yes	No	No	No	Crosswalk from this ramp leads to infill at	P4-a	L4	08	\$ 1,100
2138	INT1253NE1	MOFFETT RD & RIVERBEND DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2139	INT1253SE1	MOFFETT RD & RIVERBEND DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2238	INT1247NE1	MOFFETT RD & RIVERPARK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2239	INT1247SE1	MOFFETT RD & RIVERPARK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1568	INT1233NW1	MOFFETT RD & THOMAS AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1569	INT1233SW1	MOFFETT RD & THOMAS AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1687	INT1356NW1	MOLLY LN & ROSEWOOD AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1688	INT1356NE1	MOLLY LN & ROSEWOOD AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1953	INT902SE1	MONDAVI DR & SAUVIGNON DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1954	INT902SW1	MONDAVI DR & SAUVIGNON DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2444	INT889SE1	MONICA CT & MONICA LN	SE	Yes	Yes	No	Yes	No	No	No	DWS needs to be	P4-a	L4	08	\$ 1,100
2445	INT889NE1	MONICA CT & MONICA LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2446	INT889SW1	MONICA CT & MONICA LN	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2024	INT984NE1	MONIQUE CT & TUOLUMNE BEND LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2025	INT984NW1	MONIQUE CT & TUOLUMNE BEND LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2026	INT984SW1	MONIQUE CT & TUOLUMNE BEND LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
757	INT1593SW1	MONTEREY PINE AVE & POMEGRANATE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
760	INT1593SE1	MONTEREY PINE AVE & POMEGRANATE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
761	INT1593NW1	MONTEREY PINE AVE & POMEGRANATE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
762	INT1593NE1	MONTEREY PINE AVE & POMEGRANATE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
820	INT1596NW1	MONTEREY PINE AVE & SKEENA AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
823	INT1596SW1	MONTEREY PINE AVE & SKEENA AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
825	INT1596SE1	MONTEREY PINE AVE & SKEENA AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
692	INT1589NW1	MONTEREY PINE AVE & WAYNESBORO DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
693	INT1589NE1	MONTEREY PINE AVE & WAYNESBORO DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
694	INT1589SW1	MONTEREY PINE AVE & WAYNESBORO DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
695	INT1589SE1	MONTEREY PINE AVE & WAYNESBORO DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
840	INT1601NW1	MONTMORENCY CT & VALERA DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
841	INT1601NE1	MONTMORENCY CT & VALERA DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
846	INT1601SW1	MONTMORENCY CT & VALERA DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1249	MID1751NE1	MOONLIGHT DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1250	MID1751SE1	MOONLIGHT DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1252	MID1752SW1	MOONLIGHT DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1253	MID1752NW1	MOONLIGHT DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1244	INT477NW1	MOONLIGHT DR & SKYBRITE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1245	INT477NE1	MOONLIGHT DR & SKYBRITE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1247	INT477SW1	MOONLIGHT DR & SKYBRITE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1233	INT419SE1	MOONLIGHT DR & SUNDALE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1234	INT419NE1	MOONLIGHT DR & SUNDALE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1235	INT419NW1	MOONLIGHT DR & SUNDALE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1279	INT524SW1	MOONLIGHT DR & WISHING WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1280	INT524NE1	MOONLIGHT DR & WISHING WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1008	INT1496SE1	MOONVIEW DR & VENUS DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1011	INT1496NE1	MOONVIEW DR & VENUS DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
829	INT1624SE1	MORELLO DR & SKEENA AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
832	INT1624SW1	MORELLO DR & SKEENA AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
834	INT1624NW1	MORELLO DR & SKEENA AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
837	INT1612NW1	MORELLO DR & VALERA DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
839	INT1612SW1	MORELLO DR & VALERA DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1702	INT532NW1	MORGAN RD & PARTEE LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1703	INT532SW1	MORGAN RD & PARTEE LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1699	MID1754NW1	MORGAN RD & PRIVATE RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
1700	MID1754SW1	MORGAN RD & PRIVATE RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L5	08	\$ 1,100
932	INT537SE1	MORGAN RD & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
934	INT537NE1	MORGAN RD & SAN PEDRO AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
935	INT537NW1	MORGAN RD & SAN PEDRO AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
936	INT537SW1	MORGAN RD & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1464	INT534SE1	MORGAN RD & SERENE LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1467	INT534NE1	MORGAN RD & SERENE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
880	INT536SE1	MORGAN RD & TASHA DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
881	INT536NE1	MORGAN RD & TASHA DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1462	INT533NW1	MORGAN RD & TRANQUIL LN	NW	Yes	Yes	No	Yes	No	Yes	No	Ramp leads into SW infill	P3	L4	07	\$ 5,600
1458	INT533SE1	MORGAN RD & TRANQUIL LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1460	INT533NE1	MORGAN RD & TRANQUIL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2190	INT1144NE1	MOUNTAIN RIDGE DR & OAK RIDGE CT & OAK RIDGE DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2191	INT1144SE1	MOUNTAIN RIDGE DR & OAK RIDGE CT & OAK RIDGE DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
162	INT1474SE1	MULLEN WY & ROEDING RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
163	INT1474SW1	MULLEN WY & ROEDING RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1986	INT822SE1	MUNCHKIN DR & WOODWORTH AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1987	INT822SW1	MUNCHKIN DR & WOODWORTH AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1988	INT822NE1	MUNCHKIN DR & WOODWORTH AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1989	INT821NE1	MUNCHKIN DR & YELLOW BRICK RD	NE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 1,100
2069	INT663NE1	MUSICK AVE & WOODWORTH AVE	NE	Yes	Yes	No	No	No	No	No	Ramp leads to infill on	P4-a	L4	08	\$ 1,100
1758	INT1095SW1	MYRTLEWOOD DR & RIDGEWAY CT & RIDGEWAY DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1759	INT1095SE1	MYRTLEWOOD DR & RIDGEWAY CT & RIDGEWAY DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1761	INT1095NE1	MYRTLEWOOD DR & RIDGEWAY CT & RIDGEWAY DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1763	INT1095NW1	MYRTLEWOOD DR & RIDGEWAY CT & RIDGEWAY DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1972	INT805SW1	NADINE AVE & RICHLAND AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1973	INT805SE1	NADINE AVE & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1974	INT805NE1	NADINE AVE & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1956	INT843SE1	NADINE AVE & SAUSALITO WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1957	INT843SW1	NADINE AVE & SAUSALITO WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1916	INT920SW1	NADINE AVE & STONUM RD	SW	No	Yes	No	No	No	No	No	SW INFILL AT THIS	P2	L2-b	02	\$ 3,200
1913	INT920NW1	NADINE AVE & STONUM RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1914	INT920NE1	NADINE AVE & STONUM RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L2-b	04	\$ 1,100
1915	INT920SE1	NADINE AVE & STONUM RD	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
1975	INT832NW1	NADINE AVE & WIZARD LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1976	INT832NE1	NADINE AVE & WIZARD LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1961	INT854NW1	NAPA CT & SAUSALITO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1962	INT854SW1	NAPA CT & SAUSALITO WY	SW	Yes	Yes	Yes	Yes	No	No	No		P4-a	L2-b	04	\$ 3,200
1963	INT854SE1	NAPA CT & SAUSALITO WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
78	INT1675NW1	NESTLED OAK CT & WINTER OAK LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
83	INT1675NE1	NESTLED OAK CT & WINTER OAK LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
84	INT1675SW1	NESTLED OAK CT & WINTER OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
768	INT702SE1	NIMO CT & POSHO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
769	INT702SW1	NIMO CT & POSHO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1618	INT1003SW1	NIMROOD DR & URM I AVE	SW	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 3,200
64	MID1746NE1	NO NAME ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
65	MID1746NE2	NO NAME ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L3	09	
67	MID1746NE3	NO NAME ST	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
68	MID1746SE1	NO NAME ST	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
70	MID1747SW1	NO NAME ST	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
72	MID1747NW1	NO NAME ST	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1228	INT1545SE1	NORFOLK WY & SUFFOLK DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1230	INT1545SW1	NORFOLK WY & SUFFOLK DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1220	INT1546NE1	NORFOLK WY & WAYNESBORO DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1223	INT1546NW1	NORFOLK WY & WAYNESBORO DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2218	INT1406SE1	NORTH CANYON DR & RIVER RD	SE	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
2219	INT1406SW1	NORTH CANYON DR & RIVER RD	SW	Yes	Yes	No	No	No	No	Yes	DWS size is not	P4-b	L4	08	\$ 1,100
154	INT1630SE1	NORTHERN OAK DR & WISE OAK LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
155	INT1630SW1	NORTHERN OAK DR & WISE OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
156	INT1630NW1	NORTHERN OAK DR & WISE OAK LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
39	INT1639SW1	OAK GLEN CT & WILD OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
42	INT1639SE1	OAK GLEN CT & WILD OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
44	INT1639NW1	OAK GLEN CT & WILD OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2101	INT1076NW1	OAK GROVE RD & PROMENADE LN	NW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2102	INT1090SW1	OAK GROVE RD & SUN RIDGE CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2103	INT1090NW1	OAK GROVE RD & SUN RIDGE CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2104	INT1090NE1	OAK GROVE RD & SUN RIDGE CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2188	INT1145NE1	OAK RIDGE DR & PINERIDGE DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2189	INT1145SE1	OAK RIDGE DR & PINERIDGE DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2165	INT1146SW1	OAK RIDGE DR & WALTER DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2166	INT1146SE1	OAK RIDGE DR & WALTER DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2167	INT1146NW1	OAK RIDGE DR & WALTER DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2168	INT1146NE1	OAK RIDGE DR & WALTER DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2144	INT1190NE1	OAKBROOKE CT & PAYNE AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2145	INT1190SE1	OAKBROOKE CT & PAYNE AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2146	INT1190NW1	OAKBROOKE CT & PAYNE AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
408	INT1326NW1	OASIS AVE & PYRAMID DR	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
409	INT1326SW1	OASIS AVE & PYRAMID DR	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2605	INT1326E1	OASIS AVE & PYRAMID DR	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1964	INT835SE1	OCEAN WY & PISMO PL	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1965	INT835SW1	OCEAN WY & PISMO PL	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1970	INT793SE1	OCEAN WY & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
1971	INT793NE1	OCEAN WY & RICHLAND AVE	NE	Yes	Yes	Yes	Yes	No	No	No		P4-a	L3	06	\$ 3,200
88	INT1676NW1	OLD OAK DR & WINTER OAK LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
89	INT1676SE1	OLD OAK DR & WINTER OAK LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
90	INT1676SW1	OLD OAK DR & WINTER OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L3	07	\$ 1,100
99	INT1627NE1	OLD OAK DR & WISE OAK LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
100	INT1627SW1	OLD OAK DR & WISE OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
925	INT588SE1	O'LEARY CT & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
926	INT588SW1	O'LEARY CT & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
928	INT588NW1	O'LEARY CT & SAN PEDRO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2542	INT927SW1	OLIVAS CT & PANERO WY	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2127	INT1133NW1	OPENSHAW RD & SHADOWBROOK WY	NW	Yes	Yes	No	Yes	No	No	No	No receiving ramp on	P4-a	L4	08	\$ 1,100
1488	INT1373SE1	ORIOLE DR & STARLING DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1490	INT1373SW1	ORIOLE DR & STARLING DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
586	INT1560SW1	PALLADIN ST & WHITEHAVEN AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
587	INT1560SE1	PALLADIN ST & WHITEHAVEN AVE	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
588	INT1560NE1	PALLADIN ST & WHITEHAVEN AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
406	INT1327NW1	PALM AVE & PYRAMID DR	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
407	INT1327SW1	PALM AVE & PYRAMID DR	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2604	INT1327E1	PALM AVE & PYRAMID DR	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2540	INT929SW1	PANERO WY & PLOUTZ RD	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2541	INT929NW1	PANERO WY & PLOUTZ RD	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2131	INT1111SW1	PARK EAST DR & VINEWOOD DR	SW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 1,100
602	INT1607NW1	PARTRIDGE ST & WHITEHAVEN AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
603	INT1607NE1	PARTRIDGE ST & WHITEHAVEN AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
605	INT1607SE1	PARTRIDGE ST & WHITEHAVEN AVE	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
606	INT1607SW1	PARTRIDGE ST & WHITEHAVEN AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
2161	INT1087NW1	PAYNE AVE & QUILLING CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2162	INT1087NE1	PAYNE AVE & QUILLING CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2163	INT1087SE1	PAYNE AVE & QUILLING CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2147	INT1165SE1	PAYNE AVE & RIVERCREST CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2148	INT1165NE1	PAYNE AVE & RIVERCREST CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2149	INT1165NW1	PAYNE AVE & RIVERCREST CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2150	INT1148NE1	PAYNE AVE & SPRING BROOK CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2151	INT1148SE1	PAYNE AVE & SPRING BROOK CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
2152	INT1148NW1	PAYNE AVE & SPRING BROOK CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L2-b	04	\$ 1,100
1675	MID1727NE1	PEACHWOOD AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1678	MID1728SW1	PEACHWOOD AVE	SW	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 3,200
1680	INT1302SE1	PEACHWOOD AVE & ROSEWOOD AVE	SE	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 3,200
2462	MID1717NW1	PELTOLA ST	NW	No	Yes	No	No	No	No	No	MIDBLOCK	P1	L2-a	01	\$ 3,200
2460	INT724NE1	PELTOLA ST & STEPHANIE WY	NE	No	Yes	No	No	No	No	No	No ramp	P1	L2-a	01	\$ 3,200
2461	INT724SE1	PELTOLA ST & STEPHANIE WY	SE	No	Yes	No	No	No	No	No	No ramp	P1	L2-a	01	\$ 3,200
2456	INT725NW1	PELTOLA ST & STEPHANIE WY	NW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
2458	INT725SW1	PELTOLA ST & STEPHANIE WY	SW	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200
1236	INT1522SW1	PERISBURG CT & PERISBURG LN &	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1237	INT1522NW1	PERISBURG CT & PERISBURG LN &	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1240	INT1522NE1	PERISBURG CT & PERISBURG LN &	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1242	INT1522SE1	PERISBURG CT & PERISBURG LN &	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
929	INT563SE1	PERSAK CT & SAN PEDRO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
930	INT563SW1	PERSAK CT & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
931	INT563NW1	PERSAK CT & SAN PEDRO AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2035	INT953SE1	PETER JOHN WY & RIVER RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2036	INT953SW1	PETER JOHN WY & RIVER RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2033	INT951NE1	PETER JOHN WY & RIVER TREE LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2034	INT951NW1	PETER JOHN WY & RIVER TREE LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2197	INT1294SE1	PETERLAI CT & RIVERBEND DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2198	INT1294SW1	PETERLAI CT & RIVERBEND DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1875	INT808SW1	PHIL WY & RICHLAND AVE	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1876	INT808NW1	PHIL WY & RICHLAND AVE	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1015	INT1494NE1	PISCES WY & VENUS DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1018	INT1494SE1	PISCES WY & VENUS DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1967	INT834NW1	PISMO PL & TRUCKEE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1968	INT834NE1	PISMO PL & TRUCKEE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1969	INT834SE1	PISMO PL & TRUCKEE WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
289	INT1700SE1	PODOCARPUS DR & SOMERSBY LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
291	INT1700SW1	PODOCARPUS DR & SOMERSBY LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1194	INT1542SE1	POPPY LN & PRIMROSE LN	SE	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1191	INT1542NE1	POPPY LN & PRIMROSE LN	NE	Yes	No	No	No	No	No	No	No ramp on other side,	P4-a	L4	08	\$ 1,100
770	INT680SE1	POSHO AVE & SANKO AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
772	INT680NE1	POSHO AVE & SANKO AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
967	INT1504SE1	PUMA WY & TRINA LN	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
969	INT1504NE1	PUMA WY & TRINA LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
971	INT1504NW1	PUMA WY & TRINA LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1004	INT1497NE1	PUMA WY & VENUS DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1006	INT1497NW1	PUMA WY & VENUS DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
404	INT1329SW1	PYRAMID DR & STANDFORD AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
405	INT1329SE1	PYRAMID DR & STANDFORD AVE	SE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2603	INT1329N1	PYRAMID DR & STANDFORD AVE	N	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2581	INT819SE1	RANCHO DR & RICHLAND AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2582	INT819NE1	RANCHO DR & RICHLAND AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1485	INT691SW1	RED GUM CT & RIDLON LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1486	INT691SE1	RED GUM CT & RIDLON LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1487	INT691NE1	RED GUM CT & RIDLON LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1281	INT1535NE1	RHONE DR & TIRANO WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1282	INT1535NW1	RHONE DR & TIRANO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2478	INT791NW1	RICHARD WY & RICHLAND AVE & WINTHROP LN	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2479	INT791NE1	RICHARD WY & RICHLAND AVE & WINTHROP LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2480	INT791SE1	RICHARD WY & RICHLAND AVE & WINTHROP LN	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2481	INT791SW1	RICHARD WY & RICHLAND AVE & WINTHROP LN	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2614	INT1761SE1	RICHARD WY & UNAMED	SE	Yes	No	No	No	No	No	Yes		P4-b	L4	08	\$ 3,200
2585	MID1739NE1	RICHLAND AVE & PRIVATE RD	NE	No	No	No	No	No	No	No	Private street	P4-a	L2-b	04	\$ -
1885	INT801SE1	RICHLAND AVE & STONUM RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1886	INT801NE1	RICHLAND AVE & STONUM RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1990	INT813NE1	RICHLAND AVE & WOODWORTH AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1991	INT813SE1	RICHLAND AVE & WOODWORTH AVE	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2427	INT794NE1	RICHLAND AVE & ZONA BELLA LN	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
2428	INT794SE1	RICHLAND AVE & ZONA BELLA LN	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1476	INT633NE1	RICKMAN WY & RIDLON LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
1478	INT633SE1	RICKMAN WY & RIDLON LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100
1479	INT633SW1	RICKMAN WY & RIDLON LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L3	06	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
1480	INT662SW1	RIDLON CT & RIDLON LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1481	INT662SE1	RIDLON CT & RIDLON LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1483	INT662NW1	RIDLON CT & RIDLON LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1489	INT716SW1	RIDLON LN & SWEET GUM DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1491	INT716NW1	RIDLON LN & SWEET GUM DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1492	INT716NE1	RIDLON LN & SWEET GUM DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1945	MID1720NE1	RIESLING DR	NE	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1946	INT960SW1	RIESLING DR & SAUVIGNON DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1947	INT960NW1	RIESLING DR & SAUVIGNON DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1948	INT960NE1	RIESLING DR & SAUVIGNON DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1691	INT1404NW1	RITA LN & ROSEWOOD AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1692	INT1404NE1	RITA LN & ROSEWOOD AVE	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2266	MID1725NW1	RIVER CREEK CI	NW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2267	MID1725SE1	RIVER CREEK CI	SE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2268	MID1724NE1	RIVER CREEK CI	NE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2269	MID1724SW1	RIVER CREEK CI	SW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2263	INT1273SE1	RIVER CREEK CI & RIVER CREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2264	INT1273SW1	RIVER CREEK CI & RIVER CREEK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2265	INT1273NE1	RIVER CREEK CI & RIVER CREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2270	INT1272SE1	RIVER CREEK CI & RIVER CREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2271	INT1272SW1	RIVER CREEK CI & RIVER CREEK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2272	INT1272NE1	RIVER CREEK CI & RIVER CREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2260	INT1323NW1	RIVER CREEK DR & RIVERETTE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2261	INT1323NE1	RIVER CREEK DR & RIVERETTE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2262	INT1323SW1	RIVER CREEK DR & RIVERETTE DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2114	INT1152SW1	RIVER RAFT CT & WHITEWATER WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2115	INT1152SE1	RIVER RAFT CT & WHITEWATER WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2116	INT1152NE1	RIVER RAFT CT & WHITEWATER WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2122	INT1210NW1	RIVER RD & RUSHING RIVER DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2123	INT1210SW1	RIVER RD & RUSHING RIVER DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2251	INT1289SE1	RIVER ROCK CT & RIVERPARK DR	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2252	INT1289SW1	RIVER ROCK CT & RIVERPARK DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2253	INT1289NW1	RIVER ROCK CT & RIVERPARK DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1402	INT469SE1	RIVER SPRINGS CT & RIVER SPRINGS WY & TRANQUIL LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1403	INT469SW1	RIVER SPRINGS CT & RIVER SPRINGS WY & TRANQUIL LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1404	INT469NW1	RIVER SPRINGS CT & RIVER SPRINGS WY & TRANQUIL LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1405	INT469NE1	RIVER SPRINGS CT & RIVER SPRINGS WY & TRANQUIL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2030	INT971NE1	RIVER TREE LN & SARAH THERESE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2031	INT971NW1	RIVER TREE LN & SARAH THERESE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2032	INT971SW1	RIVER TREE LN & SARAH THERESE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2246	MID1723NW1	RIVER VALLEY CI	NW	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2247	MID1723SE1	RIVER VALLEY CI	SE	Yes	No	No	Yes	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
2248	INT1304SE1	RIVER VALLEY CI & RIVERPARK DR	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2249	INT1304SW1	RIVER VALLEY CI & RIVERPARK DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2250	INT1304NW1	RIVER VALLEY CI & RIVERPARK DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2202	INT1358NW1	RIVERBEND DR & SAND BAR CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2203	INT1358NE1	RIVERBEND DR & SAND BAR CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2204	INT1358SW1	RIVERBEND DR & SAND BAR CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2199	INT1314SW1	RIVERBEND DR & STILLWATER LN	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2200	INT1314SE1	RIVERBEND DR & STILLWATER LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2201	INT1314NE1	RIVERBEND DR & STILLWATER LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2257	INT1324NW1	RIVERETTE DR & RIVERPARK DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2258	INT1324SW1	RIVERETTE DR & RIVERPARK DR	SW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2259	INT1324NE1	RIVERETTE DR & RIVERPARK DR	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2254	INT1270SE1	RIVERPARK CT & RIVERPARK DR	SE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2255	INT1270NW1	RIVERPARK CT & RIVERPARK DR	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
2256	INT1270NE1	RIVERPARK CT & RIVERPARK DR	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
281	INT1420SW1	ROBMAR CT & VERNAL DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
282	INT1420NW1	ROBMAR CT & VERNAL DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
290	INT1420NE1	ROBMAR CT & VERNAL DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1363	INT352SE1	ROCKY BROOK DR & ROCKY FALLS CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1364	INT352SW1	ROCKY BROOK DR & ROCKY FALLS CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1366	INT352NE1	ROCKY BROOK DR & ROCKY FALLS CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1367	INT336SE1	ROCKY BROOK DR & SALMON CREEK CT & SALMON CREEK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1368	INT336NE1	ROCKY BROOK DR & SALMON CREEK CT & SALMON CREEK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1369	INT336NW1	ROCKY BROOK DR & SALMON CREEK CT & SALMON CREEK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
269	INT1351SE1	ROEDING RD & ROSE AVE	SE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
270	INT1351SW1	ROEDING RD & ROSE AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
271	INT1351NE1	ROEDING RD & ROSE AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
272	INT1351NW1	ROEDING RD & ROSE AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-b	09	
279	INT1419NW1	ROEDING RD & VERNAL DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
280	INT1419NE1	ROEDING RD & VERNAL DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2120	INT1203SE1	ROLLING OAK CT & RUSHING RIVER DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2121	INT1203SW1	ROLLING OAK CT & RUSHING RIVER DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2117	INT1204SW1	ROLLING OAK CT & WHITEWATER WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2118	INT1204NW1	ROLLING OAK CT & WHITEWATER WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2119	INT1204SE1	ROLLING OAK CT & WHITEWATER WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2295	INT628SW1	ROLLS ROYCE LN & TYRUS ST	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2296	INT628SE1	ROLLS ROYCE LN & TYRUS ST	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
412	INT1350NE1	ROSE AVE & ROSE CT	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
413	INT1350SE1	ROSE AVE & ROSE CT	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
1681	INT1321NE1	ROSE AVE & ROSEWOOD AVE	NE	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
1683	INT1321SE1	ROSE AVE & ROSEWOOD AVE	SE	Yes	Yes	No	No	Yes	No	No		P4-a	L4	08	\$ 1,100
1685	INT1321SW1	ROSE AVE & ROSEWOOD AVE	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1686	INT1321NW1	ROSE AVE & ROSEWOOD AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
315	INT1352NE1	ROSE AVE & ROSWELL WY	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
316	INT1352SE1	ROSE AVE & ROSWELL WY	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
305	INT1361NE1	ROSE AVE & STANDFORD AVE	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
306	INT1361NW1	ROSE AVE & STANDFORD AVE	NW	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
309	INT1361SE1	ROSE AVE & STANDFORD AVE	SE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L2-a	09	
310	INT1361SW1	ROSE AVE & STANDFORD AVE	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L2-a	09	
1495	INT1343SE1	ROSE AVE & STARLING DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1500	INT1343NE1	ROSE AVE & STARLING DR	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
1497	INT1343NW1	ROSE AVE & STARLING DR	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L2-a	09	
416	INT1363NW1	ROSE AVE & VILLA RAMON DR	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
417	INT1363SW1	ROSE AVE & VILLA RAMON DR	SW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2600	INT1363E1	ROSE AVE & VILLA RAMON DR	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
311	INT1353SW1	ROSE AVE & WIX LN	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
312	INT1353SE1	ROSE AVE & WIX LN	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
313	INT1353NE1	ROSE AVE & WIX LN	NE	Yes	Yes	No	Yes	No	No	No		P1	L2-a	01	\$ 1,100
1695	INT1437NW1	ROSEWOOD AVE & VINELAND LN	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1696	INT1437NE1	ROSEWOOD AVE & VINELAND LN	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
284	INT1423SW1	ROSWELL WY & VERNAL DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
286	INT1423NW1	ROSWELL WY & VERNAL DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
288	INT1423NE1	ROSWELL WY & VERNAL DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1595	INT876NE1	ROYAL ANN DR & TARTARIAN WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1596	INT876NW1	ROYAL ANN DR & TARTARIAN WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1012	INT1495SE1	SAGITTARIUS AVE & VENUS DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1013	INT1495NE1	SAGITTARIUS AVE & VENUS DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1376	INT338SE1	SALMON CREEK DR & STONE SPRINGS DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1377	INT338NW1	SALMON CREEK DR & STONE SPRINGS DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1371	INT337SE1	SALMON CREEK DR & TRANQUIL LN	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1373	INT337NE1	SALMON CREEK DR & TRANQUIL LN	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1374	INT337NW1	SALMON CREEK DR & TRANQUIL LN	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1386	INT520NW1	SAN JUAN RD & SAN PEDRO AVE	NW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1387	INT520SW1	SAN JUAN RD & SAN PEDRO AVE	SW	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
1388	INT520NE1	SAN JUAN RD & SAN PEDRO AVE	NE	Yes	Yes	No	Yes	No	No	Yes		P5	L4	09	
918	INT630SE1	SAN PEDRO AVE & TEEK CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
919	INT630SW1	SAN PEDRO AVE & TEEK CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
921	INT630NE1	SAN PEDRO AVE & TEEK CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2027	INT969SE1	SARAH THERESE WY & TUOLUMNE BEND	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2028	INT969NE1	SARAH THERESE WY & TUOLUMNE BEND	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2029	INT969NW1	SARAH THERESE WY & TUOLUMNE BEND	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1893	INT909NW1	SAUCEDA CT & STONUM RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1894	INT909SW1	SAUCEDA CT & STONUM RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1895	INT909NE1	SAUCEDA CT & STONUM RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1909	INT921NW1	SAUVIGNON DR & STONUM RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1910	INT921SW1	SAUVIGNON DR & STONUM RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1911	INT921NE1	SAUVIGNON DR & STONUM RD	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1912	INT921SE1	SAUVIGNON DR & STONUM RD	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1951	INT943SE1	SAUVIGNON DR & ZINFANDEL PL	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1952	INT943SW1	SAUVIGNON DR & ZINFANDEL PL	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
550	INT1597NE1	SCARLET OAK CT & SOUTHERN OAK DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
552	INT1597SE1	SCARLET OAK CT & SOUTHERN OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
555	INT1597SW1	SCARLET OAK CT & SOUTHERN OAK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1996	INT938NW1	SEDONA CT & TARBORO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1997	INT938NE1	SEDONA CT & TARBORO WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1998	INT938SE1	SEDONA CT & TARBORO WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1742	MID1721SW1	SENIMI CI	SW	Yes	No	No	No	No	No	No	Nowhere to cross to	P4-a	L4	08	\$ 3,200
1560	INT1432SW1	SERGIS CT & SHUSHAN DR	SW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
1561	INT1432NW1	SERGIS CT & SHUSHAN DR	NW	No	Yes	No	No	No	No	No		P2	L4	05	\$ 3,200
2229	INT1290SW1	SHADOW RIDGE DR & VALLEY WIND WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2230	INT1290NW1	SHADOW RIDGE DR & VALLEY WIND WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2231	INT1290NE1	SHADOW RIDGE DR & VALLEY WIND WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2128	INT1110SE1	SHADOWBROOK WY & VINEWOOD DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2129	INT1110NE1	SHADOWBROOK WY & VINEWOOD DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2130	INT1110NW1	SHADOWBROOK WY & VINEWOOD DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
545	INT1602SE1	SILVER OAK CT & SILVER OAK LN & SOUTHERN OAK DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
547	INT1602NW1	SILVER OAK CT & SILVER OAK LN & SOUTHERN OAK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
548	INT1602SW1	SILVER OAK CT & SILVER OAK LN & SOUTHERN OAK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
575	INT1605SE1	SILVER OAK LN & VALLEY OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
576	INT1605SW1	SILVER OAK LN & VALLEY OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
572	INT1604SE1	SILVER OAK LN & WHISPERING OAK DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
573	INT1604SW1	SILVER OAK LN & WHISPERING OAK DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
574	INT1604NW1	SILVER OAK LN & WHISPERING OAK DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
533	INT1603NE1	SILVER OAK LN & WILD OAK DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
535	INT1603NW1	SILVER OAK LN & WILD OAK DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
536	INT1603SW1	SILVER OAK LN & WILD OAK DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
537	INT1603SE1	SILVER OAK LN & WILD OAK DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
895	INT1570NW1	SKEENA AVE & VANDALAY CT & VANDALAY DR	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
898	INT1570NE1	SKEENA AVE & VANDALAY CT & VANDALAY DR	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
901	INT1570SW1	SKEENA AVE & VANDALAY CT & VANDALAY DR	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
902	INT1570SE1	SKEENA AVE & VANDALAY CT & VANDALAY DR	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of compliance	P4-b	L4	08	\$ 1,100
1241	INT479SW1	SKYBRITE DR & SUN MEADOW DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1243	INT479NW1	SKYBRITE DR & SUN MEADOW DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
842	INT693SW1	SODA CANYON CT & SODA CANYON DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
843	INT693NW1	SODA CANYON CT & SODA CANYON DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
844	INT693SE1	SODA CANYON CT & SODA CANYON DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
852	INT689NW1	SODA CANYON DR & SUNGATE CT & SUNGATE DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
853	INT689NE1	SODA CANYON DR & SUNGATE CT & SUNGATE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
854	INT689SE1	SODA CANYON DR & SUNGATE CT & SUNGATE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
849	INT690NW1	SODA CANYON DR & ZENA WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
850	INT690SW1	SODA CANYON DR & ZENA WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
851	INT690SE1	SODA CANYON DR & ZENA WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
558	INT1579NE1	SOUTHERN OAK DR & WHITE OAK CT	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
559	INT1579SE1	SOUTHERN OAK DR & WHITE OAK CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
560	INT1579SW1	SOUTHERN OAK DR & WHITE OAK CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1665	INT770SE1	SOUTHWOOD DR & SUNCREST DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1666	INT770NE1	SOUTHWOOD DR & SUNCREST DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1631	INT906SW1	SOUTHWOOD DR & WOODVIEW DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1633	INT906NW1	SOUTHWOOD DR & WOODVIEW DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1290	INT1537NE1	ST GOTTHARD WY & TIRANO WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1291	INT1537SW1	ST GOTTHARD WY & TIRANO WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
295	INT1421SW1	STANDFORD AVE & VERNAL DR	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
296	INT1421SE1	STANDFORD AVE & VERNAL DR	SE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
402	INT1299NW1	STANDFORD AVE & VILLA RAMON DR	NW	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
403	INT1299NE1	STANDFORD AVE & VILLA RAMON DR	NE	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2606	INT1299S1	STANDFORD AVE & VILLA RAMON DR	S	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
105	INT1629NE1	STANDING OAK DR & WISE OAK LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
107	INT1629SE1	STANDING OAK DR & WISE OAK LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
110	INT1629SW1	STANDING OAK DR & WISE OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1270	INT501SW1	STARBOARD WY & TWILIGHT DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1271	INT501SE1	STARBOARD WY & TWILIGHT DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2459	MID1716SE1	STEPHANIE WY	SE	No	Yes	No	No	No	No	No	No ramp	P2	L4	05	\$ 3,200

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2223	INT1310NE1	STILLWATER LN & WILLOW CREEK CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2224	INT1310SE1	STILLWATER LN & WILLOW CREEK CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2225	INT1310SW1	STILLWATER LN & WILLOW CREEK CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2499	INT904NE1	STONECRESS & STONEHENGE WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2500	INT904SW1	STONECRESS & STONEHENGE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2501	INT904NW1	STONECRESS & STONEHENGE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2502	INT905NW1	STONEHAVEN WY & STONEHENGE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1896	INT918NW1	STONUM RD & TARBORO WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1897	INT918NE1	STONUM RD & TARBORO WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1898	INT918SE1	STONUM RD & TARBORO WY	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1887	INT866SW1	STONUM RD & VAN NORSTRAND CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1888	INT866NE1	STONUM RD & VAN NORSTRAND CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1889	INT866SE1	STONUM RD & VAN NORSTRAND CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1040	INT660SW1	STRAWBERRY DR & TWIN BRIDGES DR	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1246	INT1512NW1	SUFFOLK DR & WAYNESBORO CT & WAYNESBORO DR	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1248	INT1512SW1	SUFFOLK DR & WAYNESBORO CT & WAYNESBORO DR	SW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1251	INT1512SE1	SUFFOLK DR & WAYNESBORO CT & WAYNESBORO DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1254	INT1512NE1	SUFFOLK DR & WAYNESBORO CT & WAYNESBORO DR	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1238	INT420SE1	SUN MEADOW DR & SUNDALE DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1239	INT420NE1	SUN MEADOW DR & SUNDALE DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1063	INT565NE1	THOMASNELL WY & VICKINELL PL	NE	Yes	No	No	Yes	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1022	INT594SW1	TOMBA DR & VALENTINA WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1024	INT594NW1	TOMBA DR & VALENTINA WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1025	INT594NE1	TOMBA DR & VALENTINA WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1980	INT844SW1	TOTO CT & YELLOW BRICK RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1981	INT844NW1	TOTO CT & YELLOW BRICK RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1982	INT844SE1	TOTO CT & YELLOW BRICK RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1406	INT440SE1	TRANQUIL LN & WILLOW POND CT	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1407	INT440SW1	TRANQUIL LN & WILLOW POND CT	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1408	INT440NW1	TRANQUIL LN & WILLOW POND CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
976	MID1731SE1	TRINA LN	SE	Yes	No	No	No	No	No	No	Nothing to cross to	P4-a	L4	08	\$ 1,100
1277	INT523NW1	TWILIGHT DR & WISHING WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1278	INT523NE1	TWILIGHT DR & WISHING WY	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1020	INT1493SE1	URANUS DR & VENUS DR	SE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
21	INT67SE1	USTICK RD & W WHITMORE AVE	SE	No	No	No	No	No	No	No	County NE corner has ramp w/Sidewalks. NW and SW no sidewalk or	P4-a	L3	06	\$ -
1125	INT426NW1	VALLEY BROOK DR & WILLOW LAKE WY	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1126	INT426SW1	VALLEY BROOK DR & WILLOW LAKE WY	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
292	INT1422SW1	VERNAL DR & WIX LN	SW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
293	INT1422NW1	VERNAL DR & WIX LN	NW	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
294	INT1422NE1	VERNAL DR & WIX LN	NE	Yes	Yes	No	No	No	No	No		P1	L2-a	01	\$ 1,100
2608	MID1760W1	VILLA RAMON DR	W	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2609	MID1760E1	VILLA RAMON DR	E	Yes	Yes	No	Yes	No	No	Yes	No field survey - newly	P5	L4	09	
2496	INT823NE1	WEATHERVANE LN & WESTVIEW DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

City of Ceres
Curb Ramp Summary List

UNIQUE ID	FACILITY ID	INTERSECTION NAME	QUADRANT	RAMP PRESENT	RAMP NEEDED	DISPLACEMENT	TACT GROOVES	EXCESS SLOPE	OBSTRUCTION	DWS INSTALLED	NOTES	PHYSICAL RANK	LOCATION RANK	OVERALL RANK	*COST ESTIMATE (\$)
2497	INT823SE1	WEATHERVANE LN & WESTVIEW DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
616	INT1578SW1	WHITE FALL CT & WHITEHAVEN AVE	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
618	INT1578NW1	WHITE FALL CT & WHITEHAVEN AVE	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
620	INT1578NE1	WHITE FALL CT & WHITEHAVEN AVE	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
60	INT1674SW1	WILD OAK DR & WINTER OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
62	INT1674SE1	WILD OAK DR & WINTER OAK LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
66	INT1674NE1	WILD OAK DR & WINTER OAK LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
33	INT1628NW1	WILD OAK DR & WISE OAK LN	NW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
34	INT1628SW1	WILD OAK DR & WISE OAK LN	SW	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
35	INT1628SE1	WILD OAK DR & WISE OAK LN	SE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
37	INT1628NE1	WILD OAK DR & WISE OAK LN	NE	Yes	Yes	No	No	No	No	Yes	DWS size out of	P4-b	L4	08	\$ 1,100
1409	MID1748NE1	WILLOW POND CT	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1410	MID1748NW1	WILLOW POND CT	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
2070	INT717NW1	WINEPRESS LN & WOODWORTH AVE	NW	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
2071	INT717NE1	WINEPRESS LN & WOODWORTH AVE	NE	Yes	Yes	No	No	No	No	No		P4-a	L4	08	\$ 1,100
1977	INT833SE1	WIZARD LN & YELLOW BRICK RD	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1978	INT833SW1	WIZARD LN & YELLOW BRICK RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1979	INT833NE1	WIZARD LN & YELLOW BRICK RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1623	INT908NW1	WOODVIEW CT & WOODVIEW DR	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1624	INT908NE1	WOODVIEW CT & WOODVIEW DR	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1626	INT908SE1	WOODVIEW CT & WOODVIEW DR	SE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1983	INT858SW1	WOODWORTH AVE & YELLOW BRICK RD	SW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1984	INT858NW1	WOODWORTH AVE & YELLOW BRICK RD	NW	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100
1985	INT858NE1	WOODWORTH AVE & YELLOW BRICK RD	NE	Yes	Yes	No	Yes	No	No	No		P4-a	L4	08	\$ 1,100

TOTALS: \$ 2,734,700

***Preliminary Construction Estimate based on the following:**

Install DWS only	\$ 1,100
Reconstruct curb ramps (displacement/excessive slopes)	\$ 3,200
Reconstruct curb ramps (due to obstruction)	\$ 5,600

NOTES:

Cost for installing DWS only, some locations may need additional concrete sections remove/replaced in order to install the DWS correctly
Ramps that are present but noted Ramp Needed = "NO" are estimated for remove/replace with sidewalk.